



Manual 21 Update 15

Rules and Procedures for Determination of Generating Capability

Jerry Bell

Resource Adequacy Planning Dept

Planning Committee

April 6th, 2021

- Biennial review and minor restructuring
- Proper use of weather data for verification tests

- Provisions for testing units that were mothballed or existing units that want to enter the markets have been moved from the capability verification testing section (1.3.3) to the CAPMOD testing section (1.3.2)
 - Units returning from mothballed status or existing units entering the markets for the first time or after an absence need to CAPMOD so they should be in the CAPMOD section

- Weather data used on verification tests must be used consistently
 - Both observed and rated generator site conditions shall be based on plant weather station records or local weather bureau records.
 - Both rated and observed generator site conditions shall be obtained from the same weather data source.
 - All generators at the same plant shall use the same weather data source.
 - Local weather bureau records can be attained from, organizations such as NOAA, universities, colleges and commercial weather services. It is expected that the weather data used, originates from weather collection devices/systems that are proven and calibrated by certified personnel on a regular basis.
 - If barometric pressure values are used for test corrections, rated conditions or for determining rated ICAP the barometric pressure values must be corrected to plant elevation.

SME/Presenter:
Jerry Bell

Jerry.Bell@pjm.com



Member Hotline

(610) 666 – 8980

(866) 400 – 8980

custsvc@pjm.com