

# Generator Deliverability Testing Results

- PJM has completed testing of the new generator deliverability procedures on the 2026 RTEP summer base case and has identified about 15 new upgrades.
- PJM plans to complete testing of the new procedures on the 2026 RTEP winter and light load base cases over the next couple of weeks.
- PJM has run preliminary testing of the new higher deliverability requirements for wind and solar that will be part of the new procedures on the AG1 queue impact study base case (2024 RTEP summer base case).
  - Applied commercial probabilities
  - Seeing on the order of a 20% increase in network upgrade requirements
- PJM expects to complete this testing on the AG1 queue impact study base case for both summer and light load over the next month.