

PJM Load Model Selection for 2023 Reserve Requirement Study (RRS)

Patricio Rocha Garrido Resource Adequacy Planning RAAS July 7, 2023




- The Load Model Selection analysis is performed under Assumptions Set #1 (i.e., assumptions for PRISM)
- The Load Model Selection analysis is performed due to the fact that the Coincident Peak distributions from the PJM Load Forecast cannot be used directly in PRISM
- The analysis is based on method approved at June 9, 2016 PC meeting (Appendix V in 2016 RRS Assumptions Letter)
 - Selected Load Model should be a good match of CP1 distribution from PJM load Forecast
 - Consideration of historical PJM / World load diversity
- This year the analysis is based on the 2023 Load Forecast Report.
 Focus is on 2027/28 Delivery Year.



Load Model Candidate vs CP1 from Load Forecast

Peak Day (CP1) Cumulative Distribution






PJM Load Model Combinations to Assess

- A total of 153 Load Models are examined
 - Ranging from a 23-year Load Model (i.e. calculated using data from a 23 year period) to several 7-year Load Models
 - Load Models built with less than 7 years of data are not considered




Load Forecast Model CP1 Distribution - 2023 vs 2022








Approach $1-70^{th}$ percentile and above





Approach 2 – 70th percentile and above

Approach #2 Results





Approach #1. Top Ranked

- 53208: 2013-2019

– 53209: 2012-2018

- 53143: 2003-2012

Approach #2. Top Ranked

- 53208: 2013-2019

- 53209: 2012-2018

- 53143: 2003-2012



Comments about results from Approaches #1 and #2

- There is convergence between Approaches #1 and #2 regarding the top ranked LMs in the 70th percentile and above of the CP1 distribution
 - Such convergence also occurs when examining the 90th percentile and above and the 70th to 95th percentile range of the CP1 distribution (not shown in slides)
- Therefore, the shortlisted Load Models are:
 - 53208: 2013-2019
 - **-** 53209: 2012-2018
 - **–** 53143: 2003-2012
- Last year's selected Load Model (2002-2012) is not in the shortlist



- To analyze PJM/World peak load diversity, World Load Models were created using the PLOTS program, observing the same historical time periods
 - Uses historical coincident peak pattern
 - World defined as MISO, NY, TVA, and VACAR.



LM #53208 (2013-2019) - PJM vs World Assessment

| | | PJM RTO LM #53208 7 Yr Load Model - 2013 - 2019 | | | World Region LM #53214 | | |
|--------|-----|---|-----------|--------|---------------------------|-----------|--------|
| Month | WK# | PLOTS Mean | PLOTS STD | EWM | PLOTS Mean | PLOTS STD | EWM |
| June | 5 | 0.9189 | 0.0989 | 0.9442 | 0.9495 | 0.0547 | 0.9565 |
| June | 6 | 0.8927 | 0.0788 | 0.8980 | 0.9352 | 0.0558 | 0.9433 |
| June | 7 | 0.7538 | 0.0615 | 0.7443 | 0.8311 | 0.0489 | 0.8319 |
| July | 8 | 0.9040 | 0.0937 | 0.9497 | 0.8792 | 0.0745 | 0.9059 |
| July | 9 | 0.7906 | 0.0825 | 0.8209 | 0.9201 | 0.0387 | 0.9118 |
| July | 10 | 0.9518 | 0.0937 | 1.0000 | 1.0000 | 0.0469 | 1.0000 |
| July | 11 | 0.8864 | 0.0566 | 0.8950 | 0.9177 | 0.0556 | 0.9265 |
| August | 12 | 0.7044 | 0.0620 | 0.8173 | 0.8198 | 0.0477 | 0.9926 |
| August | 13 | 0.8024 | 0.0832 | 0.9524 | 0.8109 | 0.0357 | 0.9690 |
| August | 14 | 0.8482 | 0.0565 | 0.9783 | 0.7893 | 0.0445 | 0.9523 |
| August | 15 | 0.7823 | 0.0587 | 0.9044 | 0.7796 | 0.0398 | 0.9358 |



LM #53209 (2012-2018) - PJM vs World Assessment

| | | PJM RTO LM #53209 7 Yr Load Model - 2012 - 2018 | | | World Region LM #53215 | | |
|--------|-----|---|-----------|--------|---------------------------|-----------|--------|
| Month | WK# | PLOTS Mean | PLOTS STD | EWM | PLOTS Mean | PLOTS STD | EWM |
| June | 5 | 0.8859 | 0.0581 | 0.8934 | 0.9192 | 0.0414 | 0.9372 |
| June | 6 | 0.9246 | 0.0697 | 0.9442 | 0.9248 | 0.0543 | 0.9565 |
| June | 7 | 0.7970 | 0.0772 | 0.8204 | 0.8717 | 0.0493 | 0.8966 |
| July | 8 | 0.9247 | 0.1030 | 0.9455 | 0.9332 | 0.0656 | 0.9463 |
| July | 9 | 0.7864 | 0.0577 | 0.7662 | 0.8773 | 0.0772 | 0.9008 |
| July | 10 | 1.0000 | 0.0819 | 1.0000 | 1.0000 | 0.0528 | 1.0000 |
| July | 11 | 0.8935 | 0.0758 | 0.8878 | 0.9434 | 0.0710 | 0.9621 |
| August | 12 | 0.8025 | 0.0821 | 0.9483 | 0.8939 | 0.0520 | 0.9926 |
| August | 13 | 0.8511 | 0.0564 | 0.9783 | 0.8478 | 0.0500 | 0.9394 |
| August | 14 | 0.7422 | 0.0656 | 0.8618 | 0.7342 | 0.0564 | 0.8192 |
| August | 15 | 0.7872 | 0.0780 | 0.9263 | 0.7697 | 0.0435 | 0.8467 |



LM #53143 (2003-2012) - PJM vs World Assessment

| | | PJM RTO LM #53143 10 Yr Load Model - 2003 - 2012 | | | World Region LM #53216 | | |
|--------|-----|--|-----------|--------|---------------------------|-----------|--------|
| Month | WK# | PLOTS Mean | PLOTS STD | EWM | PLOTS Mean | PLOTS STD | EWM |
| June | 5 | 0.8033 | 0.0551 | 0.8302 | 0.8526 | 0.0451 | 0.8757 |
| June | 6 | 0.9056 | 0.0632 | 0.9442 | 0.9189 | 0.0455 | 0.9442 |
| June | 7 | 0.8775 | 0.0421 | 0.8939 | 0.9288 | 0.0475 | 0.9565 |
| July | 8 | 0.9078 | 0.0434 | 0.8735 | 0.9059 | 0.0369 | 0.9073 |
| July | 9 | 0.9146 | 0.0673 | 0.9033 | 0.9483 | 0.0423 | 0.9556 |
| July | 10 | 1.0000 | 0.0788 | 1.0000 | 0.9990 | 0.0363 | 1.0000 |
| July | 11 | 0.9333 | 0.0755 | 0.9300 | 0.9586 | 0.0497 | 0.9738 |
| August | 12 | 0.9763 | 0.0634 | 0.9783 | 1.0000 | 0.0597 | 0.9926 |
| August | 13 | 0.9413 | 0.0735 | 0.9535 | 0.9784 | 0.0409 | 0.9513 |
| August | 14 | 0.8800 | 0.0576 | 0.8763 | 0.9209 | 0.0298 | 0.8845 |
| August | 15 | 0.8368 | 0.0714 | 0.8458 | 0.8797 | 0.0519 | 0.8659 |



- Both selected load models have PJM peaking on the same week as the World
- Load Model #53208: 2003-2019 has a better overall performance under both approaches.
 - Ranked 1st using both approaches when examining multiples ranges in the CP1 distribution:
 - 70th percentile and above
 - 90th percentile and above
 - Between 75th and 95th percentiles



Historical Peak Load Coincidence PJM / World

| Year | PJM Peak - Actual Date | World Peak - Actual Date | Peak Coincidence? |
|------|------------------------|--------------------------|-------------------|
| 1998 | 21-Jul-98 | 21-Jul-98 | Yes |
| 1999 | 30-Jul-99 | 28-Jul-99 | No |
| 2000 | 9-Aug-00 | 31-Aug-00 | No |
| 2001 | 9-Aug-01 | 8-Aug-01 | No |
| 2002 | 1-Aug-02 | 1-Aug-02 | Yes |
| 2003 | 21-Aug-03 | 14-Aug-03 | No |
| 2004 | 3-Aug-04 | 2-Aug-04 | No |
| 2005 | 26-Jul-05 | 25-Jul-05 | No |
| 2006 | 2-Aug-06 | 1-Aug-06 | No |
| 2007 | 8-Aug-07 | 8-Aug-07 | Yes |
| 2008 | 9-Jun-08 | 21-Jul-08 | No |
| 2009 | 10-Aug-09 | 10-Aug-09 | Yes |
| 2010 | 7-Jul-10 | 4-Aug-10 | No |
| 2011 | 21-Jul-11 | 20-Jul-11 | No |
| 2012 | 17-Jul-12 | 17-Jul-12 | Yes |
| 2013 | 18-Jul-13 | 18-Jul-13 | Yes |
| 2014 | 7-Jan-14 | 7-Jan-14 | Yes |
| 2015 | 28-Jul-15 | 28-Jul-15 | Yes |
| 2016 | 11-Aug-16 | 22-Jul-16 | No |
| 2017 | 19-Jul-17 | 20-Jul-17 | No |
| 2018 | 28-Aug-18 | 29-Jun-18 | No |
| 2019 | 19-Jul-19 | 19-Jul-19 | Yes |
| 2020 | 20-Jul-20 | 20-Jul-20 | Yes |
| 2021 | 24-Aug-21 | 24-Aug-21 | Yes |

In the last 24 years, PJM and the World **have not peaked** on the same day 13 times.



LM #53208 (2013-2019) - Switching of World peak week

| | | PJM RTO LM #53208 7 Yr Load Model - 2013 - 2019 | World Region LM #53214 |
|-------|-----|--|---------------------------|
| Month | WK# | Per-Unitized Peak | Per-Unitized Peak |
| July | 8 | 0.9497 | 0.9059 |
| July | 9 | 0.8209 | 0.9118 |
| July | 10 | 1.0000 | 0.9265 |
| July | 11 | 0.8950 | 1.0000 |



2023 RRS Load Model Recommendation

- PJM recommendation to RAAS on selection of historical time period for load model:
 - Use 7yr (2013-2019, #53208) Load Model for 2023 RRS Base Case and switch World peak to a different July week so that PJM and World peak in the same month but not in the same week.