Apply Conductor Coating Technology to Lines 11620 & 11622 Elwood - Goodings Grove

General Information

Proposing entity name COMED

Does the entity who is submitting this proposal intend to be the

Designated Entity for this proposed project?

Yes

Company proposal ID

PJM Proposal ID 937

Apply Conductor Coating Technology to Lines 11620 & 11622 Elwood - Goodings Grove Project title

Project description Apply conductor coating to lines 11620 & 11622 from Elwood to Goodings Grove. The coating

increases emissivity and reduces absorptivity of the conductor, allowing for increased ratings. This

technology was presented at PJM's Emerging Technology Forum on 3/17/21.

Email Personal email redacted.

06/2028 Project in-service date

Tie-line impact No

Interregional project No

Is the proposer offering a binding cap on capital costs? No

Additional benefits Introduces this new technology on the PJM system.

Project Components

1. Apply Coating to 345 kV Lines 11620 & 11622

Transmission Line Upgrade Component

Component title Apply Coating to 345 kV Lines 11620 & 11622

Project description Proprietary information

2023-W1-937

Impacted transmission line 11620 & 11622

Point A Elwood

Point B Goodings Grove

Point C

Terrain description

The lines are on existing ComEd right-of-way over flat terrain. Approximately half of the terrain is farmland with the rest bordering industrial, residential, and wooded lands. There are two interstate highway crossings.

Existing Line Physical Characteristics

Operating voltage 345

Conductor size and type 2156 ACSR Bluebird

Hardware plan description Existing line hardware will not be changed.

Tower line characteristics 345 kV lines 11620 and 11622 are on a to

345 kV lines 11620 and 11622 are on a total of 104 structures ranging in age from 3 to 54 years. The structures are a combination of lattice and steel monopoles. These structures were inspected within the last 5 years with approximately 40 percent of them being replaced in 2020 to accommodate additional generation at TSS 900 Elwood.

Operating

Emergency ratings

Proposed Line Characteristics

Voltage (kV)	345.000000	345.000000

Designed

Normal ratings

Summer (MVA)	1441.000000	1830.000000
Winter (MVA)	1702.000000	2021.000000

Conductor size and type 2156 ACSR Bluebird with ceramic coating

Shield wire size and type

The shield wire will not be replaced

Rebuild line length 18.7 miles

2023-W1-937

Rebuild portion description No rebuild will be necessary. Right of way The existing ROW will be utilized. ComEd Construction responsibility Benefits/Comments **Component Cost Details - In Current Year \$** Engineering & design Detailed cost estimates broken down by category are considered proprietary information and are redacted. Permitting / routing / siting Detailed cost estimates broken down by category are considered proprietary information and are redacted. ROW / land acquisition Detailed cost estimates broken down by category are considered proprietary information and are redacted. Materials & equipment Detailed cost estimates broken down by category are considered proprietary information and are redacted. Construction & commissioning Detailed cost estimates broken down by category are considered proprietary information and are redacted. Construction management Detailed cost estimates broken down by category are considered proprietary information and are redacted. Detailed cost estimates broken down by category are considered proprietary information and are Overheads & miscellaneous costs redacted. Contingency Detailed cost estimates broken down by category are considered proprietary information and are redacted. Total component cost \$8,523,936.00 Component cost (in-service year) \$9,881,578.00

Congestion Drivers

None

2023-W1-937

Existing Flowgates

FG#	Fr Bus No.	From Bus Name	To Bus No.	To Bus Name	СКТ	Voltage	TO Zone	Analysis type	Status
2023W1-GD-S57	1270736	ELWOOD ; B	270770	GOODINGS ;4B	1	345	222	Summer Gen Deliv	Included
2023W1-GD-S12	5 2 70737	ELWOOD ; R	270769	GOODINGS ;2R	1	345	222	Summer Gen Deliv	Included
2023W1-GD-S54	8270737	ELWOOD ; R	270769	GOODINGS ;2R	1	345	222	Summer Gen Deliv	Included
2023W1-GD-S19	0270737	ELWOOD ; R	270769	GOODINGS ;2R	1	345	222	Summer Gen Deliv	Included
2023W1-GD-S56	3270736	ELWOOD ; B	270770	GOODINGS ;4B	1	345	222	Summer Gen Deliv	Included
2023W1-GD-S55	4270737	ELWOOD ; R	270769	GOODINGS ;2R	1	345	222	Summer Gen Deliv	Included
2023W1-GD-S12	6 2 70736	ELWOOD ; B	270770	GOODINGS ;4B	1	345	222	Summer Gen Deliv	Included
2023W1-GD-S57	0270736	ELWOOD ; B	270770	GOODINGS ;4B	1	345	222	Summer Gen Deliv	Included

New Flowgates

None

Financial Information

Capital spend start date 01/2027

Construction start date 01/2027

Project Duration (In Months) 17

Additional Comments

None

2023-W1-937 4