

Effective Date	February 25, 2019
Impacted Manual #(s)/Manual Title(s):	
M-12 Balancing Operations V39	
Conforming Order(s):	
None	
Associated Issue Tracking Title:	N/A
Committee Approval Path - What committee(s) have already seen these changes?	
Planned committee reviews/endorsements: SOS: January 4, 2019, February 1, 2019 OC: January 8, 2019, February 5, 2019 (Endorsement) MRC: January 24, 2019, February 21, 2019 (Endorsement)	
MRC 1st read date:	January 24, 2019
MRC voting date:	February 21, 2019
Impacted Manual sections:	
<ul style="list-style-type: none"> • New Sub-section 3.6 Primary Frequency Response • Clean up in Section 3 and Attachment D 	
Reason for change:	
<ul style="list-style-type: none"> • Added PFR performance evaluation details associated with FERC Order 842– Primary Frequency Response and PFRSTF recommended path forward. • Cover-to-cover periodic review 	
Summary of the changes:	
<ul style="list-style-type: none"> • Details frequency response calculation for high & low frequency events • Addresses when a resource will be evaluated for PFR and when a resource will not be evaluated • Details follow-up process for identified non-performance • Details event selection criteria for performance evaluation and quarterly review process • Removed versioning for BAL standard 	