

Effective Date	5/26/2021
Impacted Manual #(s)/Manual Title(s):	
Manual 21 – Rules and Procedures for Determination of Generating Capability	
Conforming Order(s):	
N/A	
Associated Issue Tracking Title:	N/A
Committee Approval Path - What committee(s) have already seen these changes?	
PC – First Read – 4/6/2021 MRC – First Read – 4/21/2021 PC – Seek Endorsement– 5/11/2021 MRC – Seek Endorsement – 5/26/2021	
MRC 1st read date:	4/21/2021
MRC voting date:	5/26/2021
Impacted Manual sections:	
<ol style="list-style-type: none"> 1) Added more detail about host and process load in Section 1.2 2) Added a new subsection 2.1.1 which delineates the proper usage of weather data and specifies that barometric pressure values must be adjusted for plant elevation 	
Reason for change:	
<ol style="list-style-type: none"> 1) Biennial review 2) To ensure generator owners/agents use weather data and barometric pressure properly 	
Summary of the changes:	
Biennial review	