

Dynamic Line Rating Installation on Three PPL Circuits

DLR Project Initiation

PPL requested RTR manage the installation of the Ampacimon devices on the Juniata-Cumberland and Susquehanna-Harwood 1&2 230kV lines.



- Asset Owner
- Project Owner
- IT and PJM Integration
- NERC-CIP Compliance



- DLR System/Sensor Provider
- Line Capacity Modeling
- DLR Configuration
- IT Integration with PPL



- Determination of Installation Methods
 - Heli Live Line + Ground Crew (for select spans)
- Create and submit tickets to TCC
 - Both Live Line and Outage
- Line Crossings
- Environmental Permitting



- Regional Operator
- Accept 1-Day ahead DLR ratings




Background

High congestion costs projected in 2025

Harwood to Susquehanna | 230 kV | ACSS | 2040A Static Rating

Juniata to Cumberland | 230 kV | ACSR | 1240A Static Rating

2020/21 RTEP Market Efficiency Window Eligible Energy Market Congestion Drivers* (Posted 03-05-2021)				ME Base Case (Annual Congestion \$million)		ME Base Case (Hours Binding)	
FG#	Constraint	FROM AREA	TO AREA	2025 Simulated Year	2028 Simulated Year	2025 Simulated Year	2028 Simulated Year
ME-1	Kammer North to Natrium 138 kV	AEP	AEP	\$ 2.02	\$ 6.56	69	167
ME-3	Junction to French's Mill 138 kV	APS	APS	\$ 9.18	\$ 11.97	276	301
ME-4	Yukon to AA2-161 Tap 138 kV	APS	APS	\$ 4.36	\$ 5.16	1742	1958
ME-5	Charlottesville to Proffit Rd Del Pt 230 kV	DOM	DOM	\$ 3.76	\$ 4.96	121	124
ME-6	Plymouth Meeting to Whitpain 230 kV	PECO	PECO	\$ 3.33	\$ 4.09	111	101
ME-7	Cumberland to Juniata 230 kV***	PLGRP	PLGRP	\$ 9.00	\$ 6.61	213	179
ME-8	Harwood to Susquehanna 230 kV***	PLGRP	PLGRP	\$ 14.49	\$ 8.69	830	501



Solutions Considered

Reconductor



Double Circuit



Dynamic Line Rating



Time to Implement	2 – 3 Years	3 – 5 Years	Months
Downtime	Extended Outages	Extended Outages	No Outages Required
Cost	\$0.5 M per mile	\$2 - 3 M per mile	< \$1 M
Est Capacity Benefit	+ 34%	+ 106%	+10 – 30%

What is DLR?

System of line sensors installed to measure conductor and real-time environmental data in order to determine the true capacity and forecasted capacity

❑ Static Line Ratings

Assumes

- Wind speed
- Ambient Temp
- Solar Radiation
- 2 Seasons (Planning)

Conservatively Calculates Ratings

No way to measure field conditions, ensure safe operations, or line health

❑ Dynamic Line Ratings

Measures

- Wind Speed
- Ambient Temp
- Conductor Temp
- Conductor Sag

Accurate Real-Time and Forecasted Ratings

Measures Conductor Health

Perpendicular wind is the key factor to increasing capacity

DLR sensors must accurately measure the actual wind speed that each critical span is experiencing

Wind estimates based on weather station data alone have proven to be inaccurate




U.S. Department of Energy | April 2014

Operating Conditions	Change in Conditions	Impact on Capacity
Ambient temperature	2 °C decrease	+ 2%
	10 °C decrease	+ 11%
Solar radiation	Cloud shadowing	+/- a few percent
	Total eclipse	+ 18%
Wind	3 ft./s increase, 45° angle	+ 35%
	3 ft./s increase, 90° angle	+ 44%

Source: Navigant Consulting, Inc. (Navigant) analysis; data from (7)


Table 1. Impacts of Changing Operating Conditions on Transmission Line Capacity

Dynamic Line Ratings Process



Planning for DLR

Ampacimon DLR Simulations



Design Data

- Geospatial model of each line span
- Conductor diameter, aluminum section, steel section
- Absorptivity, emissivity
- Resistance at 20°C
- Temperature resistance coefficient
- Maximum conductor temperature
- Number of sub-conductors
- Seasonal ratings

Weather Data

- Wind Speed
- Wind Direction
- Ambient Temperature
- Solar Radiation


ADR VIEW IN A NUTSHELL

Input data:

- Historic weather data covering surveyed area
- Line design data and existing ratings
- Conductor features
- Span design data

Deliverables:

- ADR View report containing statistics, histograms,
- Time-stamped data in .csv format
- Presentation of results by an Ampacimon expert (face-to-face or conference call)




DLR Simulation Results

Steady-state DLR at emergency rating temperature


SUSQ-HARW Summer Emergency Rating (MVA)
(April-September)

Greater than static 100% of the time




SUSQ-HARW Winter Emergency Rating (MVA)
(October-March)

Greater than static 98.9% of the time



Target Span Identification


1 Critical Span Distribution From DLR Simulation



2 Required Span Selection Rules

- Orientation between spans changes more than 15°
- Distance is greater than 10 km
- Conductor or number of sub-conductor change
- Span safety concerns
- Utility span data identifies high risk span(s)

3 Final Span Selection



Preparing for Installation

Susquehanna – Harwood | 2 Circuits | 12 Sensors

Juniata - Cumberland | 1 Circuit | 6 Sensors

- Assembled Crewing Required
- Conducted Crew Training on Sensor Mounting Procedure
- Practiced Mounting Procedures
- Shepherded outage tickets through the PL ticket process
- Energized Sensors Prior to Install to Ensure Functionality and Connectivity
- Physical Install Challenges:
 - Heavy Snowfall and Wind
 - Existing Environment Permits in the Area
 - Needed ground installation for some spans due to adverse weather conditions -> Took advantage of existing outage window for ground installation




Sensor Deployment

Susquehanna – Harwood | 2 Circuits | 12 Sensors

Juniata - Cumberland | 1 Circuit | 6 Sensors

- Installed December 2020
- One phase per identified span
- Sensor mounted 5 – 10% of the total span length from either tower
- Live Line Installation Via Helicopter
 - Select spans installed from ground
- Mounting procedure is 5 - 10 minutes per sensor



Upcoming Work for PPL

- Definition of formal ratings procedure being developed by PPL in partnership with PJM
- Integration of ratings into PJM 1-day ahead operations and market to clear congestion violations
- Finalize IT System with NERC-CIP Compliance



Ryan Robinson

Owner

RTR Energy Solutions

RRobinson@rtrenergysolutions.com

Cell: 724-550-5010



Bill Skumanich

Program Manager

RTR Energy Solutions

Bills@rtrenergysolutions.com

Cell: 484-627-4405



Joey Alexander

Director, Business Development

Ampacimon

Joey.Alexander@Ampacimon.com

Cell: 678-231-9473

Joey Alexander | Director, Business Development | Ampacimon, Inc
678 231 9473 | Joey.Alexander@Ampacimon.com | Atlanta, GA

