

# Subregional RTEP Committee – Mid-Atlantic – BGE Supplemental Projects

March 17, 2022

# Needs

Stakeholders must submit any comments within 10 days of this meeting in order to provide time necessary to consider these comments prior to the next phase of the M-3 process

**Need Number:** BGE-2022-004

**Process Stage:** Need Meeting 3/17/2022


**Project Driver:** Equipment Material Condition, Performance, and Risk

**Specific Assumption Reference:**

- Transmission infrastructure replacements (EOL/condition/obsolescence) that are consistent with efficient asset management decisions
- Programmatic review and/or replacement of breakers, relays, wood poles, cables, etc.

**Problem Statement:**

- High Ridge 230/115 kV transformer 230-1 installed in 1960 is in deteriorating condition and has elevated maintenance costs.



# Solutions

Stakeholders must submit any comments within 10 days of this meeting in order to provide time necessary to consider these comments prior to the next phase of the M-3 process

**Need Number:** BGE-2022-001

**Process Stage:** Solution Meeting 3/17/2022

**Previously presented:** Need Meeting 2/17/2022


**Project Driver:** Equipment Material Condition, Performance, and Risk

**Specific Assumption Reference:**

- Transmission infrastructure replacements (EOL/condition/obsolescence) that are consistent with efficient asset management decisions
- Programmatic review and/or replacement of breakers, relays, wood poles, cables, etc.

**Problem Statement:**

- Windy Edge 115kV circuit breaker #B6 installed in 1971 is in deteriorating condition due to oil leaks, air system leaks operational problems that led to several failures-to-close and elevated maintenance costs



**Need Number:** BGE-2022-001

**Process Stage:** Solution Meeting – March 17, 2022

**Proposed Solution:**

Replace Windy Edge circuit breaker #B6

The estimated cost of the project is \$1.3M

Existing rating 1600 A, 50kA

New rating 3000 A, 63kA


**Alternatives Considered:**

None

**Projected In-Service:** 4/7/2022

**Project Status:** Engineering

**Model:** 2026 RTEP



**Need Number:** BGE-2022-002

**Process Stage:** Solution Meeting 3/17/2022

**Previously presented:** Need Meeting 2/17/2022


**Project Driver:** Equipment Material Condition, Performance, and Risk

**Specific Assumption Reference:**

- Transmission infrastructure replacements (EOL/condition/obsolescence) that are consistent with efficient asset management decisions
- Programmatic review and/or replacement of breakers, relays, wood poles, cables, etc.

**Problem Statement:**

- Windy Edge 115kV circuit breaker #B32 installed in 1991 is in deteriorating condition due to oil leaks, hydraulic issues, replacement part availability and elevated maintenance costs



**Need Number:** BGE-2022-002

**Process Stage:** Solution Meeting – March 17, 2022

**Proposed Solution:**

Replace Windy Edge circuit breaker #B32

The estimated cost of the project is \$1.3M

Existing rating 2000 A, 50kA

New rating 3000 A, 63kA


**Alternatives Considered:**

None

**Projected In-Service:** 5/6/2022

**Project Status:** Engineering

**Model:** 2026 RTEP





**Need Number:** BGE-2022-003

**Process Stage:** Solution Meeting 3/17/2022

**Previously presented:** Need Meeting 2/17/2022


**Project Driver:** Equipment Material Condition, Performance, and Risk

**Specific Assumption Reference:**

- Transmission infrastructure replacements (EOL/condition/obsolescence) that are consistent with efficient asset management decisions
- Programmatic review and/or replacement of breakers, relays, wood poles, cables, etc.

**Problem Statement:**

- Windy Edge 115kV circuit breaker #B26 installed in 1967 is in deteriorating condition due to heater issues, low pressure issues, replacement part availability and elevated maintenance costs



**Need Number:** BGE-2022-003

**Process Stage:** Solution Meeting – March 17, 2022

**Proposed Solution:**

Replace Windy Edge circuit breaker #B26

The estimated cost of the project is \$1.3M

Existing rating 1600 A, 50kA

New rating 3000 A, 63kA


**Alternatives Considered:**

None

**Projected In-Service:** 6/3/2022

**Project Status:** Engineering

**Model:** 2026 RTEP



# Questions?



# Appendix

# High level M-3 Meeting Schedule

Assumptions	Activity	Timing
	Posting of TO Assumptions Meeting information	20 days before Assumptions Meeting
	Stakeholder comments	10 days after Assumptions Meeting
Needs	Activity	Timing
	TOs and Stakeholders Post Needs Meeting slides	10 days before Needs Meeting
	Stakeholder comments	10 days after Needs Meeting
Solutions	Activity	Timing
	TOs and Stakeholders Post Solutions Meeting slides	10 days before Solutions Meeting
	Stakeholder comments	10 days after Solutions Meeting
Submission of Supplemental Projects & Local Plan	Activity	Timing
	Do No Harm (DNH) analysis for selected solution	Prior to posting selected solution
	Post selected solution(s)	Following completion of DNH analysis
	Stakeholder comments	10 days prior to Local Plan Submission for integration into RTEP
	Local Plan submitted to PJM for integration into RTEP	Following review and consideration of comments received after posting of selected solutions

# Revision History

3/7/2022 - V1 – Original version posted to pjm.com