

Subregional RTEP Committee - Western FirstEnergy Supplemental Projects

July 17, 2020

Solutions

Stakeholders must submit any comments within 10 days of this meeting in order to provide time necessary to consider these comments prior to the next phase of the M-3 process

Need Number: APS-2020-002

Process State: Solution Meeting 07/17/2020

Previously Presented: Need Meeting 04/20/2020

Project Driver:

Equipment Material Condition, Performance and Risk Operational Flexibility and Efficiency

Specific Assumption Reference:


System Performance Projects Global Factors

- System reliability and performance
- Substation/line equipment limits

Upgrade Relay Schemes

- Relay schemes that have a history of misoperation
- Obsolete and difficult to repair communication equipment (DTT, Blocking, etc.)
- Communication technology upgrades
- Bus protection schemes

Continued on next slide...



Problem Statement:

- FirstEnergy has identified protection schemes using a certain vintage of relays and communication equipment that have a history of misoperation.
- Proper operation of the protection scheme requires all the separate components perform adequately during a fault.
- In many cases the protection equipment cannot be repaired due to a lack of replacement parts and available expertise in the outdated technology.
- Transmission line ratings are limited by terminal equipment.

Need Number	Transmission Line / Substation Locations	Existing Line Rating (SN / SE)	Existing Conductor Rating (SN / SE)	Limiting Terminal Equipment
APS-2020-002	Roxbury – Greene 138 kV Line	164 / 206	221 / 268	Disconnect Switch, Substation Conductor
	Greene – Letterkenny 138 kV Line	221 / 268	221 / 268	N/A
	Letterkenny – Grand Point 138 kV Line	196 / 228	221 / 268	Line Trap



APS Transmission Zone M-3 Process Misoperation Relay Project

Proposed Solution:

Need Number	Transmission Line / Substation Locations	New MVA Line Rating (SN / SE)	Scope of Work	Estimated Cost (\$ M)	Target ISD
APS-2020-002	Roxbury – Greene 138 kV Line	221 / 268	• Roxbury 138 kV Substation – Replace line relaying, disconnect switch, and substation conductor	\$0.5 M	4/29/2021
	Greene – Letterkenny 138 kV Line	221 / 268	-		
	Letterkenny – Grand Point 138 kV Line	221 / 268	• Grand Point 138 kV Substation – Replace line relaying and line trap		

Alternatives Considered: Maintain existing condition

Project Status: Conceptual

Model: 2020 RTEP model for 2025 Summer (50/50)

Need Number: APS-2020-004, APS-2020-005, APS-2020-006, APS-2020-008, PN-2020-015

Process Stage: Solution Meeting 07/17/2020

Previously Presented: Need Meeting 05/22/2020

Project Driver:

*Equipment Material Condition, Performance and Risk
Operational Flexibility and Efficiency*

Specific Assumption Reference:


System Performance Projects Global Factors

- System reliability and performance
- Substation/line equipment limits

Upgrade Relay Schemes

- Relay schemes that have a history of misoperation
- Obsolete and difficult to repair communication equipment (DTT, Blocking, etc.)
- Communication technology upgrades
- Bus protection schemes

Continued on next slide...



Problem Statement:

- FirstEnergy has identified protection schemes using a certain vintage of relays and communication equipment that have a history of misoperation.
- Proper operation of the protection scheme requires all the separate components perform adequately during a fault.
- In many cases the protection equipment cannot be repaired due to a lack of replacement parts and available expertise in the outdated technology.
- Transmission line ratings are limited by terminal equipment.

Need Number	Transmission Line / Substation Locations	Existing Line Rating (SN / SE)	Existing Conductor Rating (SN / SE)	Limiting Terminal Equipment
APS-2020-004	Cabot – Lawson Junction 138 kV Line	287 / 287	297 / 365	Line Relaying, Line Trap
	McCalmont – Lawson Junction 138 kV Line	267 / 287	297 / 365	Substation Conductor, Line Relaying, Line Trap
	Fawn – Lawson Junction 138 kV Line	294 / 342	308 / 376	Substation Conductor, Line Trap
APS-2020-005	Charleroi – Union Junction 138 kV Line	274 / 302	296 / 302	Substation Conductor, Line Trap
	Mitchell – Union Junction 138 kV Line	295 / 342	308 / 376	Substation Conductor, Line Trap
	Peters – Union Junction 138 kV Line	294 / 342	308 / 376	Substation Conductor, Line Trap
APS-2020-006	Gordon – Lagonda 138 kV Line	293 / 343	309 / 376	Substation Conductor, Line Relaying, Line Trap
	Lagonda – Windsor 138 kV Line	261 / 311	308 / 376 297 / 365	Substation Conductor, Line Relaying, Line Trap
PN-2020-015 APS-2020-008	Blairsville East – Social Hall 138 kV Line	225 / 287	243 / 294	Substation Conductor, CTs, Line Relaying, Line Trap



APS Transmission Zone M-3 Process Misoperation Relay Project

Proposed Solution:

Need Number	Transmission Line / Substation Locations	New MVA Line Rating (SN / SE)	Scope of Work	Estimated Cost (\$ M)	Target ISD
APS-2020-004	Cabot – Lawson Junction 138 kV Line	297/365	• Cabot 138 kV Substation – Replace line relaying, breaker, and line trap	\$2.5 M	5/19/2022
	McCalmont – Lawson Junction 138 kV Line	297/365	• McCalmont 138 kV Substation – Replace line relaying, breaker, substation conductors, and line trap		
	Fawn – Lawson Junction 138 kV Line	308/376	• Fawn 138 kV Substation – Replace line relaying, breaker, substation conductors, and line trap		
APS-2020-005	Charleroi – Union Junction 138 kV Line	296/302	• Charleroi 138 kV Substation – Replace line relaying, substation conductors, and line trap	\$1.6 M	5/28/2022
	Mitchell – Union Junction 138 kV Line	308/376	• Mitchell 138 kV Substation – Replace line relaying, substation conductors, and line trap		
	Peters – Union Junction 138 kV Line	308/376	• Peters 138 kV Substation – Replace line relaying, substation conductors, and line trap		
APS-2020-006	Gordon – Lagonda 138 kV Line	308/376	• Gordon 138 kV Substation – Replace line relaying, substation conductors, and line trap	\$1.4 M	6/1/2022
	Lagonda – Windsor 138 kV Line	297/365	• Windsor 138 kV Substation – Replace line relaying, breaker, substation conductors, and line trap		
PN-2020-015 APS-2020-008	Blairsville East – Social Hall 138 kV Line	243/294	• Social Hall 138 kV Substation – Replace line relaying, breaker, substation conductors, line trap, and current transformers	\$1.2 M	6/1/2021

Alternatives Considered: Maintain existing condition

Project Status: Conceptual

Model: 2020 RTEP model for 2025 Summer (50/50)

Need Number: APS-2020-010

Process Stage: Solutions Meeting 07/17/2020

Previously Presented: Needs Meeting 05/22/2020

Project Driver:

Customer Service


Specific Assumption Reference:

New customer connection request will be evaluated per FirstEnergy’s “Requirements for Transmission Connected Facilities” document and “Transmission Planning Criteria” document.

Problem Statement:

New Customer Connection – A customer requested 138 kV service, anticipated load is 10 MW, location is near the Rider – Weston 138 kV line.

Requested in-service date is December 2020.



Need Number: APS-2020-010

Process Stage: Solutions Meeting 07/17/2020

Proposed Solution:

- Tap the Rider-Weston 138 kV line approximately 3.5 miles from Rider substation and build a 138 kV line one span toward the proposed customer substation
- Install two (2) 138 kV in-line switches on either side of the new customer tap connection
- Install one (1) 138 kV in-line switch on the line extension towards the customer substation

Estimated Project Cost: \$0.9M


Alternatives Considered:

- N/A

Projected In-Service: 12/31/2020

Project Status: Conceptual

Model: 2019 Series 2024 Summer RTEP 50/50



Appendix

High Level M-3 Meeting Schedule

Assumptions	Activity	Timing
	Posting of TO Assumptions Meeting information	20 days before Assumptions Meeting
	Stakeholder comments	10 days after Assumptions Meeting
Needs	Activity	Timing
	TOs and Stakeholders Post Needs Meeting slides	10 days before Needs Meeting
	Stakeholder comments	10 days after Needs Meeting
Solutions	Activity	Timing
	TOs and Stakeholders Post Solutions Meeting slides	10 days before Solutions Meeting
	Stakeholder comments	10 days after Solutions Meeting
Submission of Supplemental Projects & Local Plan	Activity	Timing
	Do No Harm (DNH) analysis for selected solution	Prior to posting selected solution
	Post selected solution(s)	Following completion of DNH analysis
	Stakeholder comments	10 days prior to Local Plan Submission for integration into RTEP
	Local Plan submitted to PJM for integration into RTEP	Following review and consideration of comments received after posting of selected solutions

Revision History

7/7/2020 – V1 – Original version posted to pjm.com

7/23/2020 – V2 – Corrected existing conductor rating for APS-2020-006