Subregional RTEP Committee – Western FirstEnergy Supplemental Projects

November 19, 2021

Solutions

Stakeholders must submit any comments within 10 days of this meeting in order to provide time necessary to consider these comments prior to the next phase of the M-3 process



APS Transmission Zone M-3 Process Misoperation Relay Projects

Need Number: APS-2021-006, APS-2021-010 Process Stage: Solution Meeting 11/19/2021

Previously Presented:

Need Meeting 06/15/2021 (APS-2021-006) & Need meeting 08/16/2021 (APS-2021-010)

Project Driver:

Equipment Material Condition, Performance and Risk

Operational Flexibility and Efficiency

Specific Assumption Reference:


System Performance Projects Global Factors

- System reliability and performance
- Substation/line equipment limits

Upgrade Relay Schemes

- Relay schemes that have a history of misoperation
- Obsolete and difficult to repair communication equipment (DTT, Blocking, etc.)
- Communication technology upgrades
- Bus protection schemes

Continued on next slide...





APS Transmission Zone M-3 Process Misoperation Relay Projects

Problem Statement:

- FirstEnergy has identified protection schemes using a certain vintage of relays and communication equipment that have a history of misoperation.
- Proper operation of the protection scheme requires all the separate components perform adequately during a fault.
- In many cases the protection equipment cannot be repaired due to a lack of replacement part and available expertise in the outdated technology.
- Transmission line ratings are limited by terminal equipment.

Need Number	Transmission Line / Substation Locations	Existing Line Rating (SN / SE)	Existing Conductor Rating (SN / SE)	Limiting Terminal Equipment
APS-2021-006	Meadow Brook – Strasburg 138 kV Line	229 / 229	275 / 333	Relay Thermals, CT, and Wave Trap

Need Number	Transmission Line / Substation Locations	Existing Line Rating (SN / SE)	Existing Conductor Rating (SN / SE)	Limiting Terminal Equipment
	Buckhannon – Volga Tap 138 kV Line	164 / 206	221 / 268	Disconnect Switch, Substation Conductor, Wave Trap
	Volga Tap – Corder Crossing 138 kV Line	221 / 268	221 / 268	N/A
APS-2021-010	Corder Crossing – Leer South 138 kV Line	221 / 268	221 / 268	N/A
	Leer South – Pruntytown 138 kV Line	250 / 287 WN/WE	250 / 317 WN/WE	Meter



APS Transmission Zone M-3 Process Misoperation Relay Projects

Proposed Solution:

Need Number	Transmission Line / Substation Locations	New MVA Line Rating (SN / SE)	Scope of Work	Estimated Cost (\$ M)	Target ISD
APS-2021-006	Meadow Brook – Strasburg 138 kV Line	275 / 333	 Meadow Brook 138 kV Substation – Replace wave trap Strasburg 138 kV Substation – Replace line relaying, CT, and wave trap 	\$1.1M	03/31/2022

Need Number	Transmission Line / Substation Locations	New MVA Line Rating (SN / SE)	Scope of Work	Estimated Cost (\$ M)	Target ISD
APS-2021-010	Buckhannon – Volga Tap 138 kV Line	221 / 268	Pruntytown 138 kV Substation – Replace disconnect switch, substation conductor, and wave trap	\$1.6M	11/23/2022
	Leer South – Pruntytown 138 kV Line	221 / 268	Pruntytown 138 kV Substation – Meter		

Alternatives Considered: Maintain existing condition

Project Status: Conceptual

Model: 2020 RTEP model for 2025 Summer (50/50)

High Level M-3 Meeting Schedule

Assum	ptions
	J

Activity	Timing
Posting of TO Assumptions Meeting information	20 days before Assumptions Meeting
Stakeholder comments	10 days after Assumptions Meeting

Needs

Activity	Timing
TOs and Stakeholders Post Needs Meeting slides	10 days before Needs Meeting
Stakeholder comments	10 days after Needs Meeting

Solutions

Activity	Timing
TOs and Stakeholders Post Solutions Meeting slides	10 days before Solutions Meeting
Stakeholder comments	10 days after Solutions Meeting

Submission of Supplemental Projects & Local Plan

Activity	Timing
Do No Harm (DNH) analysis for selected solution	Prior to posting selected solution
Post selected solution(s)	Following completion of DNH analysis
Stakeholder comments	10 days prior to Local Plan Submission for integration into RTEP
Local Plan submitted to PJM for integration into RTEP	Following review and consideration of comments received after posting of selected solutions

Revision History

11/08/2021 – V1 – Original version posted to pjm.com

11/11/2021 – V2 – Updated map on slide 3

11/19/2021 - V3 - Remove 'APS-2021-005' text from need number on slide 3