



Market Efficiency Update


Transmission Expansion Advisory Committee
July 13, 2017



- Where we are in the process
- Interregional Projects Status
- RPM Projects Status
- Reevaluation Analysis Status
- Next Steps



Where we are - Market Efficiency Timeline



- Market Efficiency Base Case Mid-Cycle Update completed and posted
- Analysis of proposed solutions: July 2017 - Oct 2017 (in-progress)
 - Interregional and RPM Projects to be presented at August 2017 TEAC
 - PPL projects will be analyzed next
 - BGE projects will be analyzed after PPL
 - Any high-value low-risk* type projects maybe analyzed in parallel with the above
 - All other regional projects will be analyzed last
- Target determination of final projects: Dec 2017
 - Interregional, RPM, PPL and high-value low-risk projects to be recommended at Oct, 2017 Board meeting
 - BGE and other projects to be recommended at Dec, 2017 Board meeting

**High-value low-risk projects are generally classified as low cost upgrades, with significant B/C, and with minimum competition.*

Interregional Projects



AEP/COMED/NIPSCO Interregional Proposals

- **7 Projects:**


- 1-1A, 1-9A, 1-9B, 1-10B, 1-12D, 1-17B, 1-18S

- **Cost:**


- From \$1.00 M to \$197.97 M

- **ME Constraints:**

- BOSSERMAN - OLIVE 138 kV
- PAXTON - GIFFORD 138 kV




- **1 Project:**
 - 1-13H
- **Cost:**
 - \$71.88 M
- **ME Constraint:**
 - TANNERS CREEK - MIAMI FORT 345 kV
- **2020/2021 RPM BRA Results**
 - DEOK LDA binding with Tanners Creek - Miami Fort 345KV as limiting CETL constraint




- Mid cycle update removed the interregional congestion driver “Olive – Bosserman”
 - There may be joint RTO benefits that may reveal opportunity for an interregional project
 - Analysis in progress (preliminary results show most of projects don’t pass the B/C threshold when cost is fully allocated to PJM)
- Next steps:
 - PJM to share its results with MISO and vice versa
 - RTOs jointly select the most beneficial project (if any)
 - Inform stakeholders of RTO findings

RPM Projects


- **2 Projects:**
 - 1-11B, 1-11C
- **Cost:**
 - \$ 0 Cost
 - Will be included in base case
- **ME Constraints:**
 - EUGENE - DEQUIN 345 kV
 - DEQUIN - MEADOW 345 kV
- **2020/2021 RPM BRA Results**
 - COMED LDA binding with Eugene - Dequine 345 kV line as limiting CETL constraint
- **Note:**
 - These proposals are accelerations the previously approved baseline projects b2776 and b2777



- **3 Projects:**
 - 1-3A, 1-3B, 1-17A
- **Cost:**
 - From \$0.84 M to \$66.90 M
- **RPM Constraints:**
 - E. FRANKFORT - UNIVERSITY PARK 345 kV
 - PONTIAC - BROKAW 345 kV
- **2020/2021 RPM BRA Results**
 - COMED LDA binding with Eugene - Dequine 345 kV line as limiting CETL constraint



- **3 Projects:**
 - 1-18M, 1-18N, 1-18P
- **Cost:**
 - From \$19.70 M to \$117.30 M
- **RPM Constraints:**
 - Dayton LDA RPM
- **No need for analysis**
 - Dayton LDA did not bind



- PJM determined CETL impact of proposed projects (completed)
- PJM to run RPM Base Residual Auction model for multiple study years using updated CETL values (in-progress)
- PJM to determine RPM benefits (in-progress)



RPM Evaluation Process – CETL Analysis Results

Project ID	LDA Examined	Proposed Solution	Proposer	Cost Est (\$M)	CETL Change	Comment
11B	ComEd	Accelerate the previously approved baseline project to reconductor the Dequaine-Eugene 345 kV and substation work at Dequaine.	AEP	\$0.00	1,253	11B & 11C studied together
11C	ComEd	Accelerate the previously approved baseline project to reconductor the Dequaine-Eugene 345 kV and substation work at Dequaine.	AEP	\$0.00	1,253	
3A	ComEd	Upgrade capacity on E. Frankfort - University Park 345 kV line.	ComEd	\$0.84	772	Next limit is voltage collapse
3B	ComEd	Upgrade substation equipment at Pontiac Midpoint station to increase capacity on Pontiac-Brokaw 345 kV line.	ComEd	\$5.62	339	
17A	ComEd	Build a new 345 kV switchyard (Cottage Grove). Loop in the University Park North EC - Olive 345 kV line, Crete - St. John 345 kV line, Davis Creek - Bloom 345 kV line and Davis Creek - Burnham 345 kV line. Substation upgrades at Bloom and Burnham substations. Upgrade the University Park North-Olive 345 kV line.	AEP Exelon	\$66.90	-154	Study included 3A, 3B, 11B and 11C
17B	ComEd	Build a new 345 kV switchyard (Pike Creek). Build a new Meadow Lake - Pike Creek 345 kV double circuit line. Loop the Bloom - Davis Creek 345 kV line and Burnham - Davis Creek 345 kV line into Pike Creek switchyard.	AEP Exelon	\$197.97	-435	Study included 3A, 3B, 11B and 11C
13H	DEOK	Tap the Tanners Creek - Losantville 345 kV line and build a new 345 kV switchyard (York). Tap the Miami Fort - Woodsdale 345 kV line and build a new 345/138 kV substation (Coyote) next to Wiley 138kV switchyard. Build a new 345 kV line between York and Coyote stations. Expand Wiley 138 kV switchyard by tying the Coyote 345/138 kV transformer into the Wiley 138 kV yard. Loop the Morgan-Fairfield 138 kV line into Wiley 138 kV station. Install a new 345/138 kV transformer at Foster substation.	Transource	\$71.89	-638	

Note: Dayton LDA did not bind in the 2020/2021 BRA Auction, therefore no CETL analysis was performed for Dayton LDA..

Reevaluation of Approved Market Efficiency Projects (2014/15 RTEP Window)

- Applies to market efficiency projects approved during the 2014/15 RTEP Window
- Using the Market Efficiency Base Case Mid-Cycle Update
- Analysis performed individually, one project at a time
- Reevaluation Study Process
 - Create a new base case by removing/reversing the topology related to the approved market efficiency project
 - Measure the impact of adding back the approved market efficiency project
 - Measure benefits for 15-year period starting with the in-service date
 - For RPM projects also measure the capacity benefits
 - Calculate the new B/C ratios
- Projects must meet the B/C criterion of 1.25

- PJM staff is creating reevaluation cases for all projects approved in 2014/15 cycle (80% completed)
- PJM will determine the new B/C ratios for projects
- PJM planning will be reaching out to project owners if the project does not meet reevaluation threshold

Milestone	Schedule 2016 - 2017
Reevaluation Approved Market Efficiency Projects	July - August 2017
Proposed projects analysis - Interregional, PPL and slam dunks	July – October 2017
Proposed projects analysis - BGE and other	August – December 2017
Acceleration Analysis	July – November 2017
Final TEAC Review and Board Recommendation	December 2017

Appendix A - Interregional Projects Descriptions

Project ID: 201617_1-1A

Proposed by: WPPI

Proposed Solution: Interregional
 Provide a second New Carlisle-Olive 138 kV circuit. Upgrade substation equipment at New Carlisle and Olive substations.

kV Level: 138 kV


In-Service Cost (\$M): \$2.5

In-Service Date: 2019

Target Zone: AEP

ME Constraints:
 OLIVE - BOSSERMAN 138 kV

Notes: See supplemental project Olive – Bosserman discussion in the Reliability Update presentation at April TEAC.



Project ID: NIPSCO 1-9A

Proposed by: NIPSCO

Proposed Solution: Interregional Reconductor existing NIPSCO line section between AEP Bosserman and Olive 138 kV substations. Reconductor existing NIPSCO line section between AEP Bosserman and New Carlisle 138 kV substations.

kV Level: 138 kV

In-Service Cost (\$M): \$8.00


In-Service Date: 2019

Target Zone: AEP NIPSCO

ME Constraints:

OLIVE - BOSSERMAN 138 kV

Notes: See supplemental project Olive – Bosserman discussion in the Reliability Update presentation at April TEAC.



Project ID: 201617_1-9B

Proposed by: NIPSCO

Proposed Solution: Greenfield, Interregional
 New NIPSCO line section between Thayer and Morrison 138 kV substations.

kV Level: 138 kV


In-Service Cost (\$M): \$42.50

In-Service Date: 2022

Target Zone: AML ComEd NIPSCO

ME Constraints:
 PAXTON - GIFFORD 138 kV

Notes:



Project ID: 201617_1-10B

Proposed by: Nextera

Proposed Solution: Greenfield, Interregional
 Cut the University Park - Olive 345 kV and tie into a new 345/138 kV substation (Rolling Prairie). Cut the Maple - New Carlisle 138 kV and Maple - LNG 138 kV lines and tie into the new substation.

kV Level: 138 kV


In-Service Cost (\$M): \$19.2

In-Service Date: 2021

Target Zone: AEP

ME Constraints:
 BOSSERMAN - OLIVE 138 kV

Notes: Notes: See supplemental project Olive – Bosserman discussion in the Reliability Update presentation at April TEAC.



Project ID: 201617_1-13H

Proposed by: Transource

Proposed Solution: Greenfield, Interregional
 Tap the Tanners Creek - Losantville 345 kV line and build a new 345 kV switchyard (York). Tap the Miami Fort - Woodsdale 345 kV line and build a new 345/138 kV substation (Coyote) next to Wiley 138kV switchyard. Build a new 345 kV line between York and Coyote stations. Expand Wiley 138 kV switchyard by tying the Coyote 345/138 kV transformer into the Wiley 138 kV yard. Loop the Morgan-Fairfield 138 kV line into Wiley 138 kV station. Install a new 345/138 kV transformer at Foster substation.

kV Level: 138/345 kV

In-Service Cost (\$M): \$71.89


In-Service Date: 2021

Target Zone: DEOK

ME Constraints:

TANNERS CREEK - MIAMI FORT 345 kV

Notes:



Project ID: 201617_1-17B

Proposed by: AEP Exelon

Proposed Solution: Greenfield, Interregional
 Build a new 345 kV switchyard (Pike Creek). Build a new Meadow Lake - Pike Creek 345 kV double circuit line. Loop the Bloom - Davis Creek 345 kV line and Burnham - Davis Creek 345 kV line into Pike Creek switchyard.

kV Level: 345 kV

In-Service Cost (\$M): \$197.97


In-Service Date: 2021

Target Zone: ComEd

ME Constraints:

OLIVE - BOSSERMAN 138 kV + RPM Benefits

Notes: See supplemental project Olive – Bosserman discussion in the Reliability Update presentation at April TEAC.



Project ID: 201617_1-18S

Proposed by: Northeast Transmission Development

Proposed Solution: Greenfield, Interregional
 Tap the Green Acres - Olive 345 kV line and build a new 345/138 kV substation (Coffee Creek). Loop the Flint Lake to Luchtman Road 138 kV line into Coffee Creek.

kV Level: 138/345 kV

In-Service Cost (\$M): \$17.4


In-Service Date: 2021

Target Zone: AEP

ME Constraints:

OLIVE - BOSSERMAN 138 kV

Notes: See supplemental project Olive – Bosserman discussion in the Reliability Update presentation at April TEAC.



Appendix B - RPM Projects Descriptions

Project ID: 201617_1-11B

Proposed by: AEP

Proposed Solution:
Accelerate the previously approved baseline project to reconductor the Dequine-Eugene 345 kV and substation work at Dequine.

kV Level: 345 kV


In-Service Cost (\$M): 0

In-Service Date: 2019

Target Zone: AEP

ME Constraints:
EUGENE - DEQUIN 345 kV + RPM Benefits

Notes: See approved baseline upgrade b2777



Project ID: 201617_1-11C

Proposed by: AEP

Proposed Solution:
Accelerate the previously approved baseline project to reconductor the Dequine - Meadow Lake 345 kV #2 line and substation work at Dequine.

kV Level: 345 kV


In-Service Cost (\$M): 0

In-Service Date: 2019

Target Zone: AEP

ME Constraints:
DEQUIN - MEADOW 345 kV + RPM Benefits

Notes: See approved baseline upgrade b2776



Project ID: 201617_1-3A

Proposed by: ComEd

Proposed Solution:
Upgrade capacity on E. Frankfort - University Park 345 kV line.

kV Level: 345 kV


In-Service Cost (\$M): \$0.84

In-Service Date: 2021

Target Zone: ComEd

ME Constraints:
E. FRANKFORT - UNIVERSITY PARK 345 kV + RPM Benefits

Notes:



Project ID: 201617_1-3B

Proposed by: ComEd

Proposed Solution:
Upgrade substation equipment at Pontiac Midpoint station to increase capacity on Pontiac-Brokaw 345 kV line.

kV Level: 345 kV


In-Service Cost (\$M): \$5.62

In-Service Date: 2021

Target Zone: ComEd

ME Constraints:
PONTIAC - BROKAW 345 kV + RPM Benefits

Notes:



Project ID: 201617_1-17A

Proposed by: AEP Exelon

Proposed Solution: Greenfield

Build a new 345 kV switchyard (Cottage Grove). Loop in the University Park North EC - Olive 345 kV line, Crete - St. John 345 kV line, Davis Creek - Bloom 345 kV line and Davis Creek - Burnham 345 kV line. Substation upgrades at Bloom and Burnham substations. Upgrade the University Park North-Olive 345 kV line.

kV Level: 345 kV

In-Service Cost (\$M): \$66.90


In-Service Date: 2021

Target Zone: ComEd

ME Constraints:

E. FRANKFORT - UNIVERSITY PARK 345 kV + RPM Benefits

Notes:



Project ID: 201617_1-18M

Proposed by: Northeast Transmission Development

Proposed Solution: Greenfield

Build a new 345/138 kV substation (Bull Branch) near Urbana
 138/69 kV substation. Build a new Marysville - Bull Branch
 345 kV line and a new Miami - Bull Branch 345 kV line.

Connect the Bull Branch 138kV to Urbana 138/69 kV
 substation. Tap the West Milton - Miami Fort 345 kV line and
 build a new 345/138 kV substation (Spring Run). Build a new
 Spring Run - Crown 138 kV line.

kV Level: 138/345 kV

In-Service Cost (\$M): \$117.30


In-Service Date: 2021

Target Zone: AEP

ME Constraints:

Dayton LDA RPM Benefits

Notes:



Project ID: 201617_1-18N

Proposed by: Northeast Transmission Development

Proposed Solution: Greenfield

Build a new 345/138 kV substation (Bull Branch) near Urbana
 138/69 kV substation. Build a new Marysville - Bull Branch
 345 kV line and a new Miami - Bull Branch 345 kV line.
 Connect the Bull Branch 138 kV to Urbana 138/69 kV
 substation.

kV Level: 138/345 kV


In-Service Cost (\$M): \$97.70

In-Service Date: 2021

Target Zone: AEP

ME Constraints:
 Dayton LDA RPM Benefits

Notes:



Project ID: 201617_1-18P

Proposed by: Northeast Transmission Development

Proposed Solution: Greenfield

Tap the West Milton - Miami Fort 345 kV line and build a new 345/138 kV substation (Spring Run). Build a new Spring Run - Crown 138 kV line.

kV Level: 138/345 kV


In-Service Cost (\$M): \$19.70

In-Service Date: 2021

Target Zone: Dayton

ME Constraints:
Dayton LDA RPM Benefits

Notes:



Appendix C - AEP Supplemental Project Olive – Bosserman 138 kV

- AEP has planned a supplemental project that impacts the Olive – Bosserman market efficiency constraint
- Supplemental projects are:
 - Not needed for reliability criteria, market efficiency, or operational performance
 - Funded wholly by Transmission Owner
 - No PJM approval needed
- This supplemental project is included in the Market Efficiency base case and all submitted projects to address Olive-Bosserman constraint will be evaluated under this assumption

Supplemental Project: Olive-Bosserman 138 kV
Previously Presented at 4/13/2017 TEAC and 4/21/2017 Western SRTEAC

Problem Statement/Driver:

The LaPorte Junction - New Carlisle 34.5 kV circuit has a vintage from 1930s and is wood pole construction. Between 2010-2015, ~2 million customer minutes of interruption (CMI) were recorded at Silver Lakes station. There are 183 open conditions, 95 of which are category A conditions on the ~20 mile long line.

Indiana and Michigan Power Company has requested to convert Silver Lake and Springville to 138 kV operation.

This project would also resolve congestion on the Olive-Bosserman 138 kV identified during MISO-PJM JOA market efficiency studies in addition to addressing the a potential overload identified on this facility during the PJM 2021 RTEP. It was submitted (without the new distribution station additions) to the PJM reliability and market efficiency windows.

Recommended Solution:

Construct two 138/12 kV distribution stations, Bootjack and Marquette, to replace Silver Lake 34.5 kV and Springville 69 kV stations. (S1279.1)

Cut the existing Olive – Bosserman line into New Carlisle station. (S1279.2)

Rebuild sections of the LaPorte Junction-New Carlisle/New Buffalo 34.5 kV line to 138 kV to establish Bootjack-Olive 138 kV circuit. (S1279.3)

Install a three way phase over phase switch, called Kuchar, near Liquid Carbonics station and construct a new 138 kV line between Bootjack and Kuchar. (S1279.4)

Construct a 138 kV extension to Marquette station by tapping the Bosserman-Liquid Carbonics 138 kV line. (S1279.5)


Alternatives:

Rebuild ~20 mile long New Carlisle – LaPorte Junction 34.5 kV utilizing existing line ROW corridor. This alternative was not selected because it did not provide the operational flexibility & efficiency and customer service benefits provided by the preferred option. Estimated cost: ~\$32M

Cost Estimate: \$36.786M

Projected IS date: 12/1/2019

Status: Conceptual



- Revision History
 - V1 – 7/10/2017 – Original Version Posted to PJM.com