

# Transmission Expansion Advisory Committee – PPL Supplemental Projects

April 02, 2024

# Solutions

Stakeholders must submit any comments within 10 days of this meeting in order to provide time necessary to consider these comments prior to the next phase of the M-3 process



**Need Number:** PPL-2024-0001

**Meeting Date:** 04/02/2024

**Process Stage:** Solution

**Need Presented:** 02/06/2024

**Supplemental Project Driver:** Customer Service


**Problem Statement:**

- A customer has submitted a request to have their facility served from a 138kV source in New Kingston, PA. The total facility load is approximately 1,275 MW (2032). The requested in service date is 03/2026.

Initial In-Service Load	Projected 2028 Load	Projected 2030 Load
Summer 2026: 40MW Winter 2026-27: 108 MW	Summer: 405 MW Winter: 540 MW	Summer: 1,000 MW Winter: 1,040 MW

**Specific Assumption References:**

[PPL 2024 Annual Assumptions](#)





## Need Number: PPL-2024-0001

### Proposed Solution:

- Break the existing Juniata (JUNI)-Three Mile Island (TMIS) 500kV line and extend the lines 0.1 miles into a new four bay Bernheisel (BERN) 500kV breaker-and-a-half yard.
- Rebuild the existing JUNI-TMIS 500kV line to double circuit for 13.3 miles from Juniata substation to Bernheisel substation.
  - PPL's standard is to have three sources into a BES substation.
- Install four 500-138kV transformers.
- Install a six bay 138kV yard.
- Install two 138kV capacitor banks.
- Extend six 138kV lines to customer facility

### Alternatives Considered:


1. 230kV Option: Install a four bay 230kV BAAH yard (BERN) with four 230-138kV XFMRs, 230kV cap bank, six bay 138kV BAAH yard, and two 138kV capacitors. Rebuild the JUNI-BERN, BERN-CUMB, and CUMB-WIGR 230kV lines to double circuit. Install new terminals at JUNI, CUMB, and WIGR 230kV yards. Rebuild WIGR-WSHO/WIGR-BRIS and JUNI-DAUP/LEWI-JUNI 230kV double circuit lines. Rebuild the single circuit HUMM-STEE 230kV line. Replace both Juniata 500-230kV XFMRs with larger units. Estimated cost: \$293M.
2. 500kV & 230kV Option: Install five bay 230kV BAAH yard (BERN) with four 230-138kV XFMRs, 230kV cap bank, six bay 138kV BAAH yard, and two 138kV capacitors. Install a three bay 500kV BAAH yard with two 500-230kV XFMRs. Rebuild the JUNI-BERN 230kV line to double circuit and install new terminal at JUNI 230kV yard. Re-terminate the JUNI-KEYS and JUNI-SUNB lines at JUNI and install a third 500-230kV transformer at JUNI. Estimated cost: \$260M.

**Estimated Project Cost: \$244M**

**Projected In-Service: 6/30/2026**

**Project Status: Conceptual**

**Model: 2028**



# Appendix

# High level M-3 Meeting Schedule

Assumptions	Activity	Timing
	Posting of TO Assumptions Meeting information	20 days before Assumptions Meeting
	Stakeholder comments	10 days after Assumptions Meeting
Needs	Activity	Timing
	TOs and Stakeholders Post Needs Meeting slides	10 days before Needs Meeting
	Stakeholder comments	10 days after Needs Meeting
Solutions	Activity	Timing
	TOs and Stakeholders Post Solutions Meeting slides	10 days before Solutions Meeting
	Stakeholder comments	10 days after Solutions Meeting
Submission of Supplemental Projects & Local Plan	Activity	Timing
	Do No Harm (DNH) analysis for selected solution	Prior to posting selected solution
	Post selected solution(s)	Following completion of DNH analysis
	Stakeholder comments	10 days prior to Local Plan Submission for integration into RTEP
	Local Plan submitted to PJM for integration into RTEP	Following review and consideration of comments received after posting of selected solutions

# Revision History

3/21/2024 - V1 – Original version posted to pjm.com