

Submission of Supplemental Projects for Inclusion in the Local Plan

Note

- Supplemental projects with a Local Plan submission date of 02/21/2024 will be modeled in the 2024 Series RTEP.

Initially posted to 2021 Local Plan for s2340.1 & s2340.2

Updates to s2340.1 & s2340.2 for 2024 Local Plan highlighted in red below

Dominion Transmission Zone M-3 Process Do No Harm (DNH) Analysis

Need Number: DOM-2020-0026-DNH (Rollins Ford)

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Previously Presented:

Solution – 06/08/2021; 02/07/2023

Project Driver:

Do No Harm Analysis

Problem Statement:

PJM has identified a N-1 Generator Deliverability contingency that results in an overload of both segments of Line 2114 (Remington CT to Elk Run; Elk Run to Rollins Ford) during the 2021 Do-No-Harm analysis.


For example, the loss of Line 569 (Loudoun – Morrisville) under contingency DVP-P1-2: LN 569 creates overloads of:

- Line 2114 (Remington CT to Elk Run) – Current rating 1047 MVA
- Line 2114 (Elk Run to Rollins Ford) – Current rating 1047 MVA

The violations are caused by previously presented Supplemental Project DOM-2020-0026 in the Dominion Zone.

Updated Criteria Evaluation:

PJM had also identified overlapping thermal violations in the 2026 Summer RTEP model from Remington CT to Gainesville. The reconductor portion of the previously proposed supplemental solution was submitted and approved as a part of the PJM 2021 Reliability Open Window #1 (b3689.1).



Initially posted to 2021 Local Plan for s2340.1 & s2340.2

Updates to s2340.1 & s2340.2 for 2024 Local Plan highlighted in red below

Dominion Transmission Zone M-3 Process
Do No Harm (DNH) Analysis

Previous Solution (Approved as baseline b3689.1):

Solution Approved as Baseline b3689.1:

Re-conductor the segments of 230kV Line 2114 from Remington CT to Elk Run (approx. 3.46 miles) and Elk Run to Rollins Ford (approx. 19.71 miles) using a higher capacity conductor to achieve an expected rating of 1573 MVA.

Re-conductor approx. 1.11 miles of 230kV Line 2222 from Rollins Ford to Gainesville using a higher capacity conductor to achieve an expected rating of 1573 MVA.

Proposed Solution:

At Remington CT, upgrade (2) 230 kV circuit breakers and terminal equipment (switches, leads, etc.) to 4000 A 230 kV standards.

At Gainesville, upgrade (2) 230 kV circuit breakers and terminal equipment (switches, leads, etc.) to 4000 A 230 kV standards.

Estimated Cost:


At Remington CT (s2340.1) - **\$1.5M** (Previously \$35.0M for Line #2114)

At Gainesville (s2340.2) - **\$8.0M** (Previously \$2.0M for Line #2222)

Projected In-service Date: 12/31/2026 (Previously 12/31/2025)

Project Status: Conceptual

Model: 2025 RTEP



Initially posted to 2021 Local Plan for s2499
Updates to s2499 for 2024 Local Plan highlighted in red below

Need Number: DOM-2020-0036

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Previously Presented:

Need – 10/06/2020

Solution – 11/04/2020; **07/12/2022**

Project Driver:

Equipment Material Condition, Performance, and Risk

Specific Assumption Reference:


See details on Dominion Energy’s End of Life Criteria in Dominion’s Planning Assumptions presented in December 2019 and updated in June 2020.

Problem Statement:

Dominion Energy has identified a need to replace 60 concrete structures of Line #2007 (Lynnhaven – Thalia) based on the Company’s End of Life criteria.

- The 3.37 miles long line was constructed on concrete structures in 1970. These structures have developed significant structural concerns as they age.
- Every pole is experiencing hairline cracking at a minimum, and many of the poles have more advanced cracking that has exposed some of the interior reinforcing bars and cables.
- The cracks allow for significant water infiltration which can accelerate the deterioration of the concrete and cause rusting of the steel reinforcing components.
- The Line #2007 provides service to Thalia substation with approximately 134 MW of tapped load.
- **Dominion Energy acquired rights to use the existing right-of-way corridor containing Line #2007 which are nearing expiration.**

Dominion Transmission Zone M-3 Process
 230 kV Line #2007 – EOL Rebuild



Initially posted to 2021 Local Plan for s2499
Updates to s2499 for 2024 Local Plan highlighted in red below

Dominion Transmission Zone M-3 Process
230 kV Line #2007 – EOL Rebuild

Need Number: DOM-2020-0036

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Selected Solution:

Rebuild the 3.37 miles long Line #2007 between Lynnhaven and Thalia to current 230kV standards. The normal summer rating of the line conductor will be ~~1047~~ **1573** MVA. **Dominion Energy to pursue with the City of Virginia Beach extending the rights for use of the existing Line #2007 corridor.**


Estimated Cost: ~~\$7.0~~ **\$28.7** M

Projected In-Service: 12/31/2025

Supplemental Project ID: s2499

Project Status: Conceptual

Model: 2025 RTEP



Initially posted to 2021 Local Plan for s2500
Updates to s2500 for 2024 Local Plan highlighted in red below

Need Number: DOM-2020-0037

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Previously Presented:

Need – 10/06/2020

Solution – 11/04/2020; **07/12/2022**

Project Driver:

Equipment Material Condition, Performance, and Risk

Specific Assumption Reference:


See details on Dominion Energy’s End of Life Criteria in Dominion’s Planning Assumptions presented in December 2019 and updated in June 2020.

Problem Statement:

Dominion Energy has identified a need to replace 20 concrete structures (Structure 2019/21 – Thalia segment) of Line #2019 (Greenwich – Thalia) based on the Company’s End of Life criteria.

- The 1.17 miles segment of Line #2019 was constructed on concrete structures in 1970. These structures have developed significant structural concerns as they age.
- Every pole is experiencing hairline cracking at a minimum, and many of the poles have more advanced cracking that has exposed some of the interior reinforcing bars and cables.
- The cracks allow for significant water infiltration which can accelerate the deterioration of the concrete and cause rusting of the steel reinforcing components.
- The Line #2019 provides service to Thalia substation with approximately 134 MW of tapped load.
- **Dominion Energy acquired rights to use the existing right-of-way corridor containing Line #2019 which are nearing expiration.**

Dominion Transmission Zone M-3 Process
 230 kV Partial Line #2019 – EOL Rebuild



Initially posted to 2021 Local Plan for s2500
Updates to s2500 for 2024 Local Plan highlighted in red below

Dominion Transmission Zone M-3 Process
230 kV Partial Line #2019 – EOL Rebuild

Need Number: DOM-2020-0037

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Selected Solution:

Rebuild approximately 1.17 miles of Line #2019 between Thalia and Structure 2019/21 to current 230kV standards. The normal summer rating of the line segment will be ~~1047~~ **1573** MVA. **Dominion Energy to pursue with the City of Virginia Beach extending the rights for use of the existing Line #2019 corridor.**


Estimated Cost: ~~\$3.0~~ **\$14.3** M

Projected In-Service: ~~12/15/2025~~ **12/31/2025**

Supplemental Project ID: s2500

Project Status: Conceptual

Model: 2025 RTEP



Initially posted to 2021 Local Plan for s2609.2
Updates to s2609.2 for 2024 Local Plan highlighted in red below

Dominion Transmission Zone: Supplemental Do No Harm Analysis

Need Number: DOM-2021-0016-DNH

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Pleasant View 500-230kV Transformer (s2609.2)

- Install (1) 4440 **840** MVA 500-230 kV transformer at Goose Creek Substation.
 - Extend the existing 500kV ring bus at Goose Creek Substation to be set up for a future six-breaker ring arrangement. One breaker to be installed initially creating a five-breaker ring bus.
 - Install a new 230kV ring bus at Goose Creek Substation to be set up for a future four-breaker ring arrangement. Three 230kV breakers to be installed initially.
- Cut and extend line #227 (Belmont to Beaumeade) into Goose Creek Substation.

Estimated Project Cost: \$40.0 M

Transmission Line Cost: \$5.0 M

Substation Cost: \$35 M

Alternatives Considered:

No feasible alternatives


Projected In-service Date: ~~12/15/2026~~ **12/15/2023**

Project Status: In-Service

Model: 2025 RTEP

Reason for change:

- **Inability to procure 1440 MVA transformer to address real-time operational constraints.**
- **Provide operational flexibility for securely operating the system under various outage scenarios.**



Initially posted to 2021 Local Plan for s2620
Updates to s2620 for 2024 Local Plan highlighted in red below

Need Number: DOM-2021-0018

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Previously Presented:

Need – 04/06/2020

Solution – 05/11/2021

Project Cancelled at 09/06/2022 TEAC Meeting

Project Driver:

Customer Service

Specific Assumption Reference:

Customer load request will be evaluated per Dominion’s Facility Interconnection Requirements Document and Dominion’s Transmission Planning Criteria.

Problem Statement:

DEV Distribution has submitted a DP Request to add a 2nd distribution transformer at Nokesville Substation in Prince William County. The new transformer is being driven by continued load growth in the area.

Projected 2026 load

Summer: 63.3 MW

Winter: 58.8 MW

Dominion Transmission Zone M-3 Process
 Nokesville - Add 2nd TX - DEV



Initially posted to 2021 Local Plan for s2620
Updates to s2620 for 2024 Local Plan highlighted in red below

Dominion Transmission Zone M-3 Process
Nokesville - Add 2nd TX - DEV

Need Number: DOM-2021-0018

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Project Cancelled at 09/06/2022 TEAC Meeting

Selected Solution:

Install a 1200 Amp, 50kAIC circuit switcher and associated equipment (bus, relaying, etc.) to feed the new transformer at Nokesville.


Estimated Cost: \$0.75 M

Projected In-Service: 11/01/2022

Supplemental Project ID: s2620

Project Status: Engineering

Model: 2025 RTEP



Initially posted to 2023 Local Plan
Updates for 2024 Local Plan highlighted in red on next slide

Dominion Transmission Zone: Supplemental Equipment Material Condition, Performance and Risk

Need Number: DOM-2021-0047

Process Stage: Solution Meeting 08/08/2023

Previously Presented: Solution Meeting 08/09/2022, Need Meeting 06/08/2021

Project Driver: Equipment Material Condition, Performance and Risk


Specific Assumption References:

See details on Equipment Material Condition, Performance and Risk in Dominion’s Planning Assumptions presented in December 2020.

Problem Statement:

Dominion Energy has identified a need to replace approximately 0.73 miles of 230kV Line #2167 (Hathaway to Edgecombe NUG), and 16.9 miles of 230kV Line #229 (Tarboro to Edgecombe NUG) which includes 2.1-mile segments of double circuit with Line #55 (Tarboro to Anaconda) and 0.95 miles single circuit segments of Line #55 based on the Company’s End of Life criteria.

- Double-circuit is on steel towers and single-circuit is on 2-pole wood H-frame structures all dating back to 1967. Conductor is ACSR.
- A field-condition assessment indicated woodpecker damage and broken insulators.
- Industry guidelines indicate equipment life for steel structures is 40-60 years, wood structures 35-55 years, conductor and connectors are 40-60 years, and porcelain insulators are 50 years.



Initially posted to 2023 Local Plan for s2825.1
Updates to s2825.1 for 2024 Local Plan highlighted in red below

Dominion Transmission Zone: Supplemental Line #229 and Line #55 Partial Rebuild

Need Number: DOM-2021-0047

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Proposed Solution:

Rebuild ~~entire~~ Line #2167 Edgecombe NUG Tap – Hathaway (approximately ~~0.73~~ **0.4** miles) to current 230kV standards with appropriate structures. The minimum normal summer conductor rating of this line will be 1573 MVA. Rebuild ~~entire~~ Line #229 Edgecombe NUG Tap – Tarboro (approximately ~~46.9~~ **16.6** miles) to current 230kV standards with appropriate structures. The minimum normal summer conductor rating of the line will be 1573 MVA. **Line #2167 rebuilt section will be connected to Line #229 at the Edgecombe NUG Tap and will be renumbered to Line #229. Line #229 becomes Tarboro to Hathaway and the double-circuit line from Edgecombe NUG Tap to Edgecombe NUG will be disconnected and made idle. (s2825.1)**

Rebuild approximately 3 miles from Tarboro to Str 55/133 of Line #55 Tarboro – Harts Mill to current 115kV standards with appropriate structures. The minimum normal summer conductor rating of the line will be 393 MVA.

Terminal equipment will be upgraded as necessary. **(s2825.2)**

Estimated Project Cost: \$ ~~40~~ **43**M


Alternatives Considered:

No feasible alternatives

Project Target In-service Date: 12/31/2023

Project Status: ~~Conceptual~~ **Construction**

Model: 2025 RTEP



Initially posted to 2021 Local Plan for s2613
Updates to s2613 for 2024 Local Plan highlighted in red below

Dominion Transmission Zone M-3 Process
 230 kV Line #272 – EOL Rebuild

Need Number: DOM-2021-0014

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 11/12/2021

Previously Presented:

Need – 03/09/2021

Solution – 04/06/2021, **04/30/2024**

Project Driver:

Equipment Material Condition, Performance, and Risk


Specific Assumption Reference:

See details on Equipment Material Condition, Performance and Risk in Dominion’s Planning Assumptions presented in December 2020.

Problem Statement:

Dominion Energy has identified a need to replace 79 existing transmission towers that carry 230 kV Line #272 (Dooms - Grottoes). The need for replacement is based on the Company’s End of Life criteria.

- The 11.5 mile long line consists of CORTEN X-Series lattice-type towers that were constructed in 1967.
- These towers have inherent corrosion problems causing continuous deterioration to the steel members and have reached the end of their useful life. They are amongst the weakest and most problematic CORTEN lattice towers on our system and are a high priority for replacement.



Initially posted to 2021 Local Plan for s2613
Updates to s2613 for 2024 Local Plan highlighted in red below

Dominion Transmission Zone M-3 Process
230 kV Line #272 – EOL Rebuild

Need Number: DOM-2021-0014

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 11/12/2021

Selected Solution:

Approximately 11.5 miles containing weathering CORTEN lattice-type towers will be replaced with steel monopoles and new conductor with a normal summer rating of **1573 MVA** to meet current 230 kV standards.


Estimated Cost: **\$34.0 M**

Projected In-Service: **12/31/2027**

Supplemental Project ID: s2613

Project Status: Conceptual

Model: 2025 RTEP



**Initially posted to 2021 Local Plan for s2609.2 and s2609.9
Updates to s2609.2 and s2609.9 for 2024 Local Plan
highlighted in red below**

Need Number: DOM-2021-0016-DNH

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 12/10/2021

Presentation Date:

DNH – 11/30/2021, 6/6/2023, 2/6/2024

Supplemental Project Driver:

Do No Harm Analysis

Specific Assumption Reference:

Customer load request will be evaluated per Dominion’s Facility Interconnection Requirements Document and Dominion’s Transmission Planning Criteria.


Problem Statement:

PJM has identified violations on three separate facilities.

- 1) Pleasant View 500-230kV TX – **(Generator Deliverability Analysis)**
 - Contingency scenario: DVP_P1-3: 8BRAMBLETON-TX#1
- 2) Line #202 (Clark to Idylwood) – **(N-1 Contingency Analysis)**
 - Contingency scenario: DVP_P7-1: LN 227-274
- 3) Ox 500-230kV Transformers (1 & 2) – **(N-1-1 Contingency Analysis)**
 - Contingency scenarios: DVP_P1-2: LN 561 and DVP_P1-3: 8OX-TX#1
DVP_P1-2: LN 561 and DVP_P1-3: 8OX TX#2
- 4) Line #205 (Locks – Harrowgate – Tyler) – **(Generator Deliverability Analysis)**
 - Contingency scenario: DVP_P4-2: 562T563

These violations were caused by Supplemental Project DOM-2021-0016 in the Dominion Zone.

Dominion Transmission Zone M-3 Process Do No Harm (DNH) Analysis



**Initially posted to 2021 Local Plan for s2609.2 and s2609.9
Updates to s2609.2 and s2609.9 for 2024 Local Plan
highlighted in red below**

Dominion Transmission Zone M-3 Process Do No Harm (DNH) Analysis

Need Number: DOM-2021-0016-DNH

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 12/10/2021

Selected Solution (Part 1 of 4):

Pleasant View 500-230kV Transformer (s2609.2)

- Install (1) **840 MVA** 500-230 kV transformer at Goose Creek Substation. (TD 12/15/2023)
 - Extend the existing 500kV ring bus at Goose Creek Substation to be set up for a future six-breaker ring arrangement. One breaker to be installed initially creating a five-breaker ring bus.
 - Install a new 230kV ring bus at Goose Creek Substation to be set up for a future four-breaker ring arrangement. Three 230kV breakers to be installed initially.
- Cut and extend line #227 (Belmont to Beaumeade) into Goose Creek Substation. (TD 12/15/2023)
- Upgrade 230kV Pleasant View breakers L3T203 and L3T2180 from 50kA to **80kA** (s2609.9)


Estimated Cost: \$41.0M Total (Transmission Line \$5.0M; Substation \$36.0M)

Projected In-Service: 12/15/2027

Supplemental Project ID: (see above)

Project Status: Engineering

Model: 2025 RTEP



Dominion Transmission Zone M-3 Process

Barrister 230kV Delivery - DEV

Need Number: DOM-2022-0001

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Previously Presented:

Need – 06/07/2022

Solution – 08/09/2022

Project Driver:

Customer Service

Specific Assumption Reference:

Customer load request will be evaluated per Dominion’s Facility Interconnection Requirements Document and Dominion’s Transmission Planning Criteria.


Problem Statement:

DEV Distribution has submitted a DP Request for a new substation (Barrister) in Loudoun County with a total load in excess of 100MW. Requested in-service date is 6/30/2026.

Projected 2027 Load

Summer: 147.0 MW

Winter: 130.0 MW



Dominion Transmission Zone M-3 Process Barrister 230kV Delivery - DEV

Need Number: DOM-2022-0001

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Selected Solution:

Interconnect the new substation by cutting and extending Line from Roundtable to Stratus and Line from Lockridge to Stratus into the proposed Barrister Substation. Terminate both ends into a six-breaker ring bus arrangement to create Roundtable- Barrister, Lockridge-Barrister lines as well as two Stratus-Barrister lines.

Need Number DOM-2022-0041 (Stratus 230kV Delivery - DEV) is adjacent to Barrister Substation.

Estimated Cost: \$24.0M (Total)


Barrister Substation	\$10.0M
Line Extension	\$ 2.0M
Barrister Land Purchase	\$12.0M

Projected In-Service: 06/30/2026

Supplemental Project ID: s3027

Project Status: Engineering

Model: 2025 RTEP



Dominion Transmission Zone M-3 Process

Ocean Court 230kV Delivery - DEV

Need Number: DOM-2022-0002

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Previously Presented:

Need – 06/07/2022

Solution – 08/09/2022

Project Driver:

Customer Service

Specific Assumption Reference:

Customer load request will be evaluated per Dominion’s Facility Interconnection Requirements Document and Dominion’s Transmission Planning Criteria.


Problem Statement:

DEV Distribution has submitted a DP Request for a new substation (Ocean Court) in Loudoun County with a total load in excess of 100MW. Requested in-service date is 6/30/2024.

Projected 2027 Load

Summer: 158.0 MW

Winter: 142.7 MW



Dominion Transmission Zone M-3 Process Ocean Court 230kV Delivery - DEV

Need Number: DOM-2022-0002

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Selected Solution:

Cut and extend Line #2231 (Global Plaza-Pacific) to the proposed Ocean Court Substation. Terminate lines in a four-breaker 230kV ring bus with an ultimate arrangement of six-breaker ring.


Estimated Cost: \$10.0M (Total)

Projected In-Service: 06/30/2024

Supplemental Project ID: s3028

Project Status: Engineering

Model: 2025 RTEP



Dominion Transmission Zone M-3 Process Pleasant View - Add 4th TX - DEV

Need Number: DOM-2022-0010

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Previously Presented:

Need – 03/08/2022

Solution – 08/09/2022

Project Driver:

Customer Service

Specific Assumption Reference:

Customer load request will be evaluated per Dominion’s Facility Interconnection Requirements Document and Dominion’s Transmission Planning Criteria.


Problem Statement:

DEV Distribution has submitted a DP Request to add the 4th distribution transformer at Pleasant View Substation in Loudoun County. The new transformer is being driven by continued load growth in the area. Requested in-service date is 07/15/2023.

Projected 2027 Load

Summer: 55.0 MW

Winter: 55.0 MW



Dominion Transmission Zone M-3 Process Pleasant View - Add 4th TX - DEV

Need Number: DOM-2022-0010

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Selected Solution:

Install a 1200 Amp, 50kAIC circuit switcher and associated equipment (bus, relaying, etc.) to feed the new transformer at Pleasant View.


Estimated Cost: \$1.0 M

Projected In-Service: 03/06/2025

Supplemental Project ID: s3029

Project Status: Engineering

Model: 2025 RTEP



Dominion Transmission Zone M-3 Process Dawkins Branch 230kV Delivery - NOVEC

Need Number: DOM-2022-0017

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Previously Presented:

Need – 06/07/2022

Solution – 07/12/2022

Project Driver:

Customer Service

Specific Assumption Reference:

Customer load request will be evaluated per Dominion’s Facility Interconnection Requirements Document and Dominion’s Transmission Planning Criteria.


Problem Statement:

NOVEC has submitted a DP Request for a new substation (Dawkins Branch) to serve a data center complex in Prince William County with a total load in excess of 100 MW. Requested in-service date is 07/01/2023.

Projected 2027 Load

Summer: 73.0 MW

Winter: 76.8 MW



Dominion Transmission Zone M-3 Process Dawkins Branch 230kV Delivery - NOVEC

Need Number: DOM-2022-0017

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Selected Solution:

Interconnect the new substation by cutting and extending Line #2163 (Vint Hill - Liberty) to the proposed Dawkins Branch Substation. Terminate both ends into a four-breaker ring arrangement to create a Vint Hill – Dawkins Branch line and a Dawkins Branch - Liberty line.


Estimated Cost: \$16.0M

Projected In-Service: 06/30/2023

Supplemental Project ID: s3018

Project Status: Complete

Model: 2025 RTEP



Dominion Transmission Zone M-3 Process Garrisonville - Add 2nd TX - DEV

Need Number: DOM-2022-0019

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Previously Presented:

Need – 06/07/2022

Solution – 07/12/2022

Project Driver:

Customer Service

Specific Assumption Reference:

Customer load request will be evaluated per Dominion’s Facility Interconnection Requirements Document and Dominion’s Transmission Planning Criteria.


Problem Statement:

DEV Distribution has submitted a DP Request to add a 2nd distribution transformer at Garrisonville Substation in Stafford County. The new transformer is being driven by significant area load growth. Requested in-service date is 12/31/2023.

Projected 2027 Load

Summer: 59.9 MW

Winter: 74.4 MW



Dominion Transmission Zone M-3 Process Garrisonville - Add 2nd TX - DEV

Need Number: DOM-2022-0019

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Selected Solution:

Install a 1200 Amp, 50kAIC circuit switcher and associated equipment (bus, relaying, etc.) to feed the new transformer at Garrisonville.

Estimated Cost: \$0.75M

Projected In-Service: 05/17/2024

Supplemental Project ID: s3019

Project Status: Construction

Model: 2025 RTEP



Dominion Transmission Zone M-3 Process

Youngs Branch - Add 2nd TX - DEV

Need Number: DOM-2022-0020

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Previously Presented:

Need – 06/07/2022

Solution – 07/12/2022

Project Driver:

Customer Service

Specific Assumption Reference:

Customer load request will be evaluated per Dominion’s Facility Interconnection Requirements Document and Dominion’s Transmission Planning Criteria.


Problem Statement:

DEV Distribution has submitted a DP Request to add a 2nd distribution transformer at Youngs Branch Substation in Prince William County. The new transformer is being driven by datacenter load growth. Requested in-service date is 10/15/2023.

Projected 2027 Load

Summer: 141.6 MW

Winter: 124.5 MW



Dominion Transmission Zone M-3 Process

Youngs Branch - Add 2nd TX - DEV

Need Number: DOM-2022-0020

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Selected Solution:

Install a 1200 Amp, 50kAIC circuit switcher and associated equipment (bus, relaying, etc.) to feed the new transformer at Youngs Branch.


Estimated Cost: \$0.75M

Projected In-Service: 03/28/2024

Supplemental Project ID: s3020

Project Status: Construction

Model: 2025 RTEP



Dominion Transmission Zone M-3 Process

Replace Farmville TX#5 - DEV

Need Number: DOM-2022-0023

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Previously Presented:

Need – 04/12/2022

Solution – 09/06/2022

Project Driver:

Equipment Material Condition, Performance, and Risk


Specific Assumption Reference:

See details on Equipment Material Condition, Performance and Risk in Dominion’s Planning Assumptions presented in December 2021.

Problem Statement:

Farmville TX#5 is a 168 MVA, 230/115/13.2 kV transformer bank that was manufactured in 1981. This transformer bank has been identified for replacement based on the results of Dominion’s transformer health assessment (THA) process. Detailed drivers include:

- Age (>40 years old).
- Reduced BIL ratings (3 levels below standard).
- Tertiary winding design not meeting current MVA requirement for loading.
- Degraded porcelain type bushings.
- Oil DGA indicates high CO and CO2 levels; potential break down of dielectric paper insulation on main current carrying conductors inside the transformer.
- THA score less than 80.



Dominion Transmission Zone M-3 Process

Replace Farmville TX#5 - DEV

Need Number: DOM-2022-0023

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Selected Solution:

Replace Farmville TX#5 with a new three-phase, 230/115/13.2 kV, 168 MVA unit.
Include other ancillary equipment (high side breaker, arresters, switches, relays, etc.) as needed.


Estimated Cost: \$6.4 M

Projected In-Service: 12/31/2024

Supplemental Project ID: s3041

Project Status: Engineering

Model: 2025 RTEP



Dominion Transmission Zone M-3 Process

Replace Clubhouse TX#1 - DEV

Need Number: DOM-2022-0024

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Previously Presented:

Need – 04/12/2022

Solution – 09/06/2022

Project Driver:

Equipment Material Condition, Performance, and Risk


Specific Assumption Reference:

See details on Equipment Material Condition, Performance and Risk in Dominion’s Planning Assumptions presented in December 2021.

Problem Statement:

Clubhouse TX#1 is a 168 MVA, 230/115/13.2 kV transformer bank that was manufactured in 1981. This transformer bank has been identified for replacement based on the results of Dominion’s transformer health assessment (THA) process. Detailed drivers include:

- Age (>40 years old).
- Reduced BIL ratings (3 levels below standard).
- Tertiary winding design not meeting current MVA requirement for loading.
- Degraded porcelain type bushings.
- Oil DGA indicates high CO and CO2 levels; potential break down of dielectric paper insulation on main current carrying conductors inside the transformer.
- THA score less than 80.



Dominion Transmission Zone M-3 Process

Replace Clubhouse TX#1 - DEV

Need Number: DOM-2022-0024

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Selected Solution:

Replace Clubhouse TX#1 with a new three-phase, 230/115/13.2 kV, 224 MVA unit. Include other ancillary equipment (arresters, switches, relays, etc.) as needed.


Estimated Cost: \$6.6 M

Projected In-Service: 05/15/2024

Supplemental Project ID: s3042

Project Status: Construction

Model: 2025 RTEP



Dominion Transmission Zone M-3 Process

Evans Creek 230kV Delivery - DEV

Need Number: DOM-2022-0027

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Previously Presented:

Need – 05/10/2022

Solution – 07/12/2022

Project Driver:

Customer Service

Specific Assumption Reference:

Customer load request will be evaluated per Dominion’s Facility Interconnection Requirements Document and Dominion’s Transmission Planning Criteria.


Problem Statement:

DEV Distribution has submitted a delivery point request (Roanoke DP) for a new delivery point to serve a data center customer in La Crosse, VA. The total load is in excess of 100 MW. The customer requests service by August 1, 2025.

Projected 2027 Load

Summer: 126.0 MW

Winter: 98.0 MW



Dominion Transmission Zone M-3 Process Evans Creek 230kV Delivery - DEV

Need Number: DOM-2022-0027

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Selected Solution:

Construct Evans Creek 230kV substation with four breaker 230kV breaker ring bus to terminate two 230kV lines. Construct one new 230kV transmission line for approximately 5 miles from Tunstall Sub to Evans Creek Substation. Construct one new 230kV transmission line for approximately 3 miles from Raines Sub to Evans Creek Substation. New right-of-way will be needed for both transmission lines. New conductor to have a minimum summer normal rating of 1573 MVA.

Estimated Cost: \$30.0M (Total)


Transmission Line	\$15M
230kV Substation	\$15M

Projected In-Service: 08/01/2025

Supplemental Project ID: s3021

Project Status: Engineering

Model: 2025 RTEP



Dominion Transmission Zone M-3 Process Tunstall 230kV Delivery - DEV

Need Number: DOM-2022-0028

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Previously Presented:

Need – 05/10/2022

Solution – 07/12/2022

Project Driver:

Customer Service

Specific Assumption Reference:

Customer load request will be evaluated per Dominion’s Facility Interconnection Requirements Document and Dominion’s Transmission Planning Criteria.


Problem Statement:

DEV Distribution has submitted a delivery point request (Hillcrest DP) for a new delivery point to serve a data center customer in South Hill, VA. The total load is in excess of 100 MW. The customer requests service by August 1, 2025.

Projected 2027 Load

Summer: 77.0 MW

Winter: 59.0 MW



Dominion Transmission Zone M-3 Process Tunstall 230kV Delivery - DEV

Need Number: DOM-2022-0028

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Selected Solution:

- Obtain land and build a new 500/230kV Unity switching station near the intersection of Line #593 (Finneywood-Rawlings) and Route 138.
- Cut and terminate Line #593 into Unity 500/230kV switching station. In the new Unity switching station, install two 840 MVA 500/230kV transformers, a 230kV ring bus with 6 breakers and a 500kV ring bus with 6 breakers.
- Construct Tunstall 230kV substation with four rows of 230kV breaker and half bus to terminate four 230kV lines.
- Construct two new 230kV single circuit transmission lines for approximately 11 miles from Unity Sub to Tunstall Substation.
- New right-of-way will be needed for both transmission lines. New conductor to have a minimum summer normal rating of 1573 MVA.

Estimated Cost: \$140.0M (Total)



Transmission Line	\$40M
500kV Substation	\$80M
230kV Substation	\$20M

Projected In-Service: 08/01/2025

Supplemental Project ID: s3022

Project Status: Engineering

Model: 2025 RTEP



Dominion Transmission Zone M-3 Process

Raines 230kV Delivery - DEV

Need Number: DOM-2022-0029

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Previously Presented:

Need – 05/10/2022

Solution – 07/12/2022

Project Driver:

Customer Service

Specific Assumption Reference:

Customer load request will be evaluated per Dominion’s Facility Interconnection Requirements Document and Dominion’s Transmission Planning Criteria.


Problem Statement:

DEV Distribution has submitted a delivery point request (Interstate DP) for a new delivery point to serve a data center customer in La Crosse, VA. The total load is less than 100 MW. The customer requests service by August 1, 2025.

Projected 2027 Load

Summer: 37.0 MW

Winter: 25.0 MW



Dominion Transmission Zone M-3 Process

Raines 230kV Delivery - DEV

Need Number: DOM-2022-0029

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Selected Solution:

Construct Raines 230kV substation with four breaker 230kV breaker ring bus to terminate two 230kV lines. Construct one new 230kV transmission line for approximately 8 miles from Tunstall Sub to Raines Substation. New right-of-way will be needed for the transmission line. New conductor to have a minimum summer normal rating of 1573 MVA.

Due to the total load requested less than 100 MW, the data center customer will be required to pay excess facilities for all equipment required for the ring bus configuration above a T-tap.

Estimated Cost: \$20.0M (Total)


Transmission Line	\$15M
230kV Substation	\$5M

Projected In-Service: 08/01/2025

Supplemental Project ID: s3023

Project Status: Engineering

Model: 2025 RTEP



Dominion Transmission Zone M-3 Process Mountain Run 230kV Delivery - REC

Need Number: DOM-2022-0034

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Previously Presented:

Need – 06/07/2022

Solution – 09/06/2022

Project Driver:

Customer Service

Specific Assumption Reference:

Customer load request will be evaluated per Dominion’s Facility Interconnection Requirements Document and Dominion’s Transmission Planning Criteria.


Problem Statement:

Rappahannock Electric Cooperative (REC) has submitted a two DP Requests. One to increase capacity at their existing 115kV Mountain Run DP and one for a new substation in the vicinity of the Mountain Run DP to serve a new data center complex in Culpeper County with a total projected load of 350 MW. The requested in-service date is 06/01/2024.

Projected 2027 Load

Summer: 140.7 MW

Winter: 140.7 MW



Dominion Transmission Zone M-3 Process

Mountain Run 230kV Delivery - REC

Need Number: DOM-2022-0034

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Selected Solution:

1. Build new Kyser switching station to feed REC’s existing Mountain Run DP. The initial build will include four 230kV breakers, associated bus, switches, etc.
2. Build new Cirrus switching station to feed REC’s new DP. The initial build will include four 230kV breakers, associated bus, switches, etc.
3. Wreck and rebuild approximately five miles of existing double-circuit 115kV Line #2 and Line #70, using 230kV construction, from Mountain Run Junction to the new Kyser/Cirrus switching stations.
4. Cut 230kV Line #2199 at Mountain Run Junction and feed the rebuilt double-circuit line to Kyser/Cirrus switching stations.
5. Re-connect the remaining sections of 115kV Lines #2 and Line #70 at Mountain Run Junction.
6. REC to convert their existing Mountain Run DP to 230kV.
7. Install a 230/115kV – 168 MVA transformer and spare at Cirrus switching station to maintain the 115kV feed to Culpeper and Culpeper DP.


Estimated Cost:	\$60.0 M (Total)
Transmission Line	\$22.0M
Substation	\$38.0M

Projected In-Service: 12/30/2025

Supplemental Project ID: s3044

Project Status: Engineering

Model: 2025 RTEP



Dominion Transmission Zone M-3 Process Northstar 230kV Delivery - DEV

Need Number: DOM-2022-0035

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Previously Presented:

Need – 06/07/2022

Solution – 07/12/2022

Project Driver:

Customer Service

Specific Assumption Reference:

Customer load request will be evaluated per Dominion’s Facility Interconnection Requirements Document and Dominion’s Transmission Planning Criteria.


Problem Statement:

NOVEC has submitted a DP Request for a new substation (Northstar) in Loudoun County with a total load in excess of 100MW. Requested in-service date is 01/01/2025.

Projected 2027 Load

Summer: 124.0 MW

Winter: 153.0 MW



Dominion Transmission Zone M-3 Process Northstar 230kV Delivery - DEV

Need Number: DOM-2022-0035

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Selected Solution:

Interconnect the new substation by cutting and extending Line #2045 (Brambleton-Loudoun) to the proposed Northstar Substation. Lines to terminate in a 230kV four-breaker ring arrangement with an ultimate arrangement of a six-breaker ring.


Estimated Cost: \$10.0M

Projected In-Service: 01/01/2025

Supplemental Project ID: s3024

Project Status: Engineering

Model: 2025 RTEP



Dominion Transmission Zone M-3 Process Thunderball 230kV Delivery - DEV

Need Number: DOM-2022-0036

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Previously Presented:

Need – 06/07/2022

Solution – 07/12/2022

Project Driver:

Customer Service

Specific Assumption Reference:

Customer load request will be evaluated per Dominion’s Facility Interconnection Requirements Document and Dominion’s Transmission Planning Criteria.


Problem Statement:

NOVEC has submitted a DP Request for a new substation (Thunderball) in Loudoun County with a total load in excess of 100MW. Requested in-service date is 11/02/2024.

Projected 2027 Load

Summer: 124.0 MW

Winter: 153.0 MW



Dominion Transmission Zone M-3 Process Thunderball 230kV Delivery - DEV

Need Number: DOM-2022-0036

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Selected Solution:

Interconnect the new substation by cutting and extending Line #206 (Stonewater-Brambleton) to the proposed Thunderball Substation. Lines to terminate in a 230kV four-breaker ring arrangement with an ultimate arrangement of a six-breaker ring.


Estimated Cost: \$10.0M

Projected In-Service: 11/02/2024

Supplemental Project ID: s3025

Project Status: Construction

Model: 2025 RTEP



Dominion Transmission Zone M-3 Process

Trappe Rock 230kV Delivery - DEV

Need Number: DOM-2022-0037

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Previously Presented:

Need – 06/07/2022

Solution – 07/12/2022

Project Driver:

Customer Service

Specific Assumption Reference:

Customer load request will be evaluated per Dominion’s Facility Interconnection Requirements Document and Dominion’s Transmission Planning Criteria.


Problem Statement:

NOVEC has submitted a DP Request for a new substation (Trappe Rock) in Loudoun County with a total load in excess of 100MW. Requested in-service date is 9/02/2024.

Projected 2027 Load

Summer: 90.0 MW

Winter: 153.0 MW



Dominion Transmission Zone M-3 Process

Trappe Rock 230kV Delivery - DEV

Need Number: DOM-2022-0037

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Selected Solution:

Interconnect the new substation by cutting and extending Line #201 (Belmont-Altair) to the proposed Trappe Rock Substation. Lines to terminate in a 230kV four-breaker ring arrangement with an ultimate arrangement of a six-breaker ring.


Estimated Cost: \$10.0M

Projected In-Service: 09/02/2024

Supplemental Project ID: s3026

Project Status: Construction

Model: 2025 RTEP



Dominion Transmission Zone M-3 Process

White Oak 230kV Delivery - DEV

Need Number: DOM-2022-0038

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Previously Presented:

Need – 07/12/2022

Solution – 08/09/2022

Project Driver:

Customer Service

Specific Assumption Reference:

Customer load request will be evaluated per Dominion’s Facility Interconnection Requirements Document and Dominion’s Transmission Planning Criteria.


Problem Statement:

DEV Distribution has submitted a delivery point request at White Oak Substation to serve a data center customer in Henrico, VA. The total load is in excess of 100 MW. The customer requests service by March 1, 2023.

Projected 2027 Load

Summer: 146.5 MW

Winter: 136.5 MW



Dominion Transmission Zone M-3 Process White Oak 230kV Delivery - DEV

Need Number: DOM-2022-0038

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Selected Solution:

To Interconnect Customer Load: (s3030.1)

- Install equipment and bus work to support the installation of 2-56 MVA distribution transformers.

To Resolve DNH 300 MW N-1-1 Load Drop Violation: (s3030.2)

- Cut Line #2075 and extend double circuit 230kV lines into White Oak Substation. Install 2-1200 Amp switches and upgrade bus work and existing equipment at the White Oak Substation. Add 3 additional 230kV breakers to terminate 230kV lines.


Estimated Cost: \$30 M

Projected In-Service: March 2023 (to connect Distribution TX)
Dec 2025 (to cut line #2075 into White Oak)

Supplemental Project ID: s3030.1, s3030.2

Project Status: Engineering

Model: 2025 RTEP



Dominion Transmission Zone M-3 Process Techpark Place 230kV Delivery - DEV

Need Number: DOM-2022-0039

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Previously Presented:

Need – 07/12/2022

Solution – 08/09/2022

Project Driver:

Customer Service

Specific Assumption Reference:

Customer load request will be evaluated per Dominion’s Facility Interconnection Requirements Document and Dominion’s Transmission Planning Criteria.


Problem Statement:

DEV Distribution has submitted a new delivery point request for Techpark Place (TPP) Substation to serve a data center customer in Henrico, VA. The total load is in excess of 100 MW. The customer requests service by January 1, 2024.

Projected 2027 Load

Summer: 283.6 MW

Winter: 283.6 MW



Dominion Transmission Zone M-3 Process Techpark Place 230kV Delivery - DEV

Need Number: DOM-2022-0039

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Selected Solution:

Cut Line #286 (Darbytown-White Oak) and Line #2198 (Portugee-White Oak) and terminate at new TPP Substation in a 6-breaker 230kV ring bus. Include associated equipment (bus, switches, relays, etc.) as required.


Estimated Cost: \$25 M

Projected In-Service: 04/01/2024

Supplemental Project ID: s3031

Project Status: Construction

Model: 2025 RTEP



Dominion Transmission Zone M-3 Process

Farmwell - Add 4th TX - DEV

Need Number: DOM-2022-0040

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Previously Presented:

Need – 06/07/2022

Solution – 08/09/2022

Project Driver:

Customer Service

Specific Assumption Reference:

Customer load request will be evaluated per Dominion’s Facility Interconnection Requirements Document and Dominion’s Transmission Planning Criteria.


Problem Statement:

DEV Distribution has submitted a DP Request to add a 4th distribution transformer at Farmwell Substation in Loudoun County. The new transformer is being driven by continued load growth in the area and contingency loading for loss of one of the existing transformers. Requested in-service date is 08/01/2023.

Projected 2027 Load

Summer: 292.0 MW

Winter: 292.0 MW



Dominion Transmission Zone M-3 Process

Farmwell - Add 4th TX - DEV

Need Number: DOM-2022-0040

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Selected Solution:

Install a 1200 Amp, 50kAIC circuit switcher and associated equipment (bus, relaying, etc.) to feed the new transformer at Farmwell.


Estimated Cost: \$0.5M

Projected In-Service: 03/28/2024

Supplemental Project ID: s3032

Project Status: Construction

Model: 2025 RTEP



Dominion Transmission Zone M-3 Process

Stratus 230kV Delivery - DEV

Need Number: DOM-2022-0041

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Previously Presented:

Need – 06/07/2022

Solution – 08/09/2022

Project Driver:

Customer Service

Specific Assumption Reference:

Customer load request will be evaluated per Dominion’s Facility Interconnection Requirements Document and Dominion’s Transmission Planning Criteria.


Problem Statement:

DEV has submitted a DP Request for a new substation (Stratus) in Loudoun County with a total load in excess of 100MW. Requested in-service date is 12/31/2024.

Projected 2027 Load

Summer: 185.0 MW

Winter: 167.0 MW



Dominion Transmission Zone M-3 Process Stratus 230kV Delivery - DEV

Need Number: DOM-2022-0041

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Selected Solution:

Interconnect the new substation by cutting and extending Line #2188 (Lockridge-Shellhorn) and Line #2031 (Roundtable-Enterprise) into the proposed Stratus Substation. Terminate both ends into a six-breaker ring bus arrangement to create Roundtable-Stratus, Stratus-Shellhorn, Enterprise-Stratus, and Lockridge-Stratus lines.

Need Number DOM-2022-0001 (Barrister 230kV Delivery – DEV) will be adjacent to Stratus Substation.

Estimated Cost: \$24.0M (Total)


Stratus Substation	\$10.0M
Line Extension	\$ 2.0M
Stratus Land Purchase	\$12.0M

Projected In-Service: 08/29/2025

Supplemental Project ID: s3033

Project Status: Engineering

Model: 2025 RTEP



Dominion Transmission Zone M-3 Process

Lockridge – Add 3 TX's - DEV

Need Number: DOM-2022-0044

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Previously Presented:

Need – 06/07/2022

Solution – 08/09/2022

Project Driver:

Customer Service

Specific Assumption Reference:

Customer load request will be evaluated per Dominion’s Facility Interconnection Requirements Document and Dominion’s Transmission Planning Criteria.


Problem Statement:

DEV Distribution has submitted a DP Request to add a three additional distribution transformers at Lockridge Substation in Loudoun County. The new transformers are being driven by continued load growth in the area and contingency loading for loss of one of the existing transformers. Requested in-service date is 01/01/2023.

Projected 2027 Load

Summer: 288.0 MW

Winter: 288.0 MW



Dominion Transmission Zone M-3 Process Lockridge – Add 3 TX's - DEV

Need Number: DOM-2022-0044

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Selected Solution:

Install three 1200 Amp, 50kAIC circuit switchers and associated equipment (bus, relaying, etc.) to feed the three new transformers at Lockridge.


Estimated Cost: \$1.5M

Projected In-Service: 02/28/2024

Supplemental Project ID: s3034

Project Status: Construction

Model: 2025 RTEP



Dominion Transmission Zone M-3 Process Hornbaker 230kV Delivery - NOVEC

Need Number: DOM-2022-0045

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Previously Presented:

Need – 07/12/2022

Solution – 08/09/2022

Project Driver:

Customer Service

Specific Assumption Reference:

Customer load request will be evaluated per Dominion’s Facility Interconnection Requirements Document and Dominion’s Transmission Planning Criteria.


Problem Statement:

NOVEC has submitted a DP Request for a new substation (Hornbaker) to serve a data center complex in Prince William County with a total load in excess of 100 MW. Requested in-service date is 12/30/2025.

Projected 2027 Load

Summer: 150.0 MW

Winter: 150.0 MW



Dominion Transmission Zone M-3 Process Hornbaker 230kV Delivery - NOVEC

Need Number: DOM-2022-0045

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Selected Solution:

Interconnect the new substation by cutting and extending Line #2187 (Liberty - Pioneer) to the proposed Hornbaker Substation. Lines to terminate into a 230 kV four-breaker ring arrangement with an ultimate arrangement of a six-breaker ring.


Estimated Cost:	\$45.0M (Total)
Transmission Line	\$ 8.0M
Real Estate	\$25.0M
Substation	\$12.0M

Projected In-Service: 12/30/2025

Supplemental Project ID: s3035.1

Project Status: Engineering

Model: 2025 RTEP



Dominion Transmission Zone M-3 Process Do No Harm (DNH) Analysis

Need Number: DOM-2022-0045-DNH

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Presentation Date:

DNH – 08/09/2022

Supplemental Project Driver:

Do No Harm Analysis

Specific Assumption Reference:


Customer load request will be evaluated per Dominion’s Facility Interconnection Requirements Document and Dominion’s Transmission Planning Criteria.

Problem Statement:

PJM has identified N-1-1 thermal violations on the following separate facilities in the 2022 Do-No-Harm analysis:

- Line #2163 (Dawkins Branch to Vint Hill)
 - Contingency Scenario: DVP_P:1-2: LN 2151 and DVP_P:1-2: LN 2011
- Line #2151 (Railroad to Gainesville)
 - Contingency Scenario: DVP_P:1-2: LN 2163 and DVP_P:1-2: LN 2011
- Line #2101 (Vint Hill to Nokesville Segment)
 - Contingency Scenarios: DVP_P:1-2: LN 2151 and DVP_P:1-2: LN 2011
- Line #2011 (Clifton to Brickyard Segment)
 - Contingency Scenario: DVP_P:1-2: LN 2151 and DVP_P:1-2: LN 2163

The violations are caused by previously presented Supplemental Project DOM-2022-0045 in the Dominion Zone.



Dominion Transmission Zone M-3 Process Do No Harm (DNH) Analysis

Need Number: DOM-2022-0045-DNH

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Selected Solution:

- Construct one new 230 kV transmission line for approximately 7.5 miles from Hornbaker to Nokesville Substation with a minimum summer normal conductor rating of 1573 MVA. New right-of-way and expansion of existing right-of-way will be required.
- Install a 230 kV ring bus and associated 230 kV equipment (breakers, switches, leads) at the existing Nokesville Substation.
- Re-configure the existing terminations of line #2101 (Bristers – Vint Hill) into Nokesville Substation to accommodate the new 230 kV line.


Estimated Cost:	\$139.0M (Total)
Transmission Line	\$45.0M
Real Estate	\$82.5M
Substation	\$11.5M

Projected In-Service: 12/31/2027

Supplemental Project ID: s3035.2

Project Status: Conceptual

Model: 2025 RTEP



Dominion Transmission Zone M-3 Process Mint Springs 230kV Delivery - NOVEC

Need Number: DOM-2022-0046

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Previously Presented:

Need – 07/12/2022

Solution – 08/09/2022

Project Driver:

Customer Service

Specific Assumption Reference:

Customer load request will be evaluated per Dominion’s Facility Interconnection Requirements Document and Dominion’s Transmission Planning Criteria.


Problem Statement:

NOVEC has submitted a DP Request for a new substation (Mint Springs) to serve a data center complex in Prince William County with a total load in excess of 100 MW. Requested in-service date is 01/02/2026.

Projected 2027 Load

Summer: 50.0 MW

Winter: 50.0 MW



Dominion Transmission Zone M-3 Process Mint Springs 230kV Delivery - NOVEC

Need Number: DOM-2022-0046

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Selected Solution:

Interconnect the new substation by cutting and extending Line #2030 (Loudoun - Gainesville) to the proposed Mint Springs Substation. Lines to terminate into a 230 kV four-breaker ring arrangement with an ultimate arrangement of a six-breaker ring.


Estimated Cost: \$16.0M

Projected In-Service: 01/02/2026

Supplemental Project ID: s3036

Project Status: Engineering

Model: 2025 RTEP



Dominion Transmission Zone M-3 Process

Rixlew 230kV Delivery - NOVEC

Need Number: DOM-2022-0047

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Previously Presented:

Need – 07/12/2022

Solution – 08/09/2022

Project Driver:

Customer Service

Specific Assumption Reference:

Customer load request will be evaluated per Dominion’s Facility Interconnection Requirements Document and Dominion’s Transmission Planning Criteria.


Problem Statement:

NOVEC has submitted a DP Request for a new substation (Rixlew) to serve a data center complex in Manassas with a total load in excess of 100 MW. Requested in-service date is 12/31/2024.

Projected 2027 Load

Summer: 95.0 MW

Winter: 103.0 MW



Dominion Transmission Zone M-3 Process Rixlew 230kV Delivery - NOVEC

Need Number: DOM-2022-0047

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Selected Solution:

Interconnect the new substation by cutting and extending Line #2228 (Liberty - Pioneer) to the proposed Rixlew Substation. Lines to terminate into a 230 kV four-breaker ring arrangement with an ultimate arrangement of a six-breaker ring.


Estimated Cost: \$10.0M

Projected In-Service: 06/20/2025

Supplemental Project ID: s3037

Project Status: Engineering

Model: 2025 RTEP



Dominion Transmission Zone M-3 Process Do No Harm (DNH) Analysis

Need Number: DOM-2022-0001-DNH & DOM-2022-0041-DNH

Process Stage:
Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Presentation Date:
DNH – 09/06/2022


Supplemental Project Driver:
Do No Harm Analysis

Specific Assumption Reference:
Customer load request will be evaluated per Dominion’s Facility Interconnection Requirements Document and Dominion’s Transmission Planning Criteria.

Problem Statement:
PJM has identified N-1-1 thermal violations on the following facility in the 2022 Do-No-Harm analysis:

- Ox-Braddock Line
 - Contingency Scenario: DVP_P1-2: LN 541 and DVP_P1-2: LN 2022

The violations are caused by previously presented Supplemental Projects DOM-2022-0001 & DOM-2022-0041 in the Dominion Zone.



Dominion Transmission Zone M-3 Process Do No Harm (DNH) Analysis

Need Number: DOM-2022-0001-DNH & DOM-2022-0041-DNH

Process Stage:
Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Selected Solution:
Rebuild approx. 7.9 miles of double-circuit Line from Ox to Braddock and partial Line#2097 (Ox-Idylwood) to current 230kV standards. The normal summer rating of the line conductor will be 1573 MVA.


Estimated Cost:	\$43.5M (Total)
Transmission Line	\$37.0M
Substation	\$ 6.5M

Projected In-Service: 06/30/2027

Supplemental Project ID: s3040

Project Status: Conceptual

Model: 2025 RTEP



Dominion Transmission Zone M-3 Process

Prentice Drive 230kV Delivery - DEV

Need Number: DOM-2022-0003

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Previously Presented:

Need – 06/07/2022

Solution – 08/08/2023

Project Driver:

Customer Service

Specific Assumption Reference:

Customer load request will be evaluated per Dominion’s Facility Interconnection Requirements Document and Dominion’s Transmission Planning Criteria.


Problem Statement:

DEV has submitted a DP Request for a new substation (Prentice) in Loudoun County with a total load in excess of 100MW. Requested in-service date is 12/30/2024.

Projected 2028 Load

Summer: 160.0 MW

Winter: 145.7 MW



Dominion Transmission Zone M-3 Process Prentice Drive 230kV Delivery - DEV

Need Number: DOM-2022-0003

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Selected Solution:

Interconnect the new substation by cutting and extending Line #2188 (Lockridge – Shellhorn) to the proposed Prentice Drive Substation. Lines to terminate in a 230kV six-breaker ring arrangement.


Estimated Cost: \$20.0 M

Projected In-Service: 12/30/2024

Supplemental Project ID: s3056

Project Status: Engineering

Model: 2027 RTEP



Dominion Transmission Zone M-3 Process Line #77 End of Life Rebuild

Need Number: DOM-2022-0016

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Previously Presented:

Need – 07/21/2022

Solution – 08/18/2022

Project Driver:

Equipment Material Condition, Performance and Risk


Specific Assumption Reference:

See details on Equipment Material Condition, Performance and Risk in Dominion’s Planning Assumptions presented in December 2021.

Problem Statement:

Dominion Energy has identified a need to rebuild approximately 1.8 miles of 115kV Line #77 (Carolina – Roanoke Rapids Hydro) based on the company’s End of Life criteria.

- Line #77 was constructed on 2 pole and 3 pole wood H-frame structures in 1931 from Carolina to Roanoke Rapids Hydro. This line has ACSR and CU conductor and 7/16” steel static.
- Industry guidelines indicate equipment life for wood structures is 35-55 years, conductor and connectors are 40-60 years, and porcelain insulators are 50 years.
- Line #77 is the sole transmission feed for Roanoke Rapids Hydro Generation.



Dominion Transmission Zone M-3 Process Line #77 End of Life Rebuild

Need Number: DOM-2022-0016

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Selected Solution:

Rebuild approximately 1.8 miles single circuit of line #77 from Carolina to Roanoke Rapids Hydro to current 115 kV standards, and with a conductor minimum summer normal rating of 262 MVA. The terminal ends should be upgraded as needed.


Estimated Cost: \$7.4 M

Projected In-Service: 11/28/2025

Supplemental Project ID: s3038

Project Status: Conceptual

Model: 2025 RTEP



Dominion Transmission Zone M-3 Process Allegheny 138kV Delivery Point - DEV

Need Number: DOM-2022-0022

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Previously Presented:

Need – 06/13/2022

Solution – 09/15/2022

Project Driver:

Customer Service

Specific Assumption Reference:

Customer load request will be evaluated per Dominion’s Facility Interconnection Requirements Document and Dominion’s Transmission Planning Criteria.

Problem Statement:

DEV distribution has submitted a DP Request for a new 138kV DP (Allegheny) to serve increasing load in Allegheny County. The total projected load will be approximately 21 MW by 2033. The requested in-service date is 12/31/2023.

Projected 2028 Load

Summer: 17.4 MW

Winter: 19.3 MW



Dominion Transmission Zone M-3 Process

Alleghany 138kV Delivery Point - DEV

Need Number: DOM-2022-0022

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Selected Solution:

Create a tee-tap on 138kV Line #133 Clifton Forge – Low Moor between structures 22 and 23 to source the customer substation located approximately 100’ away from the line. Install switch structures and switches on both sides of the tap point and an H-frame backbone structure inside Alleghany Substation, along with a wave trap, MOAB switch, circuit switcher and other ancillary work as needed.


Estimated Cost: \$5.0 M (Total)
Transmission Cost: \$3.6 M
Substation Cost: \$1.4 M

Projected In-Service: 12/20/2023

Supplemental Project ID: s3045

Project Status: Complete

Model: 2025 RTEP



Dominion Transmission Zone M-3 Process

Jeffress 230kV Delivery - MEC

Need Number: DOM-2022-0032

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Previously Presented:

Need – 06/07/2022

Solution – 04/11/2023

Project Driver:

Customer Service

Specific Assumption Reference:

Customer load request will be evaluated per Dominion’s Facility Interconnection Requirements Document and Dominion’s Transmission Planning Criteria.


Problem Statement:

ODEC on behalf of Mecklenburg Electric Coop (MEC) has submitted a delivery point request (Lakeside DP) for a new delivery point to serve a data center customer in Clarksville, VA. The total load is in excess of 100 MW. The customer requests service by Jan 1, 2025.

Projected 2028 Load

Summer: 103.0 MW

Winter: 103.0 MW



Dominion Transmission Zone M-3 Process

Jeffress 230kV Delivery - MEC

Need Number: DOM-2022-0032

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Selected Solution:

The project will need to be built in 2 stages due to the timeframe associated with obtaining a CPCN and extend 230kV into the area. The 115kV Station will help meet the initial load target date.

Stage 1: Interconnect the new substation by cutting and extending Line #36 (Chase City– Buggs Island) to the proposed Jeffress 115kV Substation. The substation and line equipment used to interconnect Jeffress 115 kV with the transmission system will be same as 230kV substation. The projected in-service date for Stage 1 is January 1, 2025.

Stage 2: Construct two 230kV single circuits from Finneywood 500/230kV sub to the proposed Jeffress 230kV Substation. Once conversion from 115kV to 230kV substation is complete, remove Jeffress 115kV tap and reconnect Line #36 Chase City– Buggs Island. The projected in-service date for Stage 2 is July 1, 2026.

Estimated Cost: \$120.0 M (Total)

Transmission: \$90.0 M

115kV Substation: \$15.0 M

230kV Substation: \$15.0 M


Projected In-Service: 07/01/2026 (Stage 2)

Supplemental Project ID: s3061



Project Status: Engineering

Model: 2027 RTEP

Stage 1: Jeffress 115kV Sub



Stage 2: Jeffress 230kV Sub



Dominion Transmission Zone M-3 Process Sycolin Creek 230kV Delivery - DEV

Need Number: DOM-2022-0042

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Previously Presented:

Need – 06/07/2022

Solution – 06/06/2023

Project Driver:

Customer Service

Specific Assumption Reference:

Customer load request will be evaluated per Dominion’s Facility Interconnection Requirements Document and Dominion’s Transmission Planning Criteria.


Problem Statement:

DEV has submitted a DP Request for a new substation (Sycolin Creek) in Loudoun County with a total load in excess of 100MW. Requested in-service date is 06/15/2026.

Projected 2028 Load

Summer: 136.0 MW

Winter: 100.0 MW



Dominion Transmission Zone M-3 Process Sycolin Creek 230kV Delivery - DEV

Need Number: DOM-2022-0042

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Selected Solution:

Interconnect the new substation by constructing two 230kV lines approximately 1.0 mile from Twin Creeks Substation to proposed Sycolin Creek Substation. Lines to terminate in a 230kV six-breaker ring arrangement.


Estimated Cost: \$28.0 M

Projected In-Service: 06/15/2026

Supplemental Project ID: s3048

Project Status: Engineering

Model: 2027 RTEP



Dominion Transmission Zone M-3 Process

Twin Creeks 230kV Delivery - DEV

Need Number: DOM-2022-0043

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Previously Presented:

Need – 06/07/2022

Solution – 06/06/2023

Project Driver:

Customer Service

Specific Assumption Reference:

Customer load request will be evaluated per Dominion’s Facility Interconnection Requirements Document and Dominion’s Transmission Planning Criteria.


Problem Statement:

DEV has submitted a DP Request for a new substation (Twin Creeks) in Loudoun County with a total load in excess of 100MW. Requested in-service date is 12/31/2024.

Projected 2028 Load

Summer: 209.2 MW

Winter: 183.0 MW



Dominion Transmission Zone M-3 Process Twin Creeks 230kV Delivery - DEV

Need Number: DOM-2022-0043

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Selected Solution:

Interconnect the new substation by cutting and extending Line #203 (Pleasant View – Edwards Ferry) to the proposed Twin Creeks Substation. Lines to terminate in a 230kV six-breaker ring arrangement.


Estimated Cost: \$20.0 M

Projected In-Service: 12/31/2024

Supplemental Project ID: s3049

Project Status: Engineering

Model: 2027 RTEP



Dominion Transmission Zone M-3 Process Do No Harm (DNH) Analysis

Need Number: DOM-2022-0046-DNH & DOM-2022-0047-DNH

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Presentation Date:

DNH – 02/07/2023

Supplemental Project Driver:

Do No Harm Analysis

Specific Assumption Reference:


Customer load request will be evaluated per Dominion’s Facility Interconnection Requirements Document and Dominion’s Transmission Planning Criteria.

Problem Statement:

PJM has identified N-1-1 thermal violations on the following separate facilities in the 2022 Do-No-Harm analysis:

- Line #2101 (Nokesville to Bristers Segment)
 - Contingency Scenario: DVP_P1-2: LN 569 and DVP_P1-2: LN 539
- Bristers 500-230 kV TX#1
 - Contingency Scenario: DVP_P1-3: 8BRISTER-TX#1 and DVP_P1-2: LN 539
- Bristers 500-230 kV TX#2
 - Contingency Scenario: DVP_P1-3: 8BRISTER-TX#2 and DVP_P1-2: LN 539

The violations are caused by previously presented Supplemental Projects DOM-2022-0046 and DOM-2022-0047 in the Dominion Zone.



Dominion Transmission Zone M-3 Process Do No Harm (DNH) Analysis

Need Number: DOM-2022-0046-DNH & DOM-2022-0047-DNH

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Selected Solution (Part 1 of 2):

To address: 230 kV Line Violation

- Reconductor approximately 9.2 miles of Line #2101 (Nokesville to Bristers) using a higher capacity conductor as well as terminal equipment upgrades to achieve a minimum normal summer conductor rating of 1573 MVA.


Estimated Cost: \$23.0M

Projected In-Service: 12/31/2027

Supplemental Project ID: s3047.1

Project Status: Conceptual

Model: 2027 RTEP



Initially posted to 2024 Local Plan for s3047.2

Updates to s3047.2 for 2024 Local Plan located in next 2 slides

Need Number: DOM-2022-0046-DNH & DOM-2022-0047-DNH

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Selected Solution (Part 2 of 2):

To address: Bristers 500-230 kV TX #1 & 2 Violation

- Install (2) 1400 MVA 500-230 kV transformer and associated 500 kV and 230 kV equipment (breakers, switches, leads) at Vint Hill Substation to supply the area with a 500 kV source
- Cut and loop 500 kV line #535 (Loudoun – Meadowbrook) and #569 (Loudoun - Morrisville) as the 500 kV sources into the proposed 500 kV ring bus
- Vint Hill Substation will be expanded to the north of the existing site to accommodate the 500 kV ring required for the addition of the new transformers
- Existing terminations for 230 kV line #2174 (Wheeler – Vint Hill), line #2101 (Bristers – Vint Hill), and line #2163 (Liberty – Vint Hill) will be rearranged to terminate into the expanded Vint Hill Substation
- 230 kV line #2114 (Remington CT – Rollins Ford) will also be cut and looped into the expanded Vint Hill Substation due to spatial constraints along the existing right-of-way

Estimated Cost: \$115.0M (Total)
Transmission Line Cost: \$5.0M
Substation Cost: \$110.0M


Projected In-Service: 12/31/2027

Supplemental Project ID: s3047.2

Project Status: Conceptual

Model: 2027 RTEP

Dominion Transmission Zone M-3 Process Do No Harm (DNH) Analysis



Initially posted to 2024 Local Plan for s3047.2
Updates to s3047.2 for 2024 Local Plan highlighted in red below

Dominion Transmission Zone M-3 Process
 Do No Harm (DNH) Analysis

Need Number: DOM-2022-0046-DNH & DOM-2022-0047-DNH

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/16/2024

Presentation Date:

DNH – 02/07/2023, **04/30/2024**

Supplemental Project Driver:

Do No Harm Analysis

Specific Assumption Reference:


Customer load request will be evaluated per Dominion’s Facility Interconnection Requirements Document and Dominion’s Transmission Planning Criteria.

Problem Statement:

PJM has identified N-1-1 thermal violations on the following separate facilities in the 2022 Do-No-Harm analysis:

- Line #2101 (Nokesville to Bristers Segment)
 - Contingency Scenario: DVP_P1-2: LN 569 and DVP_P1-2: LN 539
- Bristers 500-230 kV TX#1
 - Contingency Scenario: DVP_P1-3: 8BRISTER-TX#1 and DVP_P1-2: LN 539
- Bristers 500-230 kV TX#2
 - Contingency Scenario: DVP_P1-3: 8BRISTER-TX#2 and DVP_P1-2: LN 539

The violations are caused by previously presented Supplemental Projects DOM-2022-0046 and DOM-2022-0047 in the Dominion Zone.



Initially posted to 2024 Local Plan for s3047.2
Updates to s3047.2 for 2024 Local Plan highlighted in red below

Dominion Transmission Zone M-3 Process
 Do No Harm (DNH) Analysis

Need Number: DOM-2022-0046-DNH & DOM-2022-0047-DNH

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/16/2024

Selected Solution (Part 2 of 2):

To address: Bristers 500-230 kV TX #1 & 2 Violation

- Install (2) 1400 MVA 500-230 kV transformer and associated 500 kV and 230 kV equipment (breakers, switches, leads) at Vint Hill Substation to supply the area with a 500 kV source
- Cut and loop 500 kV line #535 (Loudoun – Meadowbrook) ~~and #569 (Loudoun – Morrisville)~~ as the 500 kV sources into the proposed 500 kV ring bus. **Via approval during the 2022 Competitive Open Window #3, new Morrisville – Vint Hill and Vint Hill – Wishing Star 500 kV will be the 2nd 500 kV source**
- Vint Hill Substation will be expanded to the north of the existing site to accommodate the 500 kV ring required for the addition of the new transformers
- Existing terminations for 230 kV line #2174 (Wheeler – Vint Hill), line #2101 (Bristers – Vint Hill), and line #2163 (Liberty – Vint Hill) will be rearranged to terminate into the expanded Vint Hill Substation
- 230 kV line #2114 (Remington CT – Rollins Ford) will also be cut and looped into the expanded Vint Hill Substation due to spatial constraints along the existing right-of-way


Estimated Cost: \$114.0M (Total)
 Transmission Line Cost: \$4.0M
 Substation Cost: \$110.0M

Projected In-Service: 12/31/2027

Supplemental Project ID: s3047.2

Project Status: Conceptual

Model: 2027 RTEP



Dominion Transmission Zone M-3 Process Cemetery Rd 115kV Delivery - DEV

Need Number: DOM-2022-0048

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Previously Presented:

Need – 07/21/2022

Solution – 08/18/2022

Project Driver:

Customer Service

Specific Assumption Reference:

Customer load request will be evaluated per Dominion’s Facility Interconnection Requirements Document and Dominion’s Transmission Planning Criteria.


Problem Statement:

DEV Distribution has submitted a delivery point request for a new delivery point to serve a motor load customer in Chase City, VA. The total load is less than 100 MW. The customer requests service by October 15, 2024.

Projected 2028 Load

Summer: 49.2 MW

Winter: 49.2 MW



Dominion Transmission Zone M-3 Process Cemetery Rd 115kV Delivery - DEV

Need Number: DOM-2022-0048

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Selected Solution:

Tap Line #171 (Chase City – Herbert) near structure 171/51 and extend a single circuit 115kV tap to Cemetery Road sub.


Estimated Cost:	\$5.0 M (Total)
Transmission Line	\$4.0 M
115kV Substation	\$1.0 M

Projected In-Service: 10/15/2024

Supplemental Project ID: s3039

Project Status: Engineering

Model: 2025 RTEP



Dominion Transmission Zone M-3 Process Gretna 69kV Delivery- Add 2nd TX - DEV

Need Number: DOM-2022-0050

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Previously Presented:

Need – 08/18/2022

Solution – 09/15/2022

Project Driver:

Customer Service

Specific Assumption Reference:

Customer load request will be evaluated per Dominion’s Facility Interconnection Requirements Document and Dominion’s Transmission Planning Criteria.


Problem Statement:

DEV Distribution has submitted a DP Request to add a 2nd, 3 - 2.5/3.125 MVA distribution transformer at Gretna Substation in Pittsylvania County, Virginia. The new transformer is needed for voltage island mitigation. Requested in-service date is 12/15/2024.

Projected 2028 Load

Summer: 8.5 MW

Winter: 7.5 MW



Dominion Transmission Zone M-3 Process Gretna 69kV Delivery- Add 2nd TX - DEV

Need Number: DOM-2022-0050

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Selected Solution:

Install a 69kV circuit switcher, high side switch and associated equipment (bus, switches, relaying, etc.) to feed the new transformer at Gretna.

Estimated Cost: \$0.5 M

Projected In-Service: 12/15/2024

Supplemental Project ID: s3046

Project Status: Engineering

Model: 2025 RTEP



Dominion Transmission Zone M-3 Process Replace Clover Substation Breakers and Switches

Need Number: DOM-2022-0051

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Previously Presented:

Need – 09/06/2022

Solution – 11/01/2022

Project Driver:


Equipment Material Condition, Performance and Risk

Specific Assumption Reference:

See details on Equipment Material Condition, Performance and Risk in Dominion’s Planning Assumptions presented in December 2021.

Problem Statement:

Dominion Energy has identified a need to replace five 230kV breakers (L912, 206812, SX1212, SX12T235 & 23512) and six disconnect switches (SX1214, SX1215, SX1218, 23518, 23514, & 23515) at Clover Substation. These breakers and switches were manufactured in 1993 and are at end of life. Additionally, there has been an increase in maintenance issues and difficulties in obtaining spare parts.



Dominion Transmission Zone M-3 Process Replace Clover Substation Breakers and Switches

Need Number: DOM-2022-0051

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Selected Solution:

Replace the following 230kV breakers and switches at Clover Substation -

- Two breakers (L912 and 206812) with 3000 amp 50kA breakers.
- Three breakers (SX1212, SX12T235 & 23512) with 4000 amp 63kA breakers.
- Six disconnect switches (SX1214, SX1215, SX1218, 23518, 23514, & 23515) with 4000 amp switches.


Estimated Cost: \$2.75 M

Projected In-Service: 07/13/2023

Supplemental Project ID: s3050

Project Status: Completed

Model: 2027 RTEP



Dominion Transmission Zone M-3 Process

Replace North Anna Substation Breakers and Switches

Need Number: DOM-2022-0052

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Previously Presented:

Need – 09/06/2022

Solution – 11/01/2022

Project Driver:

Equipment Material Condition, Performance and Risk


Specific Assumption Reference:

See details on Equipment Material Condition, Performance and Risk in Dominion’s Planning Assumptions presented in December 2021.

Problem Statement:

Dominion Energy has identified a need to replace 230kV equipment at North Anna substation:

- Breaker 25502 at end of life, manufactured in 1993
- Center breaker switches H304, H305, 25504 and 25505 at end of life about 20 years old
- Line #255 wave trap at end of life 21 years old
- Transformer #3 circuit high side switcher H302 due to fault interruption requirements



Dominion Transmission Zone M-3 Process

Replace North Anna Substation Breakers and Switches

Need Number: DOM-2022-0052

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Selected Solution:

Replace the following 230kV equipment at North Anna Substation -

- Breaker 25502 with a 3000 amp 63kA breaker.
- Center breaker switches H304, H305, 25504 and 25505 with 3000 amp switches
- Line #255 wave trap with a 3000 amp wave trap
- Transformer #3 circuit high side switcher H302 with a 1200 amp 40kAIC circuit switcher


Estimated Cost: \$2.36 M

Projected In-Service: 07/27/2023

Supplemental Project ID: s3058

Project Status: Completed

Model: 2027 RTEP



Dominion Transmission Zone M-3 Process

Replace Davis TX#2 - DEV

Need Number: DOM-2022-0053

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Previously Presented:

Need – 09/06/2022

Solution – 11/01/2022

Project Driver:

Equipment Material Condition, Performance and Risk

Specific Assumption Reference:

See details on Equipment Material Condition, Performance and Risk in Dominion’s Planning Assumptions presented in December 2021.

Problem Statement:

Davis TX#2 is a 168 MVA, 230/69/13.2 kV transformer bank that was manufactured in 1990. This transformer bank has been identified for replacement based on the results of Dominion’s transformer health assessment (THA) process. Detailed drivers include:

- Age (>30 years old).
- Reduced BIL ratings (2 levels below standard).
- Tertiary winding design not meeting current MVA requirement for loading.
- Degraded porcelain type bushings.

Additionally, a protection scheme update at Davis requires the addition of multiple external bushing CT’s to the low-voltage and high-voltage bushings which will compromise strike distances on the bushings. The ability to add more internal CT’s was not considered when the transformer was ordered in 1989.



Dominion Transmission Zone M-3 Process

Replace Davis TX#2 - DEV

Need Number: DOM-2022-0053

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Selected Solution:

Replace Davis TX#2 with a new three-phase, 230/69/13.2 kV, 168 MVA unit.
Include other ancillary equipment (arresters, switches, relays, etc.) as needed.


Estimated Cost: \$4.5 M

Projected In-Service: 05/31/2024

Supplemental Project ID: s3059

Project Status: Construction

Model: 2027 RTEP



Dominion Transmission Zone M-3 Process

Lunar 230kV Delivery - DEV

Need Number: DOM-2022-0054

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Previously Presented:

Need – 10/04/2022

Solution – 07/11/2023

Project Driver:

Customer Service

Specific Assumption Reference:

Customer load request will be evaluated per Dominion’s Facility Interconnection Requirements Document and Dominion’s Transmission Planning Criteria.


Problem Statement:

DEV has submitted a DP Request for a new substation (Lunar) in Loudoun County with a total load in excess of 100MW. Requested in-service date is 08/01/2026.

Projected 2028 Load

Summer: 188.0 MW

Winter: 140.0 MW



Dominion Transmission Zone M-3 Process Lunar 230kV Delivery - DEV

Need Number: DOM-2022-0054

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Selected Solution:

Interconnect the new substation by constructing two 230kV lines from Sycolin Creek Substation to proposed Lunar Substation. Lines to terminate in a 230kV six-breaker ring arrangement.


Estimated Cost: \$28.0 M

Projected In-Service: 08/01/2026

Supplemental Project ID: s3074

Project Status: Engineering

Model: 2027 RTEP



Dominion Transmission Zone M-3 Process

Apollo 230kV Delivery - DEV

Need Number: DOM-2022-0055

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Previously Presented:

Need – 11/01/2022

Solution – 07/11/2023

Project Driver:

Customer Service

Specific Assumption Reference:

Customer load request will be evaluated per Dominion’s Facility Interconnection Requirements Document and Dominion’s Transmission Planning Criteria.


Problem Statement:

DEV has submitted a DP Request for a new substation (Apollo) in Loudoun County with a total load in excess of 100MW. Requested in-service date is 1/1/2027.

Projected 2028 Load

Summer: 111.0 MW

Winter: 69.0 MW



Dominion Transmission Zone M-3 Process

Apollo 230kV Delivery - DEV

Need Number: DOM-2022-0055

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Selected Solution:

Interconnect the new substation by constructing two 230kV lines from Lunar Substation to proposed Apollo Substation. Lines to terminate in a 230kV six-breaker ring arrangement.


Estimated Cost: \$28.0 M

Projected In-Service: 01/01/2027

Supplemental Project ID: s3075

Project Status: Engineering

Model: 2027 RTEP



Dominion Transmission Zone M-3 Process Pluto 230kV Delivery - DEV

Need Number: DOM-2022-0056

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Previously Presented:

Need – 10/04/2022

Solution – 08/08/2023

Project Driver:

Customer Service

Specific Assumption Reference:

Customer load request will be evaluated per Dominion’s Facility Interconnection Requirements Document and Dominion’s Transmission Planning Criteria.


Problem Statement:

DEV has submitted a DP Request for a new substation (Pluto) in Loudoun County with a total load in excess of 100MW. Requested in-service date is 06/1/2026.

Projected 2028 Load

Summer: 110.0 MW

Winter: 72.0 MW



Dominion Transmission Zone M-3 Process Pluto 230kV Delivery - DEV

Need Number: DOM-2022-0056

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Selected Solution:

Interconnect the new substation by cutting and extending Line #2180 (Pleasant View – Belmont) to the proposed Pluto Substation. Lines to terminate in a 230kV four-breaker ring arrangement.


Estimated Cost: \$20.0 M

Projected In-Service: 06/01/2026

Supplemental Project ID: s3080

Project Status: Engineering

Model: 2027 RTEP



Dominion Transmission Zone M-3 Process Evergreen Mills Series Reactor

Need Number: DOM-2022-0057

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Previously Presented:

Need – 11/01/2022

Solution – 02/07/2023

Project Driver:

Operational Flexibility and Efficiency


Specific Assumption Reference:

See details on Operational Flexibility and Efficiency in Dominion’s Planning Assumptions presented in December 2021.

Problem Statement:

Near-term planning studies and Dominion Energy Operations Engineering studies have identified overloads on 230 kV Line #2172 (Brambleton – Evergreen Mills) for the loss of Line #2183 (Brambleton – Poland Road).

The Dominion Energy Operations team needs a temporary solution to avoid this overload on Line #2172 and accordingly provide flexibility for future construction outages.




Dominion Transmission Zone M-3 Process Evergreen Mills Series Reactor

Need Number: DOM-2022-0057

Process Stage:
Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Selected Solution:
Install approximately 2.2 Ω series reactor at Evergreen Mills station on terminal of Line #2172.

Estimated Cost: \$3.0 M
Projected In-Service: 06/14/2023
Supplemental Project ID: s3051
Project Status: Complete
Model: 2027 RTEP



Dominion Transmission Zone M-3 Process Pearsons Switch Replacement

Need Number: DOM-2022-0060


Process Stage:
Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Previously Presented:
Need – 12/06/2022
Solution – 02/07/2023

Project Driver:
Equipment Material Condition, Performance and Risk

Specific Assumption Reference:
See details on Equipment Material Condition, Performance and Risk in Dominion’s Planning Assumptions presented in December 2021.

Problem Statement:
Dominion Energy has identified a need to replace two 230kV switches at Pearsons substation (207576 & 207579). These switches have become inoperable and can only be operated de-energized.



Dominion Transmission Zone M-3 Process Pearsons Switch Replacement

Need Number: DOM-2022-0060

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Selected Solution:

Replace the following 230kV switches 207576 and 207579 at Pearsons substation with 3000A switches on the existing backbone. The Pearsons to Elmont segment of Line #2075 Normal, Emergency and Load Dump ratings will increase as follows:

- Summer – From (876, 956, 1163) to (1047, 1047, 1204) MVA
- Winter – From (1068, 1123, 1334) to (1160, 1160, 1334) MVA

Estimated Cost: \$0.5 M

Projected In-Service: 10/31/2023

Supplemental Project ID: s3060

Project Status: Complete

Model: 2027 RTEP



Dominion Transmission Zone M-3 Process

Replace 115kV Ground Switches with Circuit Switchers -DEV

Need Number: DOM-2022-0061

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Previously Presented:

Need – 12/14/2022

Solution – 03/16/2023

Project Driver:

Operational Flexibility and Efficiency

Specific Assumption Reference:


See details on Operational Flexibility and Efficiency in Dominion’s Planning Assumptions presented in December 2021.

Problem Statement:

Dominion has identified 7 5 substations that have legacy protection schemes on the 115kV high side of distribution transformers. These protection schemes utilize a ground switch and a motor operated switch on the high side of each transformer. For a fault in the transformer protection zone:

- The ground switch closes resulting in a bolted fault on the 115kV line
- This causes the transmission line breakers to open at the substation terminal ends
- The transformer motor operated high side switch opens isolating the transformer from the 115kV line and the terminal end breakers reclose to re-energize the 115kV line

These schemes are no longer standard protection due to the stress on the transmission equipment from the fault applied by the ground switch and the operation of the 115kV line interrupting service to all customers served by the line.



Substation	Tx #
Quantico	1 & 2
Princess Anne	1
Deep Creek	1 & 2
Creswell	2
Alexander Corner	1
Tunis	2
Brown Boveri	1

Dominion Transmission Zone M-3 Process Replace 115kV Ground Switches with Circuit Switchers -DEV

Need Number: DOM-2022-0061

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Selected Solution:

Remove the ground switches and install circuit switchers at 5 substations –

- Quantico Tx# 1 & 2
- Deep Creek Tx# 1 & 2
- Alexander Corner Tx# 1
- Tunis Tx# 2
- Brown Boveri Tx# 1


Estimated Cost: \$2.5 M

Projected In-Service: 04/30/2024

Supplemental Project ID: s3052

Project Status: Construction

Model: 2027 RTEP



Dominion Transmission Zone M-3 Process

Starlight 230kV Delivery - DEV

Need Number: DOM-2023-0001

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Previously Presented:

Need – 01/10/2023

Solution – 07/11/2023

Project Driver:

Customer Service

Specific Assumption Reference:

Customer load request will be evaluated per Dominion’s Facility Interconnection Requirements Document and Dominion’s Transmission Planning Criteria.


Problem Statement:

DEV has submitted a DP Request for a new substation (Starlight) in Loudoun County with a total load in excess of 100MW. Requested in-service date is 06/01/2028.

Projected 2028 Load

Summer: 10.0 MW

Winter: 0.0 MW




Dominion Transmission Zone M-3 Process Starlight 230kV Delivery - DEV

Need Number: DOM-2023-0001

Process Stage:
Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Selected Solution:
Interconnect the new substation by cutting two 230kV lines from Sycolin Creek Substation to Lunar Substation into proposed Starlight Substation. Lines to terminate in a 230kV six-breaker ring arrangement.

Estimated Cost: \$28.0 M
Projected In-Service: 06/01/2028
Supplemental Project ID: s3076
Project Status: Engineering
Model: 2027 RTEP



Dominion Transmission Zone M-3 Process Roundtable - Add 3rd and 4th TX - DEV

Need Number: DOM-2023-0005

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Previously Presented:

Need – 02/07/2023

Solution – 07/11/2023

Project Driver:

Customer Service

Specific Assumption Reference:

Customer load request will be evaluated per Dominion’s Facility Interconnection Requirements Document and Dominion’s Transmission Planning Criteria.


Problem Statement:

DEV Distribution has submitted a DP Request to add the 3rd and 4th distribution transformers at Roundtable Substation in Loudoun County. The new transformers are being driven by continued load growth in the area and contingency loading for loss of one of the existing transformers. Requested in-service date is 12/15/2024.

Projected 2028 Load

Summer: 141.0 MW

Winter: 138.0 MW



Dominion Transmission Zone M-3 Process Roundtable - Add 3rd and 4th TX - DEV

Need Number: DOM-2023-0005

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Selected Solution:

Install (2) 1200 Amp, 50kAIC circuit switchers and associated equipment (bus, relaying, etc.) to feed the new transformers at Roundtable.


Estimated Cost: \$1.0 M

Projected In-Service: 12/15/2024

Supplemental Project ID: s3053

Project Status: Engineering

Model: 2027 RTEP



Dominion Transmission Zone M-3 Process

Bear Run 230kV Delivery - DEV

Need Number: DOM-2023-0007

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Previously Presented:

Need – 03/07/2023

Solution – 04/11/2023

Project Driver:

Customer Service

Specific Assumption Reference:

Customer load request will be evaluated per Dominion’s Facility Interconnection Requirements Document and Dominion’s Transmission Planning Criteria.


Problem Statement:

NOVEC has submitted a Delivery Point (DP) Request stating that it is expanding Cub Run Substation in Fairfax County and the total load will exceed 100MW. Requested in-service date is 3/15/2024.

Projected 2028 Load

Summer: 90.0 MW

Winter: 90.0 MW



Dominion Transmission Zone M-3 Process

Bear Run 230kV Delivery - DEV

Need Number: DOM-2023-0007

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Selected Solution:

Interconnect the new substation by cutting and extending Line #265 (Bull Run - Sully) to the proposed Bear Run Substation. Lines to terminate in a 230kV four-breaker ring arrangement with an ultimate arrangement of a six-breaker ring.


Estimated Cost: \$24.5 M

Projected In-Service: 03/15/2024

Supplemental Project ID: s3062

Project Status: Engineering

Model: 2027 RTEP



Dominion Transmission Zone M-3 Process

Foster Drive 230kV Delivery - CoM

Need Number: DOM-2023-0008

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Previously Presented:

Need – 03/07/2023

Solution – 05/09/2023

Project Driver:

Customer Service

Specific Assumption Reference:

Customer load request will be evaluated per Dominion’s Facility Interconnection Requirements Document and Dominion’s Transmission Planning Criteria.

Problem Statement:


The City of Manassas has submitted a DP Request for a new substation (Foster Drive) to serve a data center complex in Manassas with a total load in excess of 100 MW.

Requested in-service date is 03/31/2025.

Projected 2028 Load

Summer: 260.0 MW

Winter: 260.0 MW



Dominion Transmission Zone M-3 Process Foster Drive 230kV Delivery - CoM

Need Number: DOM-2023-0008

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Selected Solution:

Interconnect the new substation by cutting and extending Line #2243 (Sandlot – Cannon Branch) to the proposed Foster Drive Substation. Lines to terminate into a 230 kV four-breaker ring arrangement with an ultimate arrangement of a six-breaker ring.

Estimated Cost: \$15.3 M (Total)

Transmission: \$0.3 M


Substation: \$15.0 M

Projected In-Service: 03/31/2025

Supplemental Project ID: s3064

Project Status: Engineering

Model: 2027 RTEP



Dominion Transmission Zone M-3 Process

Daves Store 230kV Delivery - DEV

Need Number: DOM-2023-0009

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Previously Presented:

Need – 03/07/2023

Solution – 06/06/2023

Project Driver:

Customer Service

Specific Assumption Reference:

Customer load request will be evaluated per Dominion’s Facility Interconnection Requirements Document and Dominion’s Transmission Planning Criteria.


Problem Statement:

DEV Distribution has submitted a DP Request for a new substation (Daves Store) to serve a data center complex in Gainesville with a total load in excess of 100 MW. Requested in-service date is 06/01/2025.

Projected 2028 Load

Summer: 264.0 MW

Winter: 228.0 MW



Dominion Transmission Zone M-3 Process

Daves Store 230kV Delivery - DEV

Need Number: DOM-2023-0009

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Selected Solution:

Interconnect the new substation by extending approximately 300’ of 230 kV GIL from the existing Heathcote substation to the proposed Daves Store Substation. Lines to terminate into a GIS 230 kV four-breaker arrangement expandable to an ultimate of eight 230 kV GIS breakers in a breaker-and-a-half scheme.


Estimated Cost: \$40.0 M

Projected In-Service: 06/01/2025

Supplemental Project ID: s3068.1

Project Status: Engineering

Model: 2027 RTEP



Dominion Transmission Zone M-3 Process Do No Harm (DNH) Analysis

Need Number: DOM-2023-0009-DNH

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Presentation Date:

DNH – 06/06/2023

Supplemental Project Driver:

Do No Harm Analysis

Specific Assumption Reference:


Customer load request will be evaluated per Dominion’s Facility Interconnection Requirements Document and Dominion’s Transmission Planning Criteria.

Problem Statement:

PJM has identified a 300 MW load drop violation due to the loss of the following separate facilities in the 2023 Do-No-Harm analysis:

- Daves Store + Youngs Branch + Catharpin DP
 - N-1-1 Contingency Scenario: DVP_P1-2: LN 2140 and DVP_P1-2: LN 2176

The violations are caused by previously presented Supplemental Project DOM-2023-0009 in the Dominion Zone.



Dominion Transmission Zone M-3 Process Do No Harm (DNH) Analysis

Need Number: DOM-2023-0009-DNH

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Selected Solution:

Rebuild approx. 7.9 miles of double-circuit Line from Ox to Braddock and partial Line#2097 (Ox-Idylwood) to current 230kV standards. The normal summer rating of the line conductor will be 1573 MVA.


Estimated Cost:	\$33.5M (Total)
Transmission Line	\$13.5M
Real Estate	\$18.5M
Substation	\$ 1.5M

Projected In-Service: 12/31/2026

Supplemental Project ID: s3068.2

Project Status: Conceptual

Model: 2027 RTEP



Dominion Transmission Zone M-3 Process

Gemini 230kV Delivery - DEV

Need Number: DOM-2023-0010

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Previously Presented:

Need – 03/07/2023

Solution – 06/06/2023

Project Driver:

Customer Service

Specific Assumption Reference:

Customer load request will be evaluated per Dominion’s Facility Interconnection Requirements Document and Dominion’s Transmission Planning Criteria.


Problem Statement:

DEV Distribution has submitted a DP Request for a new substation (Gemini) to serve a data center complex in Gainesville with a total load in excess of 100 MW. Requested in-service date is 08/01/2026.

Projected 2028 Load

Summer: 258.0 MW

Winter: 210.0 MW



Dominion Transmission Zone M-3 Process Gemini 230kV Delivery - DEV

Need Number: DOM-2023-0010

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Selected Solution:

Interconnect the new substation by extending approx. 600’ of (2) new 230 kV lines from Daves Store to the proposed Gemini Substation. Lines to terminate into a 230 kV four-breaker arrangement with an ultimate of six.

Estimated Cost: \$15.3 M (Total)

Transmission: \$0.30 M


Substation: \$15.0 M

Projected In-Service: 08/01/2026

Supplemental Project ID: s3069

Project Status: Engineering

Model: 2027 RTEP



Dominion Transmission Zone M-3 Process Atlas 230kV Delivery - DEV

Need Number: DOM-2023-0011

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Previously Presented:

Need – 03/07/2023

Solution – 06/06/2023

Project Driver:

Customer Service

Specific Assumption Reference:

Customer load request will be evaluated per Dominion’s Facility Interconnection Requirements Document and Dominion’s Transmission Planning Criteria.

Problem Statement:


DEV Distribution has submitted a DP Request for a new substation (Atlas) to serve a data center complex in Gainesville with a total load in excess of 100 MW.

Requested in-service date is 04/01/2028.

Projected 2028 Load

Summer: 70.0 MW

Winter: 0.0 MW



Dominion Transmission Zone M-3 Process Atlas 230kV Delivery - DEV

Need Number: DOM-2023-0011

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Selected Solution:

Interconnect the new substation by extending approx. 450’ of (1) new 230 kV line from Gemini to the proposed Atlas Substation. Re-terminate (1) of the 230 kV segments from Daves Store to Trident (DOM-2023-0009-DNH) into Atlas, extending the segment by approx. 1200’. The 230 kV lines will terminate into a 230 kV four-breaker arrangement expandable to an ultimate of six.

Estimated Cost: \$15.4 M (Total)

Transmission: \$0.40 M


Substation: \$15.0 M

Projected In-Service: 04/01/2028

Supplemental Project ID: s3070

Project Status: Engineering

Model: 2027 RTEP



Dominion Transmission Zone M-3 Process Trident 230kV Delivery - NOVEC

Need Number: DOM-2023-0012

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Previously Presented:

Need – 03/07/2023

Solution – 06/06/2023

Project Driver:

Customer Service

Specific Assumption Reference:

Customer load request will be evaluated per Dominion’s Facility Interconnection Requirements Document and Dominion’s Transmission Planning Criteria.


Problem Statement:

NOVEC has submitted a DP Request for a new substation (Trident) to serve a data center complex in Bristow with a total load in excess of 100 MW. Requested in-service date is 09/01/2025.

Projected 2028 Load

Summer: 153.3 MW

Winter: 125.3 MW



Dominion Transmission Zone M-3 Process Trident 230kV Delivery - NOVEC

Need Number: DOM-2023-0012

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Selected Solution:

Interconnect the new substation by cutting and extending Line #2161 (Gainesville – Wheeler) to the proposed Trident Substation. Lines to terminate into a 230 kV six-breaker ring arrangement.

Estimated Cost: \$15.75 M (Total)

Transmission: \$0.75 M


Substation: \$15.0 M

Projected In-Service: 09/01/2025

Supplemental Project ID: s3071

Project Status: Engineering

Model: 2027 RTEP



Dominion Transmission Zone M-3 Process Youngs Branch - Add 3rd, 4th, and 5th TX - DEV

Need Number: DOM-2023-0014

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Previously Presented:

Need – 03/07/2023

Solution – 05/09/2023

Project Driver:

Customer Service

Specific Assumption Reference:

Customer load request will be evaluated per Dominion’s Facility Interconnection Requirements Document and Dominion’s Transmission Planning Criteria.

Problem Statement:


DEV Distribution has submitted a DP Request to add a 3rd, 4th, and 5th distribution transformer at Youngs Branch Substation in Gainesville. The new transformers are being driven by significant area load growth.

Requested in-service date is 07/01/2024.

Projected 2028 Load

Summer: 270.0 MW

Winter: 270.0 MW



Dominion Transmission Zone M-3 Process Youngs Branch - Add 3rd, 4th, and 5th TX - DEV

Need Number: DOM-2023-0014

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Selected Solution:

Install (3) 1200 Amp, 50kAIC circuit switchers and associated equipment (bus, relaying, etc.) to feed the new transformers at Youngs Branch.


Estimated Cost: \$3.0 M

Projected In-Service: 07/01/2024

Supplemental Project ID: s3065

Project Status: Engineering

Model: 2027 RTEP



Dominion Transmission Zone M-3 Process

Firetower Rd 230kV Delivery - DEV

Need Number: DOM-2023-0015

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Previously Presented:

Need – 03/07/2023

Solution – 04/11/2023

Project Driver:

Customer Service

Specific Assumption Reference:

Customer load request will be evaluated per Dominion’s Facility Interconnection Requirements Document and Dominion’s Transmission Planning Criteria.


Problem Statement:

NCEMC has submitted a delivery point request for a new substation (Firetower Rd) to serve a gas compression facility in Ahoskie, NC. The total load is less than 100 MW. The customer requests service by December 31, 2023.

Projected 2028 Load

Summer: 8.1 MW

Winter: 8.1 MW



Dominion Transmission Zone M-3 Process Firetower Rd 230kV Delivery - DEV

Need Number: DOM-2023-0015

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Selected Solution:

Tap Line #246 (Earleys – Suffolk) near structure 246/290 and extend a single circuit 230kV line to Firetower Road sub.

Estimated Cost: \$5.0 M (Total)

Transmission: \$4.0 M


Substation: \$1.0 M

Projected In-Service: 02/29/2024

Supplemental Project ID: s3063

Project Status: Construction

Model: 2027 RTEP



Dominion Transmission Zone M-3 Process

Southall 230kV Delivery - REC

Need Number: DOM-2023-0017

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Previously Presented:

Need – 03/07/2023

Solution – 06/06/2023

Project Driver:

Customer Service

Specific Assumption Reference:

Customer load request will be evaluated per Dominion’s Facility Interconnection Requirements Document and Dominion’s Transmission Planning Criteria.


Problem Statement:

Rappahannock Electric Cooperative (REC) has submitted a DP Request for a new substation (Southall) to serve a data center in Louisa County with a total load in excess of 100 MW. The requested in-service date is 05/01/2025.

Projected 2028 Load

Summer: 220.0 MW

Winter: 193.0 MW



Dominion Transmission Zone M-3 Process

Southall 230kV Delivery - REC

Need Number: DOM-2023-0017

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Selected Solution:

Interconnect the new substation by cutting and extending Line #255 (North Anna - Desper) to the proposed Southall Substation. Lines to terminate in a 230kV four-breaker ring arrangement with an ultimate arrangement of a six-breaker ring.


Estimated Cost: \$55.0 M

Projected In-Service: 05/01/2025

Supplemental Project ID: s3072

Project Status: Engineering

Model: 2027 RTEP



Dominion Transmission Zone M-3 Process Spartan 230kV Delivery Point - DEV

Need Number: DOM-2023-0018

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Previously Presented:

Need – 04/11/2023

Solution – 05/09/2023

Project Driver:

Customer Service

Specific Assumption Reference:

Customer load request will be evaluated per Dominion’s Facility Interconnection Requirements Document and Dominion’s Transmission Planning Criteria.


Problem Statement:

DEV Distribution has submitted a DP Request for a new substation (Spartan) to serve a new data center in Stafford County with a total load in excess of 100 MW. The requested in-service date is 05/02/2025.

Projected 2028 Load

Summer: 110.0 MW

Winter: 105.0 MW



Dominion Transmission Zone M-3 Process Spartan 230kV Delivery Point - DEV

Need Number: DOM-2023-0018

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Selected Solution:

Interconnect the new substation by cutting and extending Line #2104 to the proposed Spartan Substation. Lines to terminate in a 230kV four-breaker ring arrangement with an ultimate arrangement of a six-breaker ring.

Estimated Cost: \$48.0 M (Total)

Transmission: \$12.0 M


Substation: \$36.0 M

Projected In-Service: 05/02/2025

Supplemental Project ID: s3066

Project Status: Engineering

Model: 2027 RTEP



Dominion Transmission Zone M-3 Process

Buttermilk - Add 3rd and 4th TX - DEV

Need Number: DOM-2023-0019

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Previously Presented:

Need – 03/07/2023

Solution – 07/11/2023

Project Driver:

Customer Service

Specific Assumption Reference:

Customer load request will be evaluated per Dominion’s Facility Interconnection Requirements Document and Dominion’s Transmission Planning Criteria.


Problem Statement:

DEV Distribution has submitted a DP Request to add the 3rd and 4th distribution transformers at Buttermilk Substation in Loudoun County. The new transformer is being driven by continued load growth in the area. Requested in-service date is 12/15/2024.

Projected 2028 Load

Summer: 147.0 MW

Winter: 146.0 MW



Dominion Transmission Zone M-3 Process Buttermilk - Add 3rd and 4th TX - DEV

Need Number: DOM-2023-0019

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Selected Solution:

Install (2) 1200 Amp, 50kAIC circuit switchers and associated equipment (bus, relaying, etc.) to feed the new transformers at Buttermilk.


Estimated Cost: \$1.0 M

Projected In-Service: 12/15/2024

Supplemental Project ID: s3077

Project Status: Engineering

Model: 2027 RTEP



Dominion Transmission Zone M-3 Process

Broderick Drive 230kV Delivery - DEV

Need Number: DOM-2023-0020

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Previously Presented:

Need – 03/07/2023

Solution – 08/08/2023

Project Driver:

Customer Service

Specific Assumption Reference:

Customer load request will be evaluated per Dominion’s Facility Interconnection Requirements Document and Dominion’s Transmission Planning Criteria.


Problem Statement:

DEV Distribution has submitted a DP Request for a new substation (Broderick Drive) to serve a data center campus in Loudoun County with a total load in excess of 100 MW. Requested in-service date is 03/01/2026.

Projected 2028 Load

Summer: 112.0 MW

Winter: 72.0 MW



Dominion Transmission Zone M-3 Process Broderick Drive 230kV Delivery - DEV

Need Number: DOM-2023-0020

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Selected Solution:

Interconnect the new substation by cutting and extending Line #2170 (Buttermilk- Pacific) to the proposed Broderick Drive Substation. Lines to terminate in a 230kV four-breaker ring arrangement.


Estimated Cost: \$24.5 M

Projected In-Service: 03/01/2026

Supplemental Project ID: s3079

Project Status: Engineering

Model: 2027 RTEP



Dominion Transmission Zone M-3 Process

Otterdam 230kV Delivery - MEC

Need Number: DOM-2023-0027

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Previously Presented:

Need – 04/11/2023

Solution – 05/09/2023

Project Driver:

Customer Service

Specific Assumption Reference:

Customer load request will be evaluated per Dominion’s Facility Interconnection Requirements Document and Dominion’s Transmission Planning Criteria.


Problem Statement:

ODEC on behalf of Mecklenburg Electric Cooperative (MEC) has submitted a delivery point request for a new delivery point at the MAMaC site in Greensville County, VA. MEC is requesting to construct a transmission line under the economic development legislative pilot program for business parks. The total load is in excess of 100 MW. The customer requests service by December 31, 2026.

Projected 2028 Load

Summer: 80.0 MW

Winter: 80.0 MW



Dominion Transmission Zone M-3 Process Otterdam 230kV Delivery - MEC

Need Number: DOM-2023-0027

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Selected Solution:

- Split Line #238 (Clubhouse - Carson) near structure 238/11 and extend double circuit 230kV lines for approx. 3 miles to the proposed Otterdam Substation.
- Terminate the two 230kV lines into 4 breaker ring bus to create a Clubhouse - Otterdam line and a Carson - Otterdam line.

Estimated Cost: \$25.0 M (Total)

Transmission: \$13.0 M


Substation: \$12.0 M

Projected In-Service: 12/31/2026

Supplemental Project ID: s3067

Project Status: Engineering

Model: 2027 RTEP



Dominion Transmission Zone M-3 Process Upgrade Verona TX#1 - DEV

Need Number: DOM-2023-0028

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Previously Presented:

Need – 04/20/2023

Solution – 07/20/2023

Project Driver:

Customer Service

Specific Assumption Reference:

Customer load request will be evaluated per Dominion’s Facility Interconnection Requirements Document and Dominion’s Transmission Planning Criteria.


Problem Statement:

Dominion Distribution has submitted a delivery point request to upgrade TX #1 at Verona substation in Augusta County, Virginia. The upgrade is being driven by increasing customer load. Requested in-service date is 06/30/2024.

Projected 2028 Load

Summer: 36.2 MW

Winter: 36.2 MW



Dominion Transmission Zone M-3 Process Upgrade Verona TX#1 - DEV

Need Number: DOM-2023-0028

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Selected Solution:

Replace the fuse H111 on high-side of Verona transformer #1 with a 1200A, 25kA circuit switcher and upgrade H114 with a motor operated switch.

Estimated Cost: \$0.35 M

Projected In-Service: 06/30/2024

Supplemental Project ID: s3055

Project Status: Engineering

Model: 2027 RTEP



Dominion Transmission Zone M-3 Process

Weyers Cave – Install 2nd TX - DEV

Need Number: DOM-2023-0030

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Previously Presented:

Need – 04/20/2023

Solution – 07/20/2023

Project Driver:

Customer Service

Specific Assumption Reference:

Customer load request will be evaluated per Dominion’s Facility Interconnection Requirements Document and Dominion’s Transmission Planning Criteria.


Problem Statement:

Dominion Distribution has submitted a delivery point request to install a 2nd transformer at Weyers Cave Substation in Augusta County, Virginia. The upgrade is being driven by increasing customer load. Requested in-service date is 12/31/2024.

Projected 2028 Load

Summer: 29.2 MW

Winter: 29.2 MW



Dominion Transmission Zone M-3 Process

Weyers Cave – Install 2nd TX - DEV

Need Number: DOM-2023-0030

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Selected Solution:

Install a 1200A, 25kA circuit switcher, high side switch, bus work and associated equipment on the 115kV high-side of the new transformer.


Estimated Cost: \$0.85 M

Projected In-Service: 12/31/2024

Supplemental Project ID: s3078

Project Status: Engineering

Model: 2027 RTEP



Dominion Transmission Zone M-3 Process Cumulus 230kV Delivery- Add 5th TX - DEV

Need Number: DOM-2023-0032

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Previously Presented:

Need – 06/06/2023

Solution – 07/11/2023

Project Driver:

Customer Service

Specific Assumption Reference:

Customer load request will be evaluated per Dominion’s Facility Interconnection Requirements Document and Dominion’s Transmission Planning Criteria.


Problem Statement:

DEV Distribution has submitted a DP Request to add a 5th distribution transformer at Cumulus Substation in Loudoun County. The new 84 MVA transformer is being driven by continued load growth in the area and contingency loading for loss of one of the existing transformers. Requested in-service date is 06/01/2025.

Projected 2028 Load

Summer: 268.2 MW

Winter: 260.3 MW



Dominion Transmission Zone M-3 Process Cumulus 230kV Delivery- Add 5th TX - DEV

Need Number: DOM-2023-0032

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Selected Solution:

Install a 1200 Amp, 50kAIC circuit switcher and associated equipment (bus, switches, relaying, etc.) to feed the new transformer at Cumulus.


Estimated Cost: \$0.5 M

Projected In-Service: 06/01/2025

Supplemental Project ID: s3054

Project Status: Engineering

Model: 2027 RTEP



Dominion Transmission Zone M-3 Process Metcalf 115kV Delivery – TX Upgrade - DEV

Need Number: DOM-2023-0036

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Previously Presented:

Need – 07/20/2023

Solution – 08/17/2023

Project Driver:

Customer Service

Specific Assumption Reference:

Customer load request will be evaluated per Dominion’s Facility Interconnection Requirements Document and Dominion’s Transmission Planning Criteria.


Problem Statement:

DEV Distribution has submitted a delivery point (DP) request to upgrade TX #1 at Metcalf Substation in Greensville County, VA. The new transformer is needed because the existing one is 52 years old and has a low THA rating. Requested in-service date is 12/31/2024.

Projected 2028 Load

Summer: 8.0 MW

Winter: 10.3 MW



Dominion Transmission Zone M-3 Process Metcalf 115kV Delivery – TX Upgrade - DEV

Need Number: DOM-2023-0036

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Selected Solution:

Replace the fuse on the high side with a 1200A, 25kAIC circuit switcher, install any high side equipment to accommodate the installation of the new transformer.


Estimated Cost: \$0.62 M

Projected In-Service: 12/31/2024

Supplemental Project ID: s3057

Project Status: Engineering

Model: 2027 RTEP



Dominion Transmission Zone M-3 Process Bishop Sub – 115kV Delivery – MEC

Need Number: DOM-2023-0041

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Previously Presented:

Need – 07/20/2023

Solution – 08/17/2023

Project Driver:

Customer Service

Specific Assumption Reference:

Customer load request will be evaluated per Dominion’s Facility Interconnection Requirements Document and Dominion’s Transmission Planning Criteria.


Problem Statement:

ODEC on behalf of Mecklenburg Electric Coop (MEC) has submitted a delivery point (DP) request to serve a Data Center load at Mecklenburg County, VA. Final load is 48 MW, and the requested service date is 01/01/2025.

Projected 2028 Load

Summer: 48.0 MW

Winter: 48.0 MW



Dominion Transmission Zone M-3 Process

Bishop Sub – 115kV Delivery – MEC

Need Number: DOM-2023-0041

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 02/21/2024

Selected Solution:

Construct a new substation by cutting and extending Line #137 (Kerr Dam – Ridge Road) to the proposed Bishop 115kV Substation. The final build-out includes 6-breaker ring bus and two 115 kV feeds to the customer. Customer will be responsible for paying for any excess transmission or substation equipment above a tap-line.


Estimated Cost:	\$15.0 M (Total)
Transmission Line	\$2.5M
115kV Substation	\$12.5M

Projected In-Service: 01/01/2025

Supplemental Project ID: s3081

Project Status: Engineering

Model: 2027 RTEP



Dominion Transmission Zone M-3 Process Magruder Substation – Upgrade TX#1

Need Number: DOM-2023-0037

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 03/25/2024

Previously Presented:

Need – 06/15/2023

Solution – 11/16/2023

Project Driver:

Customer Service

Specific Assumption Reference:

Customer load request will be evaluated per Dominion’s Facility Interconnection Requirements Document and Dominion’s Transmission Planning Criteria.


Problem Statement:

DEV has submitted a delivery point request to upgrade transformer #1 existing Magruder Substation in Hampton, VA. The upgrade is being driven by new customer load. The total load is under 100 MW. The customer requests service by December 31, 2024.

Projected 2028 Load

Summer: 64.1 MW

Winter: 58.6 MW



Dominion Transmission Zone M-3 Process Magruder Substation – Upgrade TX#1

Need Number: DOM-2023-0037

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 03/25/2024

Selected Solution:

Install a 115kV circuit switcher, high side switch and any associated transmission equipment and bus work needed to facilitate the transformer installation.

Estimated Cost: \$0.764 M

Projected In-Service: 12/31/2024

Supplemental Project ID: s3220.1

Project Status: Conceptual

Model: 2027 RTEP



Dominion Transmission Zone M-3 Process Northwoods 230kV Delivery - NOVEC

Need Number: DOM-2023-0039

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 03/25/2024

Previously Presented:

Need – 07/11/2023

Solution – 09/05/2023

Project Driver:

Customer Service

Specific Assumption Reference:

Customer load request will be evaluated per Dominion’s Facility Interconnection Requirements Document and Dominion’s Transmission Planning Criteria.


Problem Statement:

NOVEC has submitted a DP Request for a new substation (Northwoods) in Loudoun County with a total load in excess of 100MW. Requested in-service date is 04/01/2026.

Projected 2028 Load

Summer: 185.0 MW

Winter: 200.0 MW



Dominion Transmission Zone M-3 Process Northwoods 230kV Delivery - NOVEC

Need Number: DOM-2023-0039

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 03/25/2024

Selected Solution:

Interconnect the new substation by cutting and extending Line #2218 (Sojourner – Shellhorn) to the proposed Northwoods Substation. Lines to terminate in a 230kV four-breaker ring arrangement with an ultimate arrangement of a six-breaker ring.


Estimated Cost: \$20.0 M

Projected In-Service: 04/01/2026

Supplemental Project ID: s3218.1

Project Status: Engineering

Model: 2027 RTEP



Dominion Transmission Zone M-3 Process

230kV Line 246 – EOL Rebuild

Need Number: DOM-2023-0044

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 03/25/2024

Previously Presented:

Need – 12/05/2023

Solution – 08/08/2023

Project Driver:

Equipment Material Condition, Performance Risk


Specific Assumption Reference:

See details on Equipment Material Condition, Performance and Risk in Dominion’s Planning Assumptions presented in December 2022.

Problem Statement:

Dominion Energy has identified a need to replace approximately 44.3 miles of 230kV Line #246 (Suffolk to Earleys) to new 230kV standards based on the Company’s End of Life criteria.

- Line #246 was constructed on primarily wood H-frame structures in 1971, with many in need of replacement due to deterioration.
- Industry guidelines indicate equipment life for steel structures is 40-60 years, wood structures is 35-55 years, conductor and connectors are 40-60 years, and porcelain insulators are 50 years.
- Line #246 provides service to Nucor substation with approximately 36.7MW of load.



Dominion Transmission Zone M-3 Process

230kV Line 246 – EOL Rebuild

Need Number: DOM-2023-0044

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 03/25/2024

Selected Solution:

Rebuild approximately 44.3 miles of Line 246 between Earleys and Suffolk to current 230kV standards. The normal rating of the line conductor will be 1573 MVA.


Estimated Cost: \$150.0 M

Projected In-Service: 12/31/2028

Supplemental Project ID: s3222.1

Project Status: Conceptual

Model: 2027 RTEP



Dominion Transmission Zone M-3 Process Wishing Star DP 230kV Delivery- NOVEC

Need Number: DOM-2023-0045

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 03/25/2024

Previously Presented:

Need – 08/08/2023

Solution – 09/05/2023

Project Driver:

Customer Service

Specific Assumption Reference:

Customer load request will be evaluated per Dominion’s Facility Interconnection Requirements Document and Dominion’s Transmission Planning Criteria.


Problem Statement:

NOVEC has submitted a DP Request for a new substation (Wishing Star DP) in Loudoun County with a total load in excess of 100MW. Requested in-service date is 12/01/2026.

Projected 2028 Load

Summer: 57.0 MW

Winter: 30.0 MW



Dominion Transmission Zone M-3 Process Wishing Star DP 230kV Delivery- NOVEC

Need Number: DOM-2023-0045

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 03/25/2024

Selected Solution:

Provide two 230kV feeds from Dominion’s proposed Wishing Star 500/230kV Sub to NOVEC’s Wishing Star DP.

Estimated Cost: \$1.5 M

Projected In-Service: 12/01/2026

Supplemental Project ID: s3219.1

Project Status: Engineering

Model: 2027 RTEP



Dominion Transmission Zone M-3 Process Princess Anne Substation – Upgrade TX#1

Need Number: DOM-2023-0047

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 03/25/2024

Previously Presented:

Need – 08/17/2023

Solution – 11/16/2023

Project Driver:

Customer Service

Specific Assumption Reference:

Customer load request will be evaluated per Dominion’s Facility Interconnection Requirements Document and Dominion’s Transmission Planning Criteria.


Problem Statement:

DEV has submitted a delivery point request to upgrade transformer 1 at Princess Anne Substation in Virginia Beach, VA. The upgrade is being driven by new customer load. The total load is under 100 MW. The customer requests service by December 30, 2024.

Projected 2028 Load

Summer: 31.8 MW

Winter: 23.7 MW



Dominion Transmission Zone M-3 Process Princess Anne Substation – Upgrade TX#1

Need Number: DOM-2023-0047

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 03/25/2024

Selected Solution:

Install a 115kV circuit switcher, high side switch, wave trap and any associated transmission equipment and bus work needed for transformer upgrade.

Estimated Cost: \$0.5 M

Projected In-Service: 12/30/2024

Supplemental Project ID: s3221.1

Project Status: Conceptual

Model: 2027 RTEP



Dominion Transmission Zone M-3 Process Bermuda Hundred 230kV Delivery - DEV

Need Number: DOM-2019-0021

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 09/23/2024

Previously Presented:

Need – 04/30/2024

Solution – 06/04/2024

Project Driver:

Customer Service

Specific Assumption Reference:

Customer load request will be evaluated per Dominion’s Facility Interconnection Requirements Document and Dominion’s Transmission Planning Criteria.


Problem Statement:

DEV Distribution has submitted a DP Request for a new substation (Bermuda Hundred) to serve a data center in Chesterfield County with a total load in excess of 100 MW. The requested in-service date is Q4 2026.

Projected 2028 Load

Summer: 300.0 MW

Winter: 300.0 MW



Dominion Transmission Zone M-3 Process Bermuda Hundred 230kV Delivery - DEV

Need Number: DOM-2019-0021

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 09/23/2024

Selected Solution:

Connect the new substation by cutting existing 230kV Line 2050 (ICI to Allied) to proposed Bermuda Hundred Substation. Lines to terminate in a 230kV six-breaker ring arrangement.


Estimated Cost: \$15.0 M

Projected In-Service: Q4 2026

Supplemental Project ID: s3509.1

Project Status: Engineering

Model: 2029 RTEP



Dominion Transmission Zone M-3 Process Kitkat 115kV Delivery - DEV

Need Number: DOM-2022-0031

Process Stage:
Submission of Supplemental Project for Inclusion in the Local Plan – 09/23/2024

Previously Presented:

Need – 05/16/2022
Solution – 10/19/2023


Project Driver:
Customer Service

Specific Assumption Reference:
Customer load request will be evaluated per Dominion’s Facility Interconnection Requirements Document and Dominion’s Transmission Planning Criteria.

Problem Statement:
DEV distribution has submitted a DP Request for a new 115kV delivery point (Kitkat) to serve the customer from 115kV system in Augusta County with a total projected load of 20 MW. Requested in-service date is 03/30/2024.

Projected 2027 Load

Summer: 18.8 MW
Winter: 18.1 MW



Dominion Transmission Zone M-3 Process Kitkat 115kV Delivery - DEV

Need Number: DOM-2022-0031

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 09/23/2024

Selected Solution:

- Install a breaker close to pole 177 to split line #117.
- Tap line #117 close to poles 177 to provide 115kV source to the customer substation located next to the line.
- This project eliminates the need for b3264.


Estimated Cost: \$4.0 M

In-Service: 05/23/2024

Supplemental Project ID: s3513.1

Project Status: Complete

Model: 2027 RTEP



Dominion Transmission Zone M-3 Process

Edsall 230kV Delivery - DEV

Need Number: DOM-2022-0059

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 09/23/2024

Previously Presented:

Need – 12/06/2022

Solution – 04/02/2024

Project Driver:

Customer Service

Specific Assumption Reference:

Customer load request will be evaluated per Dominion’s Facility Interconnection Requirements Document and Dominion’s Transmission Planning Criteria.


Problem Statement:

DEV Distribution has submitted a DP request for a new substation (Edsall) to serve a data center complex in Fairfax County with a total load in excess of 100 MW. Requested in-service date is 09/01/2025.

Projected 2029 Load

Summer: 112.0 MW

Winter: 94.0 MW



Dominion Transmission Zone M-3 Process Edsall 230kV Delivery - DEV

Need Number: DOM-2022-0059

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 09/23/2024

Selected Solution:

At Van Dorn substation, remove breaker 210T243. Extend both the 243 Line (Ox –Van Dorn) and the 210 Line (Hayfield – Van Dorn) to the proposed Edsall substation. Lines to terminate in a 230kV four-breaker ring arrangement with an ultimate arrangement of a six-breaker ring.


Estimated Cost: \$40.0 M

Projected In-Service: 09/01/2025

Supplemental Project ID: s3504.1

Project Status: Engineering

Model: 2028 RTEP



Dominion Transmission Zone M-3 Process

Lost City 230kV Delivery - DEV

Need Number: DOM-2023-0033

Process Stage:
Submission of Supplemental Project for Inclusion in the Local Plan – 09/23/2024


Previously Presented:
Need – 05/09/2023
Solution – 01/09/2024

Project Driver:
Customer Service

Specific Assumption Reference:
Customer load request will be evaluated per Dominion’s Facility Interconnection Requirements Document and Dominion’s Transmission Planning Criteria.

Problem Statement:
DEV Distribution has submitted a DP Request for a new substation (Lost City) to serve a data center in Henrico County with a total load in excess of 100 MW. The requested in-service date is 04/30/2025.

Projected 2028 Load
Summer: 192.0 MW
Winter: 180.0 MW



Dominion Transmission Zone M-3 Process

Lost City 230kV Delivery - DEV

Need Number: DOM-2023-0033

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 09/23/2024

Selected Solution:

Connect the new substation by cutting existing 230kV Line 2282 (Techpark Place to White Oak) to proposed Lost City Substation. Lines to terminate in a 230kV four-breaker ring arrangement with an ultimate arrangement of a six-breaker ring.


Estimated Cost: \$12.3 M

Projected In-Service: 07/01/2025

Supplemental Project ID: s3502.1

Project Status: Engineering

Model: 2028 RTEP



Dominion Transmission Zone M-3 Process Ironbridge Sub – Upgrade TX#2 and Install Ring Bus

Need Number: DOM-2023-0042

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 09/23/2024

Previously Presented:

Need – 08/08/2023

Solution – 09/05/2023

Project Driver:

Customer Service

Specific Assumption Reference:

Customer load request will be evaluated per Dominion’s Facility Interconnection Requirements Document and Dominion’s Transmission Planning Criteria.


Problem Statement:

DEV Distribution has submitted a DP Request to upgrade TX #2 at Ironbridge Substation. The driver for the upgrade is the forecasted load growth in the area. The total station load will exceed 100 MVA.

Projected 2027 Load

Summer: 135.6 MW

Winter: 154.2 MW



Dominion Transmission Zone M-3 Process Ironbridge Sub – Upgrade TX#2 and Install Ring Bus

Need Number: DOM-2023-0042

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 09/23/2024

Selected Solution:

Construct a 230kV four-breaker ring bus and split Line #282 from Midlothian to Spruance NUG


Estimated Cost: \$10.3 M

Projected In-Service: 09/01/2025

Supplemental Project ID: s3501.1

Project Status: Engineering

Model: 2027 RTEP



Dominion Transmission Zone M-3 Process

Allen Creek 230kV Delivery - DEV

Need Number: DOM-2023-0052

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 09/23/2024

Previously Presented:

Need – 10/31/2023

Solution – 07/09/2024

Project Driver:

Customer Service

Specific Assumption Reference:

Customer load request will be evaluated per Dominion’s Facility Interconnection Requirements Document and Dominion’s Transmission Planning Criteria.


Problem Statement:

ODEC on behalf of Mecklenburg Electric Coop (MEC) has submitted a DP request for a new 230 kV delivery point (Allen Creek Sub) to serve a data center customer in Mecklenburg County with a total load in excess of 100 MW. Requested in-service date is 12/30/2025.

Projected 2028 Load

Summer: 80.0 MW

Winter: 110.0 MW



Dominion Transmission Zone M-3 Process

Allen Creek 230kV Delivery - DEV

Need Number: DOM-2023-0052

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 09/23/2024

Selected Solution:

- Construct Allen Creek 230 kV switching station with 4-breaker ring bus configuration. Customer will pay excess facility charges to install 6 more breakers.
- Cut Line #2258 (Finneywood – Cloud) and extend two 230kV lines to Allen Creek switching station.

Estimated Cost: \$30.0 M (Total)


Transmission Line	\$8M
230kV Substation	\$22M

Projected In-Service: 12/30/2025

Supplemental Project ID: s3511.1

Project Status: Conceptual

Model: 2028 RTEP



Dominion Transmission Zone M-3 Process Decoy Airfield 230kV Delivery - DEV

Need Number: DOM-2024-0001

Process Stage:
Submission of Supplemental Project for Inclusion in the Local Plan – 09/23/2024

Previously Presented:
Need – 02/06/2024
Solution – 06/04/2024

Project Driver:
Customer Service

Specific Assumption Reference:
Customer load request will be evaluated per Dominion’s Facility Interconnection Requirements Document and Dominion’s Transmission Planning Criteria.

Problem Statement:
DEV Distribution has submitted a DP Request for a new substation (Decoy Airfield) to serve a data center in Henrico County with a total load in excess of 100 MW. The requested in-service date is 01/01/2026.

Projected 2029 Load
Summer: 288.0 MW
Winter: 288.0 MW



Dominion Transmission Zone M-3 Process Decoy Airfield 230kV Delivery - DEV

Need Number: DOM-2024-0001

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 09/23/2024

Selected Solution:

Connect the new substation by cutting existing 230kV Line 2280 (Techpark Place to White Oak) to proposed Decoy Substation. Lines to terminate in a 230kV four-breaker ring arrangement with an ultimate arrangement of a six-breaker ring.


Estimated Cost: \$12.0 M

Projected In-Service: 01/01/2026

Supplemental Project ID: s3508.1

Project Status: Engineering

Model: 2028 RTEP



Dominion Transmission Zone M-3 Process

Nimbus - Add 3rd and 4th TX - DEV

Need Number: DOM-2024-0002

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 09/23/2024

Previously Presented:

Need – 02/06/2024

Solution – 04/02/2024

Project Driver:

Customer Service

Specific Assumption Reference:

Customer load request will be evaluated per Dominion’s Facility Interconnection Requirements Document and Dominion’s Transmission Planning Criteria.


Problem Statement:

DEV Distribution has submitted a DP Request to add the 3rd and 4th distribution transformers at Nimbus Substation in Loudoun County. The new transformer is being driven by continued load growth in the area. Requested in-service date is 10/31/2028.

Projected 2029 Load

Summer: 280.5 MW

Winter: 280.5 MW



Dominion Transmission Zone M-3 Process Nimbus - Add 3rd and 4th TX - DEV

Need Number: DOM-2024-0002

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 09/23/2024

Selected Solution:

Install (2) 1200 Amp, 50kAIC circuit switchers and associated equipment (bus, relaying, etc.) to feed the new transformers at Nimbus.


Estimated Cost: \$1.4 M

Projected In-Service: 10/31/2028

Supplemental Project ID: s3505.1

Project Status: Engineering

Model: 2028 RTEP



Dominion Transmission Zone M-3 Process

Replace Northwest TX#7 - DEV

Need Number: DOM-2024-0003

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 09/23/2024

Previously Presented:

Need – 02/06/2024

Solution – 03/05/2024

Project Driver:

Equipment Material Condition, Performance and Risk


Specific Assumption Reference:

See details on Equipment Material Condition, Performance and Risk in Dominion’s Planning Assumptions presented in December 2023.

Problem Statement:

Northwest TX#7 is a 168 MVA, 230/115/13.2 kV three-phase transformer that was manufactured in 1977. This transformer bank has been identified for replacement based on the results of Dominion’s transformer health assessment (THA) process. Detailed drivers include:

- Age (>40 years old).
- Reduced BIL ratings (3 levels below standard).
- Degraded porcelain type bushings.
- LTC (Load Tap Changer) has not been manufactured for 30 years; parts for maintenance and refurbishment becoming difficult to procure
- THA score less than 80.



Dominion Transmission Zone M-3 Process

Replace Northwest TX#7 - DEV

Need Number: DOM-2024-0003

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 09/23/2024

Selected Solution:

Replace Northwest TX#7 with a new three-phase, 230/115/13.2 kV, 168 MVA unit. Include other ancillary equipment (arresters, switches, relays, etc.) as needed.


Estimated Cost: \$5.0 M

In-Service: 06/18/2024

Supplemental Project ID: s3503.1

Project Status: Complete

Model: 2028 RTEP



Dominion Transmission Zone M-3 Process

230 kV Line #260 – EOL Rebuild

Need Number: DOM-2024-0014

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 09/23/2024

Previously Presented:

Need – 03/05/2024

Solution – 04/30/2024

Project Driver:

Equipment Material Condition, Performance and Risk


Specific Assumption Reference:

See details on Equipment Material Condition, Performance and Risk in Dominion’s Planning Assumptions presented in December 2023.

Problem Statement:

Dominion Energy has identified a need to replace approx. 10.6 miles of 230kV Line#260 from Harrisonburg to Grottoes based on the Company’s End of Life criteria.

- Line#260 from Harrisonburg to Grottoes was constructed on mostly wood structures all dating back in 1970, ACAR conductor and 3/8” static wire.
- A number of structures have been replaced, and additional wood structure replacement is identified because of wood structure issues.
- Industry guidelines indicate equipment life for steel structures is 40-60 years, wood structures is 35-55 years, conductor and connectors are 40-60 years, and porcelain insulators are 50 years.



Dominion Transmission Zone M-3 Process

230 kV Line #260 – EOL Rebuild

Need Number: DOM-2024-0014

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 09/23/2024

Selected Solution:

Approximately 10.6 miles (from Harrisonburg to Grottoes) consisting of mostly wood structures will be replaced with weathering steel H-frame structures. New conductor with a normal summer rating of 1573 MVA will be used.


Estimated Cost: \$28.0 M

Projected In-Service: 12/31/2027

Supplemental Project ID: s3506.1

Project Status: Conceptual

Model: 2028 RTEP



Dominion Transmission Zone M-3 Process

Sherwood TX#2 Upgrade - DEV

Need Number: DOM-2024-0021

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 09/23/2024

Previously Presented:

Need – 04/18/2024

Solution – 05/16/2024

Project Driver:

Customer Service

Specific Assumption Reference:

Customer load request will be evaluated per Dominion’s Facility Interconnection Requirements Document and Dominion’s Transmission Planning Criteria.


Problem Statement:

Dominion Distribution has submitted a delivery point request to upgrade TX#2 at Sherwood Substation in Albemarle County, Virginia. The upgrade is being driven by increasing customer load. Requested in-service date is 12/31/2024.

Projected 2028 Load

Summer: 98.7 MW

Winter: 64.0 MW



Dominion Transmission Zone M-3 Process Sherwood TX#2 Upgrade - DEV

Need Number: DOM-2024-0021

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 09/23/2024

Selected Solution:

Upgrade switch H284M to 2000A and circuit switcher H282 to 25kAIC on the high side of the new upgraded transformer #2.

Estimated Cost: \$0.35 M

Projected In-Service: 12/31/2024

Supplemental Project ID: s3507.1

Project Status: Engineering

Model: 2028 RTEP



Dominion Transmission Zone M-3 Process

Sloan Drive 230kV Delivery - DEV

Need Number: DOM-2024-0022

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 09/23/2024

Previously Presented:

Need – 04/30/2024

Solution – 06/04/2024

Project Driver:

Customer Service

Specific Assumption Reference:

Customer load request will be evaluated per Dominion’s Facility Interconnection Requirements Document and Dominion’s Transmission Planning Criteria.


Problem Statement:

DEV Distribution has submitted a DP Request for a new substation (Sloan Drive) to serve a data center in Chesterfield County with a total load in excess of 100 MW. The requested in-service date is Q2 2027.

Projected 2029 Load

Summer: 100.0 MW

Winter: 100.0 MW



Dominion Transmission Zone M-3 Process Sloan Drive 230kV Delivery - DEV

Need Number: DOM-2024-0022

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 09/23/2024

Selected Solution:

Connect the new substation by extending a new 230kV feed from future Bermuda Hundred Substation. Lines to terminate in a 230kV six-breaker ring arrangement.


Estimated Cost: \$25.0 M

Projected In-Service: Q4 2027

Supplemental Project ID: s3510.1

Project Status: Engineering

Model: 2029 RTEP



Dominion Transmission Zone M-3 Process Line #2114 Reactor

Need Number: DOM-2024-0027

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 09/23/2024

Previously Presented:

Need – 04/30/2024

Solution – 07/09/2024

Project Driver:

Operational Flexibility and Efficiency


Specific Assumption Reference:

See details on Operational Flexibility and Efficiency in Dominion’s Planning Assumptions presented in December 2023.

Problem Statement:

Planning studies and Dominion Energy Operations Engineering studies have identified overloads on 230 kV Line #2114 (Remington CT – Elk Run – Rollins Ford) based on a 2021 DNH analysis in the 2026 RTEP model (L/O Line 569 (Loudoun – Morrisville)).

The Dominion Energy Operations team needs a temporary solution to meet load growth expectations while avoiding thermal overloading on Line #2114 and accordingly provide flexibility for future construction outages.



Dominion Transmission Zone M-3 Process Line #2114 Reactor

Need Number: DOM-2024-0027

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 09/23/2024

Selected Solution:

Install an approximately 13.5 Ω series reactor at Remington CT on the terminal of Line #2114.


Estimated Cost: \$4.0 M

Projected In-Service: 06/01/2025

Supplemental Project ID: s3512.1

Project Status: Engineering

Model: 2026 RTEP



Dominion Transmission Zone M-3 Process Harrisonburg TX#1 Upgrade - DEV

Need Number: DOM-2023-0029

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 10/02/2024

Previously Presented:

Need – 04/20/2023

Solution – 04/18/2024

Project Driver:

Customer Service


Specific Assumption Reference:

Customer load request will be evaluated per Dominion’s Facility Interconnection Requirements Document and Dominion’s Transmission Planning Criteria.

Problem Statement:

Dominion Distribution has submitted a delivery point request to upgrade TX #1 at Harrisonburg Substation in Rockingham County, Virginia. The upgrade is being driven by increasing customer load. Requested in-service date is 12/31/2024.

Initial In-Service Load	Projected 2028 Load
Summer: 48.3 MW Winter: 71.0 MW	Summer: 51.0 MW Winter: 75.0 MW



Dominion Transmission Zone M-3 Process Harrisonburg TX#1 Upgrade - DEV

Need Number: DOM-2023-0029

Process Stage:

Submission of Supplemental Project for Inclusion in the Local Plan – 10/02/2024

Selected Solution:

Install a circuit switcher on the high-side of the new upgraded transformer #1, with a minimum of 1200A capacity and interrupting capability of 25kA.

Estimated Cost: \$0.35 M

Projected In-Service: 12/31/2024

Supplemental Project ID: s3527.1

Project Status: Construction

Model: 2028 RTEP



Revision History

02/21/2024 – V1 – Local Plan posted to pjm.com for s2340.1, s2340.2, s2499, s2500, s2609.2, s2620, s2825.1, s2825.2, s3018 – s3081 excluding s3043 & s3073.

03/26/2024 – V2 – Local Plan posted to pjm.com for s3218.1-s3222.1.

09/25/2024 – V3 – Local Plan posted to pjm.com for s2613, s2609.2, s2609.9, s3047.2, s3501.1-s3513.1

10/02/2024 – V4 – Local Plan posted to pjm.com for s3527.1