



Manual 14-D Generator Operational Requirements Revision 51

Vince Stefanowicz
Sr. Lead Engineer, Generation
System Operations Subcommittee
December 6, 2019

| | Committee | Jun | Jul | Aug | Sep | Oct | Nov | Dec |
|---|-----------|---------|--------|--------|--------|---------|---------|---------|
| Rev. 49 Non-Retail Behind the Meter Generation | SOS | | ● 7/2 | ★ 7/31 | | | | |
| | OC | ● 6/11 | | ★ 8/6 | | | | |
| | MRC | | ● 6/27 | | | ★ 9/26 | | |
| Rev. 50 Energy Storage Resource Participation | SOS | ● 6/6* | | | ★ 9/5 | | | |
| | OC | ● 6/11* | | | ★ 9/10 | | | |
| | MRC | | | | | ● 9/26 | ★ 10/31 | |
| Rev. 51 DER Ride - through | SOS | | | | | ● 10/10 | | ★ 12/6 |
| | OC | | | | | ● 10/15 | | ★ 12/10 |
| | RSCS | | | | | ○ 10/18 | | |
| | MRC | | | | | ● 10/31 | | 12/19 ★ |

- *First Read*
- ★ *Endorsement*
- *Info Only*

*Initially presented as Rev. 49

- Absent Ruling from FERC on Order 845, Generating Facility not yet defined in OATT
- In Definitions and Applicability section, defined Generating Facility for use in M-14D – removed reference to OATT

For purposes of this manual, “Generating Facility” shall mean Interconnection Customer’s device for the production and/or storage for later injection of electricity identified in the Interconnection Request, but shall not include the interconnection customer’s Interconnection Facilities.

Voluntary guidance developed through DER Ride-through Task Force

Applies to distribution-connected generators connected to radial distribution lines of voltage less than 50 kV

Directs Distributed Energy Resources to appropriate Transmission Owner Engineering & Construction Standards

- Stand alone document posted on PJM website

Added in Section 7.1.1 Generator Real-Power Control

7.1 Dispatching of Generation

7.1.1 Generator Real-Power Control

~~The Generator~~ Generating Facilities must deliver the electric energy generated by the facility to PJM at the point(s) of interconnection in the form of 3 phase, 60-Hertz alternating current at the nominal system voltage at the point of interconnection.

~~Generators~~ Generating Facilities and their protective systems (relaying, V/Hz, etc.) should meet the frequency guidelines listed in PJM Manual M-36, System Restoration, section 2.3, to coordinate with system preservation under-frequency load shedding. Additionally, ~~generators~~ Generating Facilities and their protective systems should be capable of operation at over-frequency up to 61.7 Hz for a limited duration. Refer to NERC Reliability Standard PRC-024, Generator Frequency and Voltage Protective Relay Settings. For Generating Facilities connected to radial distribution lines of voltage less than 50 kV, refer to the ride through guidance document posted at <https://www.pjm.com/planning/design-engineering/to-tech-standards.aspx> for additional guidance.

Link to draft guideline

- <https://www.pjm.com/-/media/committees-groups/committees/oc/20191015/20191015-oc-informational-only-pjm-guideline-for-ride-through-performance-rev2.ashx>

Manual 14-D, Rev 51 Review / Approval Timeline

