

| | |
|--|-------------------|
| Effective Date | November 23, 2020 |
| Impacted Manual #(s)/Manual Title(s): | |
| M-10: Pre-scheduling Operations, Revision 39 | |
| Conforming Order(s): | |
| None | |
| Associated Issue Tracking Title: | N/A |
| Committee Approval Path - What committee(s) have already seen these changes? | |
| Planned committee reviews/endorsements: SOS: August 31, 2020, October 5, 2020 RSCS: October 16, 2020 OC: September 3, 2020, October 8, 2020 (Endorsement) MRC: October 29, 2020, November 19, 2020 (Endorsement) | |
| MRC 1st read date: | October 29, 2020 |
| MRC voting date: | November 19, 2020 |
| Impacted Manual sections: | |
| See detailed list below | |
| Reason for change: | |
| Periodic Review Clarifications to existing language | |
| Periodic Cover to Cover Review | |
| Section 2.1 Generation Outage Reporting Overview <ul style="list-style-type: none"> Explained the difference between eDART and GADS Clarified when an eDART ticket is required by unit type/status and the VARIOUS definitions of eDART Reportable MW Added ambient air ticket guidance Added description of Gen Checkout and reference to User Guide Clarified when a Maintenance / Planned outage may be appropriate if coordinated with transmission or pipeline outage. Added guidance on the use of "Info Only" eDART tickets Added clarification for reporting of reduction amounts during protracted ramps over multiple days | |
| Section 2.2 Planned Outages <ul style="list-style-type: none"> Clarified that Planned Outages cannot be extended into the Peak Period. | |

Section 2.2.1 Planned Outage Request Procedure

- Clarified timeline for submission of Forecasted Planned Outages

Section 2.2.3 Planned Outage Extension

- Clarified what happens if an outage extension is not requested more than 48 hours in advance.

Section 2.2.4 Planned Outage Restrictions for Black Start Units

- Clarified requirement for GO to secure TO approval prior to BS Unit outage approval

Section 2.3 Maintenance Outages

- Clarified that back-to-back Maintenance Outages exceeding 9 days are not permitted
- Clarified that Maintenance Outages cannot be used to extend a planned outage

Section 2.3.2 Maintenance Outage Rules

- Added reference to Recall Date and Forced Date

Section 2.3.3 Maintenance Outage Extension

- Clarified disposition of Maintenance Outage that is not extended in a timely manner

Section 2.4 Unplanned (Forced) Outages

- Added language, similar to Maintenance Outage section that clarifies relationship between outage ticket and delivery obligation.