

VI.C

CIRCUIT BREAKERS

*GUIDE FOR DETERMINATION OF CIRCUIT BREAKER
LOAD CURRENT CAPABILITY RATINGS*

PJM INTERCONNECTION

Heritage MAAC Group

a task force of the Transmission and Substation Subcommittee

R. W. Munley

D. J. Lemmerman

V. C. Jhonsa

D. M. Egan

R. Vresko

A. Mannarino

Baltimore Gas and Electric Company

Exelon

Pepco Holdings Incorporated

PJM Interconnection, L.L.C.

PPL Electric Utilities

Public Service Electric and Gas Company

THIS PAGE WAS LEFT BLANK

INTENTIONALLY

Contents

REVISION HISTORY	5
SCOPE AND PURPOSE	6
DISCUSSION OF RATING METHOD	6
DEFINITIONS.....	7
AMBIENT TEMPERATURE.....	8
NORMAL RATINGS	9
EMERGENCY & LOAD DUMP CURRENT RATINGS	9
CURRENT TRANSFORMER AND CONNECTED EQUIPMENT LIMITATIONS	9
BUSHINGS & CONNECTIONS	9
DETERMINATION OF RATINGS	10
TABLE I - TEMPERATURE LIMITATIONS FOR CIRCUIT BREAKERS	11
TABLE II - CIRCUIT BREAKER RATINGS.....	13
ANNEX I - FORMULAE AND SAMPLE CALCULATIONS.....	14
PART A - CIRCUIT BREAKER RATING FORMULAE	14
PART B - CURRENT TRANSFORMER RATING FORMULAE.....	16
PART C - SAMPLE CALCULATIONS	18
ANNEX II - SAMPLE 230 KV, 4000A, POST-1964, CLASS A INSULATION.....	23
BIBLIOGRAPHY	24

REVISION HISTORY

May 1971: Rev. 0 – Original Document.

June 1999: Rev. 1 - Format changes and general revision.

October 2009: Rev. 2 - General revision and document standardization and clarification of emergency and load dump ratings, and revision of associated equations.

SCOPE AND PURPOSE

This guide presents principles and procedures to be used in establishing normal, emergency four hour and load dump current carrying capabilities for circuit breakers designed, built and tested under IEEE/ANSI standards. It does not consider close and latch, short circuit and interrupting capabilities. The resulting thermal ratings can be used for selecting the most economical nameplate ratings for new circuit breakers. Circuit breakers built under standards listed in the Bibliography of this report are included. This guide includes methods for determination of thermal ratings of all circuit breaker current transformers except free standing, external current transformers. Recognition is made that exceptions such as those listed in the subheading entitled “Current Transformer and Connected Equipment Limitations” may be necessary for special conditions. “Circuit breaker” and “circuit breaker parts” terms used in this report include bushing current transformers unless they are specifically excluded. A spreadsheet, available from PJM upon request, was developed to perform breaker ratings calculations. A sample calculation is provided in Annex II.

DISCUSSION OF RATING METHOD

The rating methods established by this report comprise the various factors and consider provisions of IEEE/ANSI Standard C37.010-2000. The method developed is based primarily on the following:

- a. Ambient temperature (θ_a).
- b. Temperature rise as function of the 1.8 power of the current.
- c. Maximum temperature determined to be acceptable for various circuit breaker components under normal and emergency conditions.
- d. Acceptable accelerated deterioration of some circuit breaker parts under emergency conditions.

It is assumed that power levels will be maintained and managed within the requirements of PJM Manual 3, Section 2, “Thermal Operating Guidelines”. PJM operating philosophy strives to restore loads to below the Normal Rating in four hours or less. The intent of this guide is that equipment loading will not be above the Normal Rating for greater than four hours. It is understood that under a single event restoration, cumulative time of loading, in excess of the Normal Rating, beyond four hours may occur. Operating in excess of four hours above the Normal Rating for a single event restoration should be evaluated by the equipment owner.

DEFINITIONS

Following are definitions of terms used in this report for use in determining PJM circuit breaker ratings.

Adjusted Rated Continuous Current of a Circuit Breaker (I)

Continuous current capability of a circuit breaker corrected to Limit of Observable Temperature Rise using specific Test Observable Temperature Rise data. Note: $I = I_r$ when specific temperature rise test data is not available.

Adjusted Rated Continuous Current of a Current Transformer Tap (I_{tap})

Continuous current capability of a specific tap of a current transformer corrected for connection on a reduced tap and to Limit of Observable Temperature Rise using specific Test Observable Temperature Rise data.

Ambient Temperature (θ_a)

Expected air temperature surrounding the rated circuit breaker.

Continuous Thermal Current Rating Factor (RF) [Pertaining to Current Transformers Only]

The specified factor by which the rated continuous current of any current transformer tap can be multiplied to obtain the primary current that can be carried continuously without exceeding the Limit of Observable Temperature Rise.

Emergency Allowable Maximum Temperature (θ_{max_e})

Maximum temperature which any circuit breaker part can withstand for various emergency rating durations, e.g., $\theta_{max_{e4}}$ = 4 hour maximum temperature, etc.

Emergency Current Rating (I_{ea})

Current that can be carried for a specified period of time, at selected ambient temperature, without any circuit breaker part exceeding its emergency allowable maximum temperature. In PJM the Emergency Current Rating is for a four hour duration, e.g., I_{ea_4} = 0 to 4 hour emergency current.

Limit of Observable Temperature Rise (θ_r)

The allowable hottest spot temperature rise at rated current. Maximum value of observable temperature rise of any part of a circuit breaker as limited by C37.010-2000 and C37.4 1953. Values are listed in Table I of this report.

Load Dump Current Rating ($I_{s0.25}$)

In PJM a Load Dump Current Rating is a Short Time Emergency Current Capability for 15 minute duration, e.g. $I_{s0.25}$ is the current which can be carried 15 minutes, or a $\frac{1}{4}$ of an hour.

Normal Allowable Maximum Temperature (θ_{max})

The allowable hottest spot temperature. Maximum temperature that any circuit breaker part can withstand continuously. Values from C37.010-2000 and C37.4 1953 are listed in Table I of this report.

Normal Current Rating (I_a)

Current that can be carried continuously without any circuit breaker part exceeding its normal allowable maximum temperature.

Rated Continuous Current (Nameplate Rating) (I_r)

Maximum current in Amperes at rated frequency a device can carry continuously without any part exceeding its Limit of Observable Temperature Rise.

Rated Continuous Current (Nameplate Rating) of a Current Transformer Tap (I_{tap_r})

Maximum current in Amperes at rated frequency a specific tap of a current transformer can carry continuously without the current transformer exceeding its Limit of Observable Temperature Rise.

Short Time Emergency Current Capability (I_s)

Short time emergency currents which can be carried for less than 4 hours, e.g. $I_{s0.25}$ is the current which can be carried for a ¼ of an hour.

Temperature Due to Initial Continuous Current (θ_i)

Maximum temperature due to initial continuous current at ambient, θ_a . Utilized in calculation of short time capabilities for less than four hours.

Temperature Reached if I_s were applied continuously (θ_s)

Maximum temperature reached if the short term current I_s were to be applied continuously at ambient θ_a . Utilized in calculation of short time capabilities for less than four hours.

Test Observable Temperature Rise (θ)

Measured steady-state temperature rise above measured ambient temperature of any part of a circuit breaker when tested at rated continuous current.

Thermal Time Constant (τ)

Time required, in hours, for the temperature of a circuit breaker part to change from the initial value to the ultimate value if the initial rate of change were continued until the ultimate temperature was reached. (Assumed to be 1/2 hour minimum for all circuit breakers and current transformers in this report).

AMBIENT TEMPERATURE

Since maximum circuit breaker temperature is a function of ambient temperature, θ_a , the value of ambient temperature is important for determination of ratings. For short-time intervals the maximum expected ambient temperature is of prime importance. Temperature records surveyed by the PJM Companies resulted in agreement on use of the following temperatures for planning purposes, which are consistent with those used for all PJM equipment ratings (Normal, Emergency and Load Dump):

<u>Description</u>	<u>Summer</u>	<u>Winter</u>
PJM Planning Basis Temperatures	35 °C	10 °C

PJM Operations utilizes ambient adjusted ratings in 5 °C increments. The method described in this document allows the calculation of these capabilities.

NORMAL RATINGS

The normal current rating of a circuit breaker is that current which can be carried continuously without any circuit breaker part exceeding its normal allowable maximum temperature. The prime considerations in defining the normal current rating of a circuit breaker are ambient temperature and Limit of Observable Temperature Rise. The normal current rating is calculated by compensating the adjusted rated continuous current (rated continuous current if temperature rise from heat run test is not available) for specific ambient temperature.

EMERGENCY & LOAD DUMP CURRENT RATINGS

Emergency ratings for durations of four hours are based on operation up to the emergency allowable maximum temperature for the limiting circuit breaker part. Emergency allowable maximum temperature limits of 15 °C above the normal allowable maximum temperature are utilized for ratings of four hours and less duration. This temperature limit may result in slightly accelerated deterioration of some circuit breaker parts but will not affect circuit breaker interrupting capability. Emergency ratings for durations of less than four hours, for example load dump current ratings, are determined based on the circuit breaker thermal time constant which is a function of the heat storage capacity of the circuit breaker. Loading prior to applying emergency ratings, including load dump current rating, shall be 100% or less of the normal rating for the ambient temperature. Ratings can be increased by assuming pre-load current less than 100% of normal rating.

After the emergency duration, it is assumed that temperatures shall be reduced to the normal rating limit prior to the emergency rating being used again. For a time constant of 30 minutes, a three hour cool down period is recommended.

CURRENT TRANSFORMER AND CONNECTED EQUIPMENT LIMITATIONS

When current transformers have Class A insulation, a continuous thermal current factor of 1.0, and are connected on a tap equivalent to or greater than the circuit breaker rated continuous current, they generally will not limit the circuit breaker normal, emergency or load dump rating. Annex I contains a method for determining the rating of a current transformer when connected on a tap which has a rating lower than that corresponding to the rated continuous current of the circuit breaker. When determining a current transformer thermal rating all accessory equipment connected to the secondary must be checked for thermal capability.

BUSHINGS & CONNECTIONS

Prior to 1964, θ_{max} for bushings was limited to 70 °C, and this should be utilized for breakers manufactured prior to this time. Since 1964, circuit breaker emergency ratings have been described as requirements of IEEE/ANSI standard C37.010 (Application Guide for AC High-Voltage Circuit Breakers). Breakers purchased to meet this standard should contain bushings that would operate to the emergency conditions described. The circuit breaker manufacturer should be contacted to determine bushing capabilities.

Connections must also be considered when determining circuit breaker loading capabilities. Bushing standards have indicated that external bus or cable connections under normal conditions should not operate with more than a 30 °C rise (e.g. a total temperature of 70 °C at a 40 °C ambient) at normal rated currents. Designs exceeding these levels would both deteriorate the bushing under normal conditions and could further elevate temperature rises under emergency and load dump conditions.

DETERMINATION OF RATINGS

Circuit breaker ratings can be determined as follows:

- a) If circuit breaker materials and/or the year of manufacture is known, refer to Table I and then determine ratings from Table II.
- b) If no information is available on circuit breaker materials or the year of manufacture, the following minimum ratings from Table II can be applied.

Minimum Rating of All Circuit Breaker Material Classes
(Percent of Circuit Breaker Adjusted Rated Continuous Current)

Rating Duration	Winter (%)	Summer (%)
Normal	123	104
Emergency, 0 to 4 hours	134	116
Load Dump, 0.25 hours, (15 minutes)	176	138

These minimum ratings do not consider limitations of current transformers:

1. With 80 °C rise insulation because only a small number are in service.
2. When connected to a reduced tap.
3. When connected equipment is thermally limiting.

These minimum ratings do not consider limitations of bushings and their external connections.

See Annex II for sample 230 kV, 3000 Amp, post 1964, Class A insulation circuit breaker ratings at 5 °C increments of ambient temperature. Note that a functional rating spreadsheet is available upon request from PJM.

MAINTENANCE REQUIREMENTS

Satisfactory performance of circuit breakers carrying loads based on ratings established by this report are dependent upon adequate maintenance.

TABLE I - TEMPERATURE LIMITATIONS FOR CIRCUIT BREAKERS

TEMPERATURE LIMITATIONS FOR CIRCUIT BREAKERS ¹					
Circuit Breaker Component Description		Limit of Observable Temperature Rise at Rated Current θ_r (°C)	Limit of Total Allowable Maximum Temperature θ_{max} (°C)	Emergency Allowable Maximum Temperature Rating θ_{max_e} (°C)	
				4 Hours or Less $\theta_{max_{e4}}$	15 Minutes or Less $\theta_{max_{e.25}}$
Breakers manufactured prior to 1964					
1	Contacts in oil, oil and bushings	30	70	85	85
2	Contact in air or gas	35	75	90	90
3	Average Winding Temperature Rise of Current Transformer with 55 °C Rise (Class A) Insulation	55	95	110	110
4	Average Winding Temperature Rise of Dry-Type Current Transformer with 80 °C Rise (Class B) Insulation	80	120	135	135
Breakers manufactured 1964 and later²					
1	Copper Contacts, Copper-to-Copper Conducting Joints, External Terminal Connected to Bushing	30	70	85	85
2	Top Oil	40	80	95	95
3	Hot Spot Oil at Points in Contact with Hot Parts, Silver (or Equal) Contacts or Conducting Joints in Oil	50	90	105	105
4	Average Winding Temperature Rise of Current Transformer with 55 °C Rise (Class A) Insulation	65	105	120	120
5	Silver (or Equal) Contacts or Conducting Joints in Air or Gas, Hottest Spot of Bushing Metal Parts in Contact with Class A Insulation or with Oil	65	105	120	120
6	Average Winding Temperature Rise of Dry-Type Current Transformer with 80 °C Rise (Class B) Insulation	110	150	165	165

¹ Adapted from IEEE/ANSI C37.010-2000

² Unless indicated otherwise by manufacturer contacts and conducting joints in other than oil or air are assumed to be at 65°C hottest spot rise and 105°C hottest spot temperature per IEEE/ANSI C37.010-2000

TABLE II - CIRCUIT BREAKER RATINGS

(% OF ADJUSTED RATED CONTINUOUS CURRENT)¹

Allowable Max. Temp. θ_{max} (°C)	70°C		75°C		80°C		90°C		95°C		105°C		120°C		150°C		Minimum Rating of all temperatures ⁵	
	\underline{W}^2	\underline{S}^3	\underline{W}^2	\underline{S}^3	\underline{W}^2	\underline{S}^3	\underline{W}^2	\underline{S}^3	\underline{W}^2	\underline{S}^3	\underline{W}^2	\underline{S}^3	\underline{W}^2	\underline{S}^3	\underline{W}^2	\underline{S}^3	\underline{W}^2	\underline{S}^3
Normal Ambient Adjusted	147	109	141	108	136	107	130	105	127	105	123	104	119	103	114	103	123	104
4 Hrs.	166	133	158	129	152	125	143	121	139	119	134	116	128	113	121	110	134	116
15 minute ⁴	200 ⁶	173	200 ⁶	165	200 ⁶	158	194	148	187	144	176	138	164	131	149	123	176	138

Notes:

1. CAUTION: The ratings in this table do not include limitations of bushings, and/or current transformers connected on reduced taps or limitations of equipment connected to current transformers.
2. Winter ambient temperature is 10°C for all rating durations.
3. Summer ambient temperatures are 35°C for all rating durations.
4. These emergency rating factors are based on breaker half-hour thermal time constants, per IEEE/ANSI C37.010-2000.
5. Minimum ratings listed do not include 120°C and 150°C because of the limited number of bushing current transformers that use 80°C rise insulation.
6. IEEE/ANSI limits loading beyond nameplate to 200%.

ANNEX I - FORMULAE AND SAMPLE CALCULATIONS

PART A - CIRCUIT BREAKER RATING FORMULAE

1.0 Correction of Rated Continuous Current (Based on factory temperature rise test only)

When a circuit breaker test temperature rise is less than guaranteed, ratings may be adjusted as follows for each material class.

$$I = I_r \left(\frac{\theta_r}{\theta} \right)^{\frac{1}{n}}$$

I = Adjusted rated continuous current

I_r = Rated continuous current (circuit breaker nameplate rating)

θ = Test observable temperature rise at rated continuous current

θ_r = Limit of Observable Temperature Rise at rated continuous current

n = 1.8 for circuit breakers

For subsequent calculations the adjusted rated continuous current (I) should be used when test data is available. When test data is not available, use rated continuous current (I_r).

Note: ANSI nomenclature utilizes (I_r), moreover $I = I_r$ when temperature rise tests are unavailable.

2.0 Calculation of Normal (Continuous) Current Ratings (Based on ambient temperature)

Winter and summer normal ratings may not be equal to rated continuous current but can be determined as follows:

$$I_a = I \left(\frac{\theta_{\max} - \theta_a}{\theta_r} \right)^{\frac{1}{n}}$$

I_a = Normal current rating

θ_a = Ambient temperature

θ_{\max} = Allowable maximum temperature ($\theta_{\max} = \theta_r + 40$ °C)

3.0 Calculation of Emergency Ratings of 4 Hour Duration

Winter and summer emergency ratings of 4 hour duration can be determined as follows:

$$I_{ea4} = I \left(\frac{\theta_{\max e4} - \theta_a}{\theta_r} \right)^{\frac{1}{n}}$$

I_{e4} = Emergency rating for 4 hour duration

$\theta_{max_{e4}}$ = Emergency (4 hour) allowable maximum temperature

4.0 Calculation of Emergency Ratings of Less Than 4 Hour Duration

Winter and summer emergency ratings of less than 4 hour duration can be determined as follows:

$$\theta_i = (\theta_{max} - 40^\circ\text{C}) \left(\frac{I_i}{I_r}\right)^n + \theta_a$$

For PJM ratings in this guide it is assumed that the initial load I_i is equal to I_r the rated load. Therefore the equation above reduces to:

$$\theta_i = (\theta_{max} - 40^\circ\text{C}) + \theta_a$$

$$\theta_s = \left(\frac{\theta_{max_{e4}} - \theta_i}{1 - e^{-\frac{t}{\tau}}}\right) + \theta_i$$

$$I_s = I_r \left(\frac{\theta_s - \theta_a}{\theta_{max} - 40^\circ\text{C}}\right)^{\frac{1}{n}}$$

θ_i = total temperature due to initial continuous current at ambient θ_a .

θ_s = total temperature reached if I_s were applied continuously at ambient θ_a .

I_s = Emergency rating of less than 4 hour duration

t = Rating duration (hours)

τ = Thermal time constant of the circuit breaker (hours)

τ , The thermal time constant of a circuit breaker, preferably should be obtained by test or it can be conservatively used as 0.5 hours (30 minutes).

PART B - CURRENT TRANSFORMER RATING FORMULAE

The current transformer is designed to allow operation in the higher temperature environment of a circuit breaker. For simplification of calculation of current transformer ratings, the assumption is made that the temperature rise of the current transformer with the continuous thermal current rating factor applied is equal to its allowable maximum temperature less the ambient temperature of the air surrounding the circuit breaker.

1.0 Correction of Rated Continuous Current for Operation on Any Tap

Using the current transformer tap setting, the adjusted rated continuous current of the tap may be determined as follows:

$$I_{tap} = I_{tap_r} \left(\frac{I_r}{I_{tap_r}} \right)^{\frac{1}{n}} \times RF$$

I_{tap} = Adjusted rated continuous current of specific current transformer tap under consideration

I_r = Rated continuous current (current transformer nameplate rating)

I_{tap_r} = Rated continuous current of specific current transformer tap under consideration

RF = Continuous thermal current rating factor (Manufacturer should be consulted for value of the continuous thermal current rating factor. Assume 1.0 if not available.)

n = 1.8 for current transformers

Note: If temperature rise data from a heat run test is available for a current transformer, the adjusted rated continuous current of the tap may be determined using the formulae in Annex I, Part C, 2.0, "Determination of Current Transformer Ratings".

2.0 Calculation of Normal (Continuous) Current Ratings

Winter and summer normal ratings for current transformers can be determined as follows:

$$I_a = I_{tap} \left(\frac{\theta_{max} - \theta_a}{\theta_r} \right)^{\frac{1}{n}}$$

3.0 Calculation of Emergency Ratings

Winter and summer emergency ratings for current transformers can be determined as follows:

4 Hour Duration

$$I_{ea4} = I_{tap} \left(\frac{\theta_{max_{e4}} - \theta_a}{\theta_r} \right)^{\frac{1}{n}}$$

Less Than 4 Hour Duration

$$\theta_i = (\theta_{max} - 40^{\circ}\text{C}) + \theta_a$$

$$\theta_s = \left(\frac{\theta_{max_{e4}} - \theta_i}{1 - e^{-\frac{t}{\tau}}} \right) + \theta_i$$

$$I_s = I_r \left(\frac{\theta_s - \theta_a}{\theta_{max} - 40^{\circ}\text{C}} \right)^{\frac{1}{n}}$$

PART C - SAMPLE CALCULATIONS

1.0 Determination of Circuit Breaker Ratings (Includes current transformer limitations)

Since all circuit breakers may contain more than one material class, it will be necessary to determine ratings for each material class and select the limiting rating for the appropriate conditions.

Assume a 1200 ampere nameplate oil circuit breaker with silver contacts, 1200/5 ampere multi-ratio bushing current transformers with Class A insulation, a continuous thermal current rating factor RF of 1.33 and connected on the 1200 ampere tap. Temperature rises from heat run test data are as follows:

Component	Observable Temperature Rise, θ °C
Bushing Terminal (Silver Plated)	50.4
Contacts (Silver-to-Silver)	43.5
Top Oil	28.0

Adjusted Rated Continuous Current (Based on factory temperature rise test only)

For the 1200 ampere (I_r) oil circuit breaker, the adjusted rated continuous current should be determined for each component.

$$I = I_r \left(\frac{\theta_r}{\theta} \right)^{\frac{1}{1.8}}$$

	θ	θ_r	I
	°C	°C	(amp)
Bushing Top Terminal	50.4	65	1382
Contacts	43.5	50	1296
Top Oil	28.0	40	1463

For the 1200/5 ampere multi-ratio bushing current transformer on the 1200 ampere tap, the adjusted rated continuous current should be determined.

$$I_{tap} = I_{tap_r} \left(\frac{I_r}{I_{tap_r}} \right)^{\frac{1}{1.8}} \times RF$$

$$I_{tap} = 1200 \left(\frac{1200}{1200} \right)^{\frac{1}{1.8}} \times 1.33$$

$$I_{tap} = 1596$$

Ambient Adjusted Normal Continuous Current Ratings (Based on adjusted current ratings evaluated from factory temperature rise test)

For all parts except CT:

$$I_a = I \left(\frac{\theta_{max} - \theta_a}{\theta_r} \right)^{\frac{1}{1.8}}$$

For CT:

$$I_a = I_{tap} \left(\frac{\theta_{max} - \theta_a}{\theta_r} \right)^{\frac{1}{1.8}}$$

	I or I _{tap} (amp.)	θ _r (°C)	θ _{max} (°C)	I _a (amp) Summer θ _a = 35°C	I _a (amp) Winter θ _a = 10°C
Bushing Top Terminal	1382	65	105	1440	1706
Contacts	1296	50	90	1366	1682
Top Oil	1463	40	80	1562	1996
CT	1596	55	95	1675	2032

Contacts are limiting for summer and winter ratings.

Emergency Ratings of 4 Hour Duration

(I = nameplate current rating, I_{tap} = Nameplate current of CT with a RF of 1.33)

For all parts except CT:

$$I_{ea4} = I \left(\frac{\theta_{max_{e4}} - \theta_a}{\theta_r} \right)^{\frac{1}{1.8}}$$

For CT:

$$I_{ea4} = I_{tap} \left(\frac{\theta_{max_{e4}} - \theta_a}{\theta_r} \right)^{\frac{1}{1.8}}$$

	I or I _{tap} (amp)	θ _r (°C)	θ _{maxe4} (°C)	I _{ea4} (amp) Summer θ _a = 35°C	I _{ea4} (amp) Winter θ _a = 10°C
Bushing Top Terminal	1200	65	120	1392	1607
Contacts	1200	50	105	1446	1714
Top Oil	1200	40	95	1503	1824
CT	1596	55	110	1896	2224

Bushing top terminal is limiting for summer and winter ratings.

Emergency Ratings of 15 Minute Duration

(I = nameplate current rating, I_{tap} = Nameplate current of CT with a RF of 1.33)

Assumes 0.5 hour (30 minute) circuit breaker time constant with t = 0.25 and τ = 0.5.

For all parts except CT:

$$\theta_i = (\theta_{max} - 40^\circ\text{C}) + \theta_a$$

$$\theta_s = \left(\frac{\theta_{maxe4} - \theta_i}{1 - e^{-\frac{t}{\tau}}} \right) + \theta_i$$

$$I_s = I_r \left(\frac{\theta_s - \theta_a}{\theta_{max} - 40^\circ\text{C}} \right)^{\frac{1}{1.8}}$$

For CT:

$$I_s = I_{tap} \left(\frac{\theta_s - \theta_a}{\theta_{max} - 40^\circ\text{C}} \right)^{\frac{1}{1.8}}$$

	I or I _{tap} (A)	θ _{max} (°C)	θ _{maxe4} (°C)	Summer θ _a = 35°C			Winter θ _a = 10°C		
				θ _i (°C)	θ _s (°C)	I _{50.25} (A)	θ _i (°C)	θ _s (°C)	I _{50.25} (A)
Bushing Top Terminal	1200	105	120	100	150.8	1654	75	189.3	2109
Contacts	1200	90	105	85	135.8	1771	60	174.3	2324
Top Oil	1200	80	95	75	125.83	1892	50	164.3	2541
CT	1596	95	110	90	140.8	2298	65	179.3	2984

Bushing top terminal is limiting for summer and winter ratings.

2.0 Determination of Current Transformer Ratings

The following example illustrates the impact on emergency ratings that results from utilizing a reduced tap on a CT. Compare these ratings to the previous example (Annex I, Part C, 1.0) and note the CT will become the component limiting circuit breaker emergency ratings.

Assume the circuit breaker in the above example has 1200/5 ampere multi-ratio current transformers with Class A insulation, a continuous thermal current rating factor (RF) of 1.33 and is connected on the 800 ampere tap.

Adjusted Rated Continuous Current

$$I_{tap} = I_{tapr} \left(\frac{I_r}{I_{tapr}} \right)^{\frac{1}{1.8}} \times RF$$
$$I_{tap} = 800 \left(\frac{1200}{800} \right)^{\frac{1}{1.8}} \times 1.33 = 1333 \text{ Amperes}$$

Ambient Adjusted Normal Continuous Current Ratings (Based on adjusted current ratings evaluated from factory temperature rise test)

$$I_a = I_{tap} \left(\frac{\theta_{max} - \theta_a}{\theta_r} \right)^{\frac{1}{1.8}}$$
$$I_a = 1333 \left(\frac{95 - \theta_a}{55} \right)^{\frac{1}{1.8}}$$

$\theta_a = 35^\circ\text{C}$ summer; 10°C winter.

I_a (winter) = $1333 \times 1.27 = 1698$ amp.

I_a (summer) = $1333 \times 1.05 = 1399$ amp.

Emergency Ratings of 4 Hour Duration

(I = nameplate current rating, I_{tap} = Nameplate current of CT with a RF of 1.33)

$$I_{ea4} = I_{tap} \left(\frac{\theta_{max_{e4}} - \theta_a}{\theta_r} \right)^{\frac{1}{1.8}}$$
$$I_{ea4} = 1333 \left(\frac{110 - \theta_a}{55} \right)^{\frac{1}{1.8}}$$

I_{ea4} (winter) = $1333 \times 1.05 = 1399$ amp.

I_{ea4} (summer) = $1333 \times 1.18 = 1573$ amp.

Emergency Ratings of 0.25 hour (15 Minute) Duration

$$\theta_i = (\theta_{max} - 40^\circ\text{C}) + \theta_a$$

$$\theta_s = \left(\frac{\theta_{max} e^{\frac{-t}{\tau}} - \theta_i}{1 - e^{\frac{-t}{\tau}}} \right) + \theta_i$$

$$I_{s_{0.25}} = I_{tap} \left(\frac{\theta_s - \theta_a}{\theta_{max} - 40^\circ\text{C}} \right)^{\frac{1}{1.8}}$$

Summer $\theta_a = 35^\circ\text{C}$

$$\theta_i = (95^\circ\text{C} - 40^\circ\text{C}) + 35^\circ\text{C} = 90^\circ\text{C}$$

$$\theta_s = \left(\frac{110^\circ\text{C} - 90^\circ\text{C}}{1 - e^{\frac{-0.25}{0.5}}} \right) + 90^\circ\text{C} = 140.8^\circ\text{C}$$

$$I_{s_{0.25}} = I_{tap} \left(\frac{140.8^\circ\text{C} - 35^\circ\text{C}}{95^\circ\text{C} - 40^\circ\text{C}} \right)^{\frac{1}{1.8}} = 1.438 I_{tap}$$

$$I_{s_{0.25}}(\text{summer}) = 1333 \times 1.438 = 1917 \text{ amp}$$

Winter $\theta_a = 10^\circ\text{C}$

$$\theta_i = (95^\circ\text{C} - 40^\circ\text{C}) + 10^\circ\text{C} = 65^\circ\text{C}$$

$$\theta_s = \left(\frac{110^\circ\text{C} - 65^\circ\text{C}}{1 - e^{\frac{-0.25}{0.5}}} \right) + 65^\circ\text{C} = 179.4^\circ\text{C}$$

$$I_{s_{0.25}} = I_{tap} \left(\frac{179.4^\circ\text{C} - 10^\circ\text{C}}{95^\circ\text{C} - 40^\circ\text{C}} \right)^{\frac{1}{1.8}} = 1.868 I_{tap}$$

$$I_{s_{0.25}}(\text{winter}) = 1333 \times 1.868 = 2490 \text{ amp}^1$$

¹ IEEE/ANSI limits loading beyond nameplate to 200% (2128 amp).

ANNEX II - SAMPLE 230 KV, 4000A, POST-1964, CLASS A INSULATION

Breaker Rating

SUBSTATION EQUIPMENT RATING WORKSHEET											
CIRCUIT BREAKER											
1) Populate the nameplate information table as fully as possible											
		NAMEPLATE									
STATION											
EQUIPMENT	Circuit Breaker										
TYPE											
MANUFACTURER											
YEAR MANUFACT.	1976										
POSITION											
DESIGNATION											
RATED VOLTAGE (KV)	230										
RATED CURRENT (A)	4000										
NOTE: Correct system voltage must be entered for corresponding MVA values in the tables below.											
2) Identify a material class and complete the input table											
Breakers manuf. Prior to 1964					Breakers manuf. 1964 and later						
	1	2	3	4	1	2	3	4	5	6	
$\theta_{max} e4$	85	90	110	135	85	95	105	120	120	165	
θ_{max}	70	75	95	120	70	80	90	105	105	150	
θ_r	30	35	55	80	30	40	50	65	65	110	
		INPUT									
$\theta_{max} e4$	120										
θ_{max}	105										
θ_r	65										
I Rated	4000										
Rated KV	230										
		Ratings		Summer 35°C		Winter 10°C					
				MVA	Amps	MVA	Amps				
		Normal		1660	4168	1967	4939				
		Emergency (4 Hr)		1850	4643	2134	5358				
CALCULATED RATINGS											
AMBIENT TEMP.		RATING (P.U.)			RATING (MVA)			RATINGS (AMPS)			
θ_a	θ_a										
Deg. C	Deg. F	NORMAL	4 HOUR	LOAD DUMP	NORMAL	4 HOUR	LOAD DUMP	NORMAL	4 HOUR	LOAD DUMP	
0	32	1.31	1.41	1.89	2080	2240	3015	5221	5623	7567	
5	41	1.27	1.37	1.83	2024	2188	2909	5082	5492	7303	
10	50	1.23	1.34	1.76	1967	2134	2801	4939	5358	7030	
15	59	1.20	1.31	1.69	1909	2080	2689	4793	5221	6749	
20	68	1.16	1.27	1.61	1850	2024	2573	4643	5082	6458	
25	77	1.12	1.23	1.54	1788	1967	2452	4489	4939	6156	
30	86	1.08	1.20	1.46	1725	1909	2327	4331	4793	5842	
35	95	1.04	1.16	1.38	1660	1850	2197	4168	4643	5514	
40	104	1.00	1.12	1.29	1593	1788	2059	4000	4489	5169	

BIBLIOGRAPHY

1. ANSI Standards C37.04-1999 Rating Structure for AC High-Voltage Circuit Breakers on a Symmetrical Current Basis.
2. ANSI Standard C37.06-2000 Schedules of Preferred Ratings and Related Required Capabilities for AC High-Voltage Circuit Breakers Rated on a Symmetrical Current Basis
3. ANSI Standard C37.09-1964 Test Procedures for AC High-Voltage Circuit Breakers
4. ANSI Standard C37.09-1999 IEEE Standard Test Procedure for AC High-Voltage Circuit Breakers Rated on a Symmetrical Current Basis.
5. ANSI Standard C37.010-1999 Application Guide for AC High-Voltage Circuit Breakers
6. ANSI Standard C37.4-1953 Alternating-Current Power Circuit Breakers
7. ANSI Standard C37.6-1971 Schedules of Preferred Ratings for AC High-Voltage Circuit Breakers Rated on a Total Current Basis
8. ANSI Standard C37.9-1953 Test Code for Power Circuit Breakers
9. ANSI Standard C57.13-1993 Requirements for Instrument Transformers
10. ANSI Standard C76.1-1943 Apparatus Bushings and Test Code for Apparatus Bushings
11. ANSI Standard C76.1-1964 (R1970) American Standard Requirements and Test Code for Outdoor Apparatus Bushings
12. ANSI Standard C76.1-1976 IEEE General Requirements and Test Procedure for Outdoor Apparatus Bushings
13. PJM Report Guide for Determination of Current Transformer Ratings, 2009, by Heritage MACC Group a task force of the Transmission and Substation Subcommittee.
14. "Method of Predicting the Thermal Loading of an Oil Circuit Breaker" Proceeding, Institution of Electric Engineers, Vol. 112, No. 5, May, 1965, pp. 986-994.
15. McNutt, W. J. and Easley, J. K., "Mathematical Modeling – A Basis for Bushing Loading Guides," IEEE Transactions on Power Apparatus & Systems, Vol. PAS-97, pages 2393-2404, November/December, 1978.
16. PJM Manual 03: "Transmission Operations", Revision: 37, June 18, 2010.